



THE ASSAM GAZETTE

অসাধাৰণ

EXTRAORDINARY

প্ৰাপ্ত কৰ্তৃত্বৰ দ্বাৰা প্ৰকাশিত

PUBLISHED BY THE AUTHORITY

নং 550 দিশপুৰ, সোমবাৰ, 11 নবেম্বৰ, 2024, 20 কাৰ্ত্তি, 1946 (শক)
No. 550 Dispur, Monday, 11th November, 2024, 20th Kartika, 1946 (S. E.)

GOVERNMENT OF ASSAM
ORDERS BY THE GOVERNOR
ASSAM ELECTRICITY REGULATORY COMMISSION

NOTIFICATION

The 5th November, 2024

Assam Electricity Regulatory Commission (Terms and Conditions for determination of Multi Year Tariff) Regulations, 2024

No. AERC.944/2024/25.- In exercise of powers conferred by clauses (zd), (ze) and (zf) of sub section (2) of section 181, read with sections 61, 62, and 86, of the Electricity Act 2003 (36 of 2003) and all other powers enabling it in this behalf, and in supersession of the Assam Electricity Regulatory Commission (Terms and Conditions for determination of Multi Year Tariff) Regulations, 2021 and after previous publication, the Assam Electricity Regulatory Commission hereby makes the following regulations:

CHAPTER 1: PRELIMINARY

1 Short title, extent, applicability and commencement

- 1.1 These Regulations shall be called the Assam Electricity Regulatory Commission (Terms and Conditions for determination of Multi Year Tariff) Regulations, 2024 for Generation, Transmission, SLDC, Distribution Wheeling and Retail Supply.
- 1.2 These Regulations shall come into force from the date of their notification in the Official Gazette of the Government of Assam.
- 1.3 These Regulations shall extend to the whole of the State of Assam.
- 1.4 These Regulations shall be applicable for determination of tariff in all cases covered under these Regulations from 1st April, 2025 onwards.
- 1.5 However, for all purposes including the review matters pertaining to the period till FY 2024-25, the issues related to determination of tariff shall be governed by Assam Electricity Regulatory Commission (Terms and Conditions for determination of Multi Year Tariff) Regulations, 2021 including amendments thereto.

- 1.6 These Regulations shall be applicable to all existing and future Generating Companies, Transmission Licensees, Distribution Wheeling and Retail Supply, SLDC and their successors, if any, within the state of Assam under Section 62 of the Act.
- (i) for supply of electricity by a generating company to a distribution licensee,
 - (ii) for transmission of electricity by a transmission licensee to a distribution licensee or to open access consumers and
 - (iii) for wheeling & retail supply of electricity by a distribution licensee.
 - (iv) in all other cases where the Commission has the jurisdiction for tariff determination.
 - (v) State load dispatch centre.
- 1.7 Notwithstanding anything contained in these regulations the Commission shall adopt the tariffs as may be determined through the process of competitive bidding, under Section 63 of the Act, in accordance with the competitive bidding guidelines notified by the Central Government.
- 1.8 These regulations shall not apply for tariff determination of renewable energy generation projects. The tariff for such generation projects shall be determined as per Assam Electricity Regulatory Commission (Terms & Conditions for determination of Tariff from Renewable Energy Sources) Regulations, 2024, and its subsequent amendment from time to time.

2 Definitions

2.1 In these Regulations, unless the context otherwise requires:

- (1) **“Accounting Statement”** means for each financial year, the following statements, namely-
- (i) balance sheet, prepared in accordance with the form contained in Part I of Schedule VI to the Companies Act, 2013 as amended from time to time;
 - (ii) profit and loss account, complying with the requirements contained in Part II of Schedule VI to the Companies Act, 2013;
 - (iii) cash flow statement, prepared in accordance with the Accounting Standard on Cash Flow Statement (AS-3) of the Institute of Chartered Accountants of India / Indian Accounting Standard on Cash Flow Statement (IND AS-7) issued by Accounting Standard Board as per the applicability;
 - (iv) report of the statutory auditors;
 - (v) cost records prescribed by the Central Government under Section 209 (1) (d) of the Companies Act, 2013;
 - (vi) together with notes thereto, and such other supporting statements and information as the Commission may direct from time to time;

Provided that in case of any local authority engaged in the business of distribution of electricity, the Accounting Statement shall mean the items, as mentioned above, prepared and maintained in accordance with the relevant Acts or Statutes as applicable to such local authority:

Provided further that the Commission may, from time to time, specify regulatory accounts to be maintained by the local authority under the Act:

Provided also that once the Commission notifies the Regulations for submission of Regulatory Accounts, the applications for tariff determination and truing up shall be based on the Regulatory Accounts.

- (2) **"Act"** means the Electricity Act, 2003 (36 of 2003), as amended from time to time;
- (3) **"Additional capitalization"** means the capital expenditure actually incurred or projected to be incurred after the date of commercial operation of the project and admitted by the Commission after prudence check;
- (4) **"Allocation Statement"** means for each financial year, a statement in respect of each of the separate businesses of the Generating Company or Transmission Licensee or SLDC or Distribution Licensee, showing the amounts of any revenue, cost, asset, liability, reserve or provision etc, which has been either:
 - (i) charged from or to each such Other Business together with a description of the basis of that charge; or
 - (ii) determined by apportionment or allocation between different businesses of the licensee including the Licensed Businesses, together with a description of the basis of the apportionment or allocation;

Provided that for the purpose of this Regulation, the licensed business of the Distribution Licensee for an area of supply would be separated as Distribution Wires and Retail Supply business:

Provided further that such allocation statement in respect of a generating station, owned and/or maintained and/or operated by the distribution licensee, shall be maintained in a manner so as to enable tariff determination, stage-wise, Unit wise and/or for the whole generating station.

- (5) **"Ancillary Service" or "AS"** in relation to power system operation means the service necessary to support the grid operation in maintaining power quality, reliability and security of the grid and includes Primary Reserve Ancillary Service, Secondary Reserve Ancillary Service, Tertiary Reserve Ancillary Service, active power support for load following, reactive power support, black start and such other services as defined in the Grid Code;
- (6) **"Applicant"** means a Generating Company or Transmission Licensee or SLDC or Distribution Licensee who has made an application for determination of Annual Revenue Requirement and Tariff in accordance with the Act and these Regulations and includes a Generating Company or Transmission Licensee or SLDC or Distribution Licensee whose tariff is the subject of a review by the Commission either on suo-motu basis or on a Petition filed by any interested or affected person or as part of an annual performance review;
- (7) **"Aggregate Revenue Requirement"** means the requirement of the Transmission Licensee or Distribution Licensee or Generating Company or SLDC for recovery, through tariff, of allowable

expenses and return on capital pertaining to its Licensed or Regulated Business for a particular financial year, in accordance with these Regulations;

- (8) **“Area of Supply”** means the area within which a Distribution Licensee is authorised by its licence to supply electricity;
- (9) **“Auditor”** means an auditor appointed by the Generating Company or Licensee or SLDC qualified for such appointment in accordance with the relevant provisions of the Companies Act; or any other Law for the time being in force ;
- (10) **“Auxiliary Energy Consumption”** in relation to a period in case of a generating station means the quantum of energy consumed by auxiliary equipment of the generating station, such as the equipment being used for the purpose of operating plant and machinery including switchyard of the generating station and the transformer losses within the generating station, expressed as a percentage of the sum of gross energy generated at the generator terminals of all the units of the generating station;

Provided further that power consumed in housing colony and other facilities of a Generating Station including the power consumed in construction phase shall not be included as part of the auxiliary consumption for the purpose of these Regulations.

- (11) **“Availability”** in relation to a thermal Generating Station for any period means the average of the daily average declared capacities as certified by Assam State Load Despatch Centre (SLDC) for all the days during that period expressed as a percentage of the installed capacity of the Generating Station minus normative auxiliary consumption in MW, as specified in these Regulations, and shall be computed in accordance with the following formula:

$$Availability = 10000 \times \sum_{i=1}^N DC_i / \{N \times IC \times (100 - AUXn)\} \%$$

Where:

N = number of time blocks in the given period

DC_i = Average Declared Capacity in MW for the *i*th time block in such period

IC = Installed Capacity of the Generating Station in MW

AUX = Normative Auxiliary Consumption in MW, expressed as a percentage of gross generation

- (12) **“Bank rate”** means the one year marginal cost of lending rate (MCLR) of the State Bank of India issued from time to time;
- (13) **“Base year”** means the financial year immediately preceding the first year of the Control Period and used for the purposes of these regulations;

- (14) **"Beneficiary"**
- (i) in relation to a Generating Station means the purchaser of electricity generated at such a Generating Station whose tariff is determined under these Regulations;
 - (ii) in relation to a Transmission Licensee, the Transmission System Users;
 - (iii) in relation to the Distribution Wires Business, the Generating Companies connected to the distribution system and consumers including open access consumers;
 - (iv) in relation to the Retail Supply Business, the consumers;
 - (v) in relation to the SLDC, the Distribution Licensees and Open Access consumers who utilise the Intra-State Transmission system for transmission of electricity and / or utilise the distribution system of a Licensee in the State for wheeling of electricity and / or avail the services of the SLDC relating to scheduling and real-time grid operations, State energy accounting, operation of pool account, etc.;
- (15) **"Block"** in relation to a combined cycle thermal Generating Station includes combustion turbine – generators, associated waste heat recovery boilers, connected steam turbine – generators and auxiliaries;
- (16) **"Bulk Power Transmission Agreement"** means an executed Agreement that contains the terms and conditions under which a Transmission System User is entitled to access an intra-State transmission system of a Transmission Licensee;
- (17) **"Capital Cost"** means the capital cost as determined in accordance with Chapter 5 of these regulations;
- (18) **"Change in law"** means occurrence of any of the following events:
- (i) enactment, bringing into effect or promulgation of any new Indian law; or
 - (ii) adoption, amendment, modification, repeal or re-enactment of any existing Indian law; or
 - (iii) change in interpretation or application of any Indian law by a competent court, Tribunal or Indian Governmental Instrumentality which is the final authority under law for such interpretation or application; or
 - (iv) change by any competent statutory authority in any condition or covenant of any consent or clearances or approval or licence available or obtained for the project; or
 - (v) coming into force or change in any bilateral or multilateral agreement/treaty between the Government of India and any other Sovereign Government having implication for the generating station or the transmission system regulated under these Regulations.
- (19) **"Commission"** means the Assam Electricity Regulatory Commission;
- (20) **"Competitive Bidding"** means a transparent process for procurement of equipment, services and works in which bids are invited by the project developer by open advertisement covering the scope and specifications of the equipment, services and works required for the project, and the terms and conditions of the proposed contract as well as the criteria by which bids shall be

evaluated, and shall include domestic competitive bidding and international competitive bidding;

- (21) **“Conduct of Business Regulations”** means the Assam Electricity Regulatory Commission (Conduct of Business) Regulations, 2004 as amended from time to time;
- (22) **“Contracted Capacity”** means the capacity in MW contracted by long-term Transmission System User as part of its long term power procurement plan through a power purchase agreement and shall be equivalent to the deemed Transmission Capacity Right of a Transmission System User;
- (23) **“Control Period”** means the period comprising of five years from April 1, 2025 to March 31, 2030, and for every block of five years thereafter or such other period as may be decided by the Commission, for submission of forecast in accordance with Chapter 3 of these Regulations;
- (24) **“Cut-off Date”** means 31st March of the year closing after two years of the year of commercial operation of the project, and in case the project is declared under commercial operation in the last quarter of a year, the cut-off date shall be 31st March of the year closing after three years of the year of commercial operation;
- (25) **“Date of Commercial Operation”** or **“COD”** means in respect of a thermal generating station or hydro generating station or transmission system or communication system shall have the same meaning as defined in the Grid Code, as amended from time to time
- (26) **“Day”** means the 24 hour period starting at 00:00 hour;
- (27) **“De-Capitalisation”** for the purpose of the tariff under these regulations, means reduction in Gross Fixed Assets of the project corresponding to the removal/deletion of assets as admitted by the Commission;
- (28) **“De-Commissioning”** means removal from service of a generating station or a unit thereof or transmission system including communication system or element thereof, based on the decision of the Board of Directors/Management Authority of the Generating Company, with intimation to the Central Electricity Authority and the Commission, either on its own or on an application made by the project developer or the beneficiaries or both, that the project cannot be operated due to non performance of the assets on account of technological obsolescence or uneconomic operation or a combination of these factors;
- (29) **“Declared Capacity”** (DC) shall mean the capability of the generating station to deliver ex-bus electricity in MW declared by such generating station in relation to any time-block of the day as defined in the AERC Grid Code or whole of the day, duly taking into account the availability of fuel;

Note:

- (i) In case of a gas turbine generating station or a combined cycle generating station, the generating station shall declare the capacity for units and modules on gas fuel

and liquid fuel separately, and these shall be scheduled separately. Total declared capacity and total scheduled generation for the generating station shall be the sum of the declared capacity and scheduled generation for gas fuel and liquid fuel for the purpose of computation of availability and Plant Load Factor respectively.

- (ii) Declared capacity however shall be limited to Installed Capacity.
 - (iii) Daily average declared capacity means the sum of capacity declared for every fifteen minutes block during the twenty four hour period divided by ninety six.
 - (iv) for hydro power Generating Stations, the ex-bus capacity in MW expected to be available from the Generating Station for the ith day of the month, which the station can deliver for at least three (3) hours, taking into account the availability of water. This shall be certified by the State Load Dispatch Centre after the day is over.;
- (30) **"Design Energy"** in relation to a hydro power Generating Station means the quantum of energy, which could be generated in a 90 per cent dependable year with 95 per cent installed capacity of the Generating Station;
- (31) **"Distribution Retail Supply Business"** means the business of sale of electricity by a distribution licensee to the consumers within the area of supply in accordance with the terms of the licence for distribution and retail supply of electricity;
- (32) **"Distribution Wheeling Business"** means the business of operating and maintaining a distribution system for wheeling of electricity in the area of supply of the Distribution Licensee;
- (33) **"Expected Revenue from Tariff and Charges"** means the revenue estimated to accrue to the Generating Company or Transmission Licensee or SLDC or Distribution Licensee from the Regulated Business at the prevailing tariff;
- (34) **"Existing Generating Unit/Station"** means a Generating Unit/ Station declared under commercial operation prior to the date of effectiveness of these Regulations;
- (35) **"Existing Project"** means a project declared under commercial operation prior to the date of effect of these Regulations;
- (36) **"Event"** means an unscheduled or unplanned occurrence in the intra-State transmission system including faults, incidents and breakdowns;
- (37) **"Fees and Charges Regulations"** means the "AERC (Payment of Fee etc) Regulations, 2020" as amended from time to time;
- (38) **"Force Majeure Event"** means, with respect to any party, any event or circumstance, which is not within the reasonable control of, and is not due to an act of omission or commission of, that party and which, by the exercise of reasonable care and diligence, could not have been prevented, and without limiting the generality of the foregoing, would include the following events:

- (i) acts of God, including but not limited to lightning, storm, action of the elements, earthquakes, flood, torrential rains, drought and natural disaster;
 - (ii) strikes, lockouts, go-slow, bandh or other industrial disturbances not instigated by any party and epidemic/pandemic on large scale or under such other specific circumstances;
 - (iii) acts of public enemy, wars (declared or undeclared), blockades, insurrections, riots, revolution, sabotage, vandalism and civil disturbance;
 - (iv) unavoidable accident, including but not limited to fire, explosion, radioactive contamination and toxic dangerous chemical contamination;
 - (v) any shutdown or interruption of the grid, which is required or directed by the State or Central Government or by the Commission or the State Load Despatch Centre; and
 - (vi) any shut down or interruption, which is required to avoid serious and immediate risks of a significant plant or equipment failure.
- (39) **"Gas-engine based Generating Station"** means generating station which generates power through reciprocating gas engines using natural gas or RLNG as fuel;
- (40) **"Generation Business"** means the business of production of electricity from a Generating Station for the purpose of (i) giving supply to any premises or enabling a supply to be so given (ii) for the purpose of supply of electricity to any Distribution Licensee in accordance with the Act and the rules and regulations made thereunder and, (iii) subject to the Regulations made under sub-section (2) of Section 42 of the Act, supply of electricity to any consumer;
- (41) **"Gross Calorific Value"** in relation to a thermal Generating Station means the heat produced in kilocalories by complete combustion of one kilogram of solid fuel or one litre of liquid fuel or one standard cubic metre of gaseous fuel, as the case may be;
- (42) **"Gross Station Heat Rate"** means the heat energy input in kcal required to generate one kWh of electrical energy at generator terminals;
- (43) **"Implementation Agreement"** means a legally valid agreement, contract or memorandum of understanding, or any such covenant, entered into (i) between transmission licensee and generating station or (ii) between transmission licensee and developer of the associated transmission system for the execution of project in coordinated manner;
- (44) **"Infirm power"** means electricity injected into the grid prior to the commercial operation of a Unit or Block of the Generating Station;
- (45) **"Installed Capacity"** means the summation of the name plate capacities of all the Units of the Generating Station or the capacity of the Generating Station (reckoned at the generator terminals) as approved by the Commission from time to time;
- (46) **"Intra-State Transmission System (InSTS)"** means any system for conveyance of electricity by transmission lines within the area of the State and includes all transmission lines, sub-stations and associated equipment of Transmission Licensees in the State:

- (47) **‘Investment Approval’** means approval by the Board of the Generating Company or the Transmission Licensee or State Load Despatch Centre or Distribution Licensee or any other competent authority conveying administrative sanction for the project, including funding of the project and the timeline for the implementation of the project:

Provided that the date of Investment Approval shall be reckoned from the date of the resolution of the Board of the generating company or the transmission licensee or State Load Despatch Centre or Distribution Licensee where the Board is competent to accord such approval and from the date of sanction letter of competent authority in other cases;

- (48) **‘Landed Fuel Cost’** means the total cost of coal (including biomass in case of co firing), lignite or the gas/naphtha/liquid fuel delivered at the unloading point of the generating station and shall include the base price or input price, washery charges wherever applicable, transportation cost (overseas or inland or both) and handling cost, charges for third party sampling and applicable statutory charges;
- (49) **‘Licensee’** means any person or persons granted license under Section 14 or exempted under Section 13 of the Act including deemed licensee;
- (50) **‘Licensed Business’** means the functions and activities, which the licensee(s) is required to undertake in terms of the license granted by the Commission or as a deemed Licensee(s) under the Act;
- (51) **‘Maximum Continuous Rating’** or **‘MCR’** in relation to a Unit of the thermal Generating Station means the maximum continuous output at the generator terminals, guaranteed by the manufacturer at rated parameters, and in relation to a Block of a combined cycle thermal Generating Station means the maximum continuous output at the generator terminals, guaranteed by the manufacturer with water or steam injection (if applicable) and corrected to 50 Hz grid frequency and specified site conditions;
- (52) **‘New Generating Unit/Station’** means a Generating Unit/Station declared under commercial operation on or after the date of coming into force of these Regulations;
- (53) **‘Net Calorific Value’** means the amount of usable heat energy released when a fuel is burned under conditions similar to those in which it is normally used. When fossil fuels are burned, the carbon and hydrogen in these fuels combine with oxygen in the air to produce carbon dioxide and water. Some of the energy released in burning goes into transforming the water into steam and is usually lost. The amount of heat spent in transforming the water into steam is not counted as part of net heat content;
- (54) **‘New Project’** means the generating station or unit thereof or the transmission or distribution system or element thereof achieving its commercial operation on or after 1.4.2025;
- (55) **‘Normative Annual Plant Availability Factor’** or **‘NAPAF’** in relation to a thermal generating station means the availability factor specified in Regulation 48.8 and in relation to a hydro generating station means the availability factor specified in Regulation 50;

- (56) **"Non-Tariff Income"** means income relating to the regulated business other than from tariff, excluding any income from Other Business and, in case of the Retail Supply Business of a Distribution Licensee, excluding income from wheeling and receipts on account of cross-subsidy surcharge and additional surcharge on charges of wheeling;
- (57) **"Open Access Regulations"** means the Assam Electricity Regulatory Commission (Terms and Conditions for Open Access) Regulations, as amended from time to time;
- (58) **"Operation and Maintenance expenses" or "O&M expenses"** means
- (i) in relation to a Generating Company, the expenditure incurred on operation and maintenance of the project of a Generating Company, or part thereof, and includes the expenditure on manpower, repairs, spares, consumables, insurance and overheads, but excludes fuel expenses and water charges;
 - (ii) in relation to a Transmission Licensee or SLDC or Distribution Licensee, the expenditure incurred on operation and maintenance of the system by the Transmission Licensee or Distribution Licensee or SLDC, and includes the expenditure on manpower, repairs, spares, consumables, insurance and overheads;
- (59) **"Original Project Cost"** means the capital expenditure incurred by the Generating Company or Transmission Licensee or Distribution Licensee, as the case may be, within the original scope of the project up to the cut-off date as admitted by the Commission;
- (60) **"Other Business"** means any business undertaken by the Generating Company, Transmission Licensee or Distribution Licensee, other than the business regulated by the Commission;
- (61) **"Plant Availability Factor (PAF)"** in relation to a generating station for any period means the average of the daily declared capacities (DCs) for all the days during the period expressed as a percentage of the installed capacity in MW less the normative auxiliary energy consumption;
- (62) **"Plant Load Factor (PLF)"** in relation to a thermal Generating Station for a given period, means the total sent-out energy corresponding to actual ex-bus generation during such period, expressed as a percentage of sent out energy corresponding to installed capacity in that period and shall be computed in accordance with the following formula:

$$\text{Plant Load Factor} = 10000 \times \sum_{i=1}^N AG_i / \{N \times IC \times (100 - AUX_n)\} \%$$

Where:

N = Number of time blocks during the period

AG_i = Actual Ex-bus Generation in MW for the i^{th} time block of the period

IC = Installed Capacity of the Generating Station or Unit in MW

AUXn = Normative Auxiliary Consumption in MW, expressed as a percentage of gross generation

- (63) **"Project"** means
- i) in the case of a thermal generating station, all components of the thermal generating station and including an integrated coal mine, biomass pellet handling system, pollution control system, and effluent treatment plan, as may be required;
 - ii) in the case of a hydro generating station, all components of the hydro generating station including the dam, intake water conductor system, power generating station and generating units of the scheme, as apportioned to power generation; and
 - iii) in case of transmission & distribution, all components of the transmission and distribution system, including the communication system as the case may be;
- (64) **'Prudence Check'** means scrutiny of reasonableness of capital expenditure incurred or proposed to be incurred, financing plan, use of efficient technology, cost and time over-run and such other factors as may be considered appropriate by the Commission for determination of tariff. While carrying out the Prudence Check, the Commission shall look into whether the generating company or transmission licensee or distribution licensee has been careful in its judgments and decisions for executing the project or has been careful and vigilant in executing the project or other decisions that may have any impact on tariff;
- (65) **'Pumped storage hydro generating station'** means a hydro station which generates power through energy stored in the form of water energy, pumped from a lower elevation reservoir to a higher elevation reservoir;
- (66) **"Rated Voltage"** means the manufacturer's design voltage at which the transmission system is designed to operate or such lower voltage at which the line is charged, for the time being, in consultation with Transmission System Users;
- (67) **"Regulated Business"** means any electricity business, which is regulated by the Commission;
- (68) **"Retail Supply Business"** shall mean the business of sale of electricity by a Distribution Licensee to its Consumers in accordance with the terms of its license;
- (69) **"Revised Emission Standards"** in respect of thermal generating station means the revised 15 norms notified as per Environment (Protection) Amendment Rules, 2015 or any other Rules as may be notified from time to time;
- (70) **"Run-of-river Generating Station"** means a hydro Generating Station, which does not have upstream pondage;
- (71) **"Run-of-river Generating Station with pondage"** means a hydro Generating Station with sufficient pondage for meeting the diurnal variation of power demand;

- (72) **"Scheduled Commercial Operation Date"** or **"SCOD"** shall mean the date(s) of commercial operation of a generating station or generating unit thereof or transmission / distribution system or element thereof and associated communication system as indicated in the Investment Approval or as agreed in power purchase agreement or transmission service agreement as the case may be, whichever is earlier;
- (73) **"Scheduled Energy"** means the quantum of energy scheduled by the State Load Dispatch Centre to be injected into the grid by a generating station for a given time period;
- (74) **"Scheduled Generation"** or **"Scheduled injection"** for a time block or any period means the schedule of generation or injection in MW or MWh ex-bus, including the schedule for Ancillary Services given by the concerned Load Dispatch Centre in accordance with the Grid Code;
- (75) **"Schedule Drawal"** for a time block or any period means the schedule of drawal in MW or MWh ex-bus, including the schedule for Ancillary Services given by the concerned Load Dispatch Centre;
- (76) **"Small Gas Turbine Generating Station"** means and includes open cycle gas turbine or combined cycle generating station with gas turbines in the capacity range of 50 MW or below;
- (77) **"State Load Dispatch Centre"** or **"SLDC"** means the centre established by the State Government for purposes of exercising the powers and discharging the functions under Section 31 of the Act;
- (78) **"State Transmission Utility"** means the Board or the Government Company specified as such by the State Government under sub-section (1) of Section 39 of the Act;
- (79) **"Storage type power station"** means a hydro power Generating Station associated with large storage capacity to enable variation in generation of electricity according to demand;
- (80) **"Transmission Service Agreement"** means the agreement, contract, memorandum of understanding, or any such covenant, entered into between the Transmission Licensee / STU and the beneficiary for the operational phase of the transmission system;
- (81) **"Transmission System"** means a line or a group of lines with or without associated sub-station, and includes equipment associated with transmission lines and sub-stations;
- (82) **"Transmission System User"** means a person who has been allotted transmission capacity rights to access an intra-State transmission system pursuant to a Bulk Power Transmission Agreement, except as provided in the Open Access Regulations;
- (83) **"Trial Run"** in relation to generating station or unit thereof shall mean the successful running of the generating station or unit thereof at maximum continuous rating or installed capacity for continuous period of 72 hours in case of unit of a thermal generating station or unit thereof and 12 hours in case of a unit of a hydro generating station or unit thereof;

Provided that where the beneficiaries have been tied up for purchasing power from the generating station, the trial run shall commence after seven days notice by the generating company to the beneficiaries;

- (84) **"Trial operation"** in relation to a transmission system or an element thereof shall mean successful charging of the transmission system or an element thereof for 24 hours at continuous flow of power, and communication signal from sending end to receiving end and with requisite metering system, telemetry and protection system in service enclosing certificate to that effect from concerned State Load Dispatch Centre;
- (85) **"Unit"** in relation to a thermal Generating Station other than combined cycle thermal Generating Station means steam generator, turbine-generator and auxiliaries, or in relation to a combined cycle thermal Generating Station, means turbine-generator and auxiliaries; and in relation to a hydro Generating Station means turbine-generator and its auxiliaries;
- (86) **"Useful life"** in relation to a Unit of a Generating Station, transmission system and distribution from the date of commercial operation shall mean the following, namely:-
- | | | |
|-------|--|------------|
| i) | Coal based thermal generating Station | - 25 years |
| ii) | Gas/Liquid fuel based thermal Generating Station | - 25 years |
| iii) | Gas-engine based thermal Generating Station | - 25 years |
| iv) | Gas Insulated Substation (GIS) | - 25 years |
| v) | AC and DC sub-station | - 25 years |
| vi) | Hydro Generating Station including Pump Storage | - 40 years |
| vii) | Transmission line (including HVAC & HVDC) | - 35 years |
| viii) | Distribution line | - 35 years |
| ix) | Optical Ground Wire (OPGW) | - 15 years |
| x) | IT system, SCADA, and Communication System
Excluding OPGW | - 7 years |

Provided that in the case of coal/lignite based thermal generating stations and hydro generating stations, the Operational Life may be 35 years and 50 years, respectively.

Provided further that the extension of life of the projects beyond the completion of their useful life shall be decided by the Commission;

- (87) **"Wheeling"** means the operation whereby the distribution system and associated facilities of a distribution licensee are used by another person for the conveyance of electricity on payment of charges to be determined under section 62, and in the event where use of the distribution system and associated facilities is by a consumer, on payment of a surcharge in addition to the

charges for wheeling as may be determined by the Commission under the first proviso to sub-section (2) of Section 42, an additional surcharge on the charges of wheeling, as may be specified by the Commission, if applicable, to meet the fixed cost of such distribution licensee arising out of his obligation to supply, under sub-section (4) of Section 42 and wheeling charges under clause (c) of sub-section (1) of Section 62;

(88) **“Wheeling Business”** means the business of operating and maintaining a distribution system for conveyance of electricity in the area of supply of the distribution licensee;

(89) **“Year”** means the financial year ending on 31st March;

2.2 Words or expressions occurring in these Regulations and not defined shall bear the same meaning as in the Electricity Act, 2003, as amended from time to time.

CHAPTER 2: GENERAL PRINCIPLES

3 Object, Scope of Regulations and Extent of Application

- 3.1 The objective of these Regulations is to specify the terms and conditions for the determination of tariffs by the Assam Electricity Regulatory Commission for the supply of electricity by a generating company to a distribution licensee, for transmission of electricity, for wheeling of electricity and for retail sale of electricity, and SLDC.
- 3.2 The Commission in specifying these Regulations is guided by the principles contained in Sections 61 and 62 of the Act, the National Electricity Policy, 2005 and the Tariff Policy, 2016 notified by the Central Government under Section 3 of the Act.
- 3.3 The Commission shall determine tariff, including terms and conditions thereof, for all matters for which the Commission has jurisdiction under the Act, including in the following cases:-
- a) Supply of electricity by a Generating Company to a Distribution Licensee;
 - b) Intra-State transmission of electricity;
 - c) State Load Dispatch Centre;
 - d) Wheeling Business of electricity;
 - e) Retail Supply Business of electricity;

Provided that the Commission shall determine such tariff, having regard to the terms and conditions contained in Chapter 6, 7, 8, 9 & 10 of these Regulations for applications under this Regulation for determination of tariff, for generation, transmission, distribution Wheeling business and retail supply business and SLDC:

Provided also that in case of distribution of electricity in the same area by two or more Distribution Licensees, the Commission may, for promoting competition among Distribution Licensees, fix only maximum ceiling of tariff for retail sale of electricity:

Provided further that the Commission, while determining tariff upon an application made to it under this Regulation, shall also have regard to the terms and conditions of tariff as may be specified by the State Commission of such other State and/or the terms and conditions of tariff as may be specified by the Central Commission where any of the Parties to such transaction come under the jurisdiction of such State Commission or of the Central Commission under Section 63 of the Act.

Provided that the petition shall provide such information as the Commission may require to satisfy itself that the guidelines issued by the Central Government have been duly followed.

- 3.4 Notwithstanding anything contained in these Regulations, the Commission shall adopt the tariff if such tariff has been determined through a transparent process of bidding in accordance with the guidelines issued by the Central Government.

4 Multi-Year Tariff Framework

- 4.1 The Commission shall determine the tariff for matters covered under Regulation 3.3 above under a Multi-Year Tariff framework with effect from 1st April, 2025.

- 4.2 The Multi-Year Tariff framework shall be based on the following elements, for calculation of Aggregate Revenue Requirement and expected revenue from tariff and charges for Generating Companies, Transmission Licensee, SLDC, Distribution Wheeling Business and Retail Supply Business:

- (i) Submission of a Multi-Year Tariff Petition by the Applicant at the beginning of the control period, comprising forecast of Aggregate Revenue Requirement for the entire Control Period and expected revenue from existing tariff and Charges, expected revenue gap or surplus, for each year of the Control Period, and proposed tariff and charges for ensuing year, i.e. first year of the Control Period:

Provided that the Distribution Licensees shall propose the category-wise tariff for the first year of the Control Period:

Provided also that Multi-Year Tariff Petition shall also include true-up for FY 2023-24 and the Annual Performance Review for FY 2024-25 to be carried out under Assam Electricity Regulatory Commission (Terms & Conditions of Multi-Year Tariff) Regulations, 2021.

- (ii) A detailed Capital Investment Plan for each year of the Control Period, shall be submitted by the applicant for the Commission's approval;
- (iii) The applicant shall submit operating norms and trajectories of performance parameters for each year of the Control Period, for the Commission's approval;
- (iv) The applicant shall submit the forecast of Aggregate Revenue Requirement and expected revenue from existing tariff for each financial year of the Control Period, and the Commission shall approve the tariff for Generating Companies, SLDC, Transmission Licensee, Distribution Wheeling Business and Retail Supply Business, for each year of the Control Period. The tariff shall be reviewed at the time of the true-up and annual performance review;
- (v) In its tariff petition, a generating company shall submit information to support the determination of tariff for each generating station;
- (vi) Annual Performance review vis-à-vis the approved forecast and categorization of variation in performance as those caused by factors beyond the control of the applicant (uncontrollable items) shall be undertaken by the Commission;

- (vii) True up of the past years based on audited annual accounts of the licensees and the Generation companies shall also be undertaken;
 - (viii) The applicant shall, along with the tariff petition, submit a statement on the status of compliance of directives, if any, issued by the Commission in its previous tariff order.
 - (ix) The mechanism for pass-through of approved gains or losses on account of uncontrollable items as specified by the Commission in these Regulations;
 - (x) The mechanism for sharing of approved gains or losses arising out of controllable items as specified by the Commission in these Regulations;
 - (xi) There shall be no true-up of the controllable items except on account of Force Majeure events or on account of variations attributable to uncontrollable items. The variations in the controllable items, as defined in regulation 10, over and above the norms specified will be governed by incentive and penalty framework specified in these regulations;
 - (xii) The tariff determined by the Commission and the directions given in the MYT order shall be the quid pro quo and mutually inclusive. The tariff determined shall, within the time period specified in the order, be subject to the compliance of the directions by the generating company and the licensees to the satisfaction of the Commission. Non-compliance of directions given in the tariff order may also lead to invocation of the provisions of section 142 of the Act;
 - (xiii) The tariff determined by the Commission shall continue to operate till it is modified or revised by the Commission.
- 4.3 Filing under Multi-Year Tariff Framework by Generating Companies, Transmission Licensees, SLDC, and Distribution Licensees, shall be done as per the timelines and in compliance with the principles for determination of Aggregate Revenue Requirement as specified in these Regulations, in such form as may be prescribed by the Commission from time to time.
- 4.4 The norms specified under these Regulations are the ceiling norms and this shall not preclude the generating company and/ or licensee or any other person, as the case may be, from agreeing to improved norms of operation. In case the improved norms are agreed to, such norms shall be applicable for determination of tariff.
- 4.5 The Distribution Licensee also carrying out the generation business shall prepare separate Annual Accounts for each of its businesses, namely, for generation (for each of the generating plant), wheeling and retail supply, as the case may be:
- Provided that till such time as separate annual accounts are available, allocation statement as provided in these Regulations 17 shall be applicable.
- 4.6 The Commission shall specify ARR for each year of the Control Period and tariff for the first year of the Control Period for each business separately. However, the Commission may specify indicative tariff for the remaining years of the Control Period in the MYT order.

5. Control Period and Baseline

- 5.1 The first Control Period under these Regulations shall be of five financial years from 1st April, 2025 to 31st March, 2030 and for every block of five years thereafter or such other period as may be decided by the Commission.

Provided that in case any generating station gets commissioned after notification of these Regulations but before commencement of the first Control Period, the Commission may determine the tariff based on the norms as specified for such generating station under these Regulations, under special case through separate Order.

- 5.2 The Commission shall determine baseline values for various financial and operational parameters of ARR for the Control Period taking into consideration the figures approved by the Commission in the past, actual average figures of last three years, audited accounts, estimate of the figures for the relevant year, Industry benchmarks/norms and other factors considered appropriate by the Commission;

Provided that in case of substantial difference between the estimates earlier provided considered for determination of baseline values and the actual audited accounts, the Commission may re-determine the baseline values for the base year Suo-moto or on an application filed by the Applicant.

6 Capital Investment Plan

- 6.1 The Generating Company, Transmission Licensee, SLDC Business and Distribution Licensee shall submit a Capital Investment Plan for the entire Control Period with separate details for each year of the Control period, as part of the MYT Petition as per the timeline specified in this Regulation and accompanied by the Fee required for processing of Investment plan, as specified in AERC (Payment of Fee) Regulations 2024, and its subsequence amendment from time to time.

Provided that if the license is required to incur capital expenditure on any scheme declared by State/ Central Govt. after approval of the Capital Investment Plan; the licensee will move a separate petition before the Commission for approval.

- 6.2 The Capital Investment Plan for a generating company shall be based on planned generation capacity growth and shall contain among other things the following (i) generation forecasts; (ii) future performance targets; (iii) proposed efficiency improvement measures; (iv) saving in operating costs; (v) plan for reduction in per unit/per MW cost of generation (vi) financial statements (which include balance sheet, profit and loss statement and cash flow statement) - current and projected (at least for the control period duration) along with basis of projections; (vii) any other new measure to be initiated by the Generating Company e.g. IT initiatives, third party energy audit, safety initiatives etc.

- 6.3 The Capital Investment Plan for transmission licensee shall be based on proposed generation capacity addition and future load forecasts of the state and should contain among other things the following: (i) future plans/ performance targets of the company including efficiency improvement measures proposed to be introduced (ii) plans for meeting reactive power requirements; (iii) plan for reduction in transmission losses; (iv) plan for improvement in quality of transmission service and reliability; (v) metering arrangements; (vi) plan for reduction in per MW transmission cost, (vii) financial statements (which include balance sheet, profit and loss statement and cash flow statement)- current and projected (at least for the period of control period duration) along with basis of projections; (viii) any other new measure to be initiated by the Licensee e.g. IT initiatives, safety initiatives etc.
- 6.4 The Capital Investment plan for distribution licensee shall be based on sales forecast (MUs)/load growth and should contain among other things the following: (i) future plans/ performance targets of the company including efficiency improvement measures proposed to be introduced (ii) plan for reduction in distribution and non-technical losses;(iii) plan for improvement in quality of supply and reliability; (iv) metering arrangements; (v) plan for improvement in collection efficiency (vi) plan for improvement in consumer services/new consumer services (vii) plan for reduction in O&M cost per MU of energy sales (viii) MIS; (ix) scheme for third party energy audit (x) plan for improvement in metering and billing; (xi) financial statements (which include balance sheet, profit and loss statement and cash flow statement)-current and projected (at least for the period of control period duration) along with basis of projections; (xii) any other new measure to be initiated by the Licensee(s) e.g. IT initiatives, development of distribution franchisee, periodical business satisfaction surveys, safety initiatives etc.
- 6.5 The capital investment plan shall be project/scheme wise and for each scheme/project shall include:
- a) Purpose of investment;
 - b) Capital Structure;
 - c) Capitalization Schedule;
 - d) Financing Plan including identified sources of investment;
 - e) Details of physical parameters / targets;
 - f) Cost-benefit analysis and payback period;
 - g) Envisaged reduction in O&M cost/losses;
 - h) Ongoing projects that will spill into the year under review and new projects (along with justification) that will commence but may be completed within or beyond the control period.

- 6.6 The Capital Investment plan should be realistic in nature, the Capital Investment plan may be mainly of the following parts:
- (i) Plans which will be implemented under some tied up schemes or funding has already been arranged
 - (ii) Capital Investments which will get covered by some upcoming schemes/expected funding;
 - (iii) Other priority-based investments required to be undertaken, but no scheme/funding is available for them.
- 6.7 Purpose of investment shall include:
- (i) for a generation company - generation capacity growth, replacement of assets, renovation and modernization, reduction in average per unit cost of generation etc;
 - (ii) for a transmission licensee - power evacuation, system augmentation, network expansion, replacement of assets, reduction in transmission losses, improvement in transmission service and reliability of supply, reduction in per MW transmission cost, IT related projects etc;
 - (iii) for a distribution licensee - meeting load growth/ sales forecast (MUs), distribution loss reduction, non-technical loss reduction, replacement of assets, meeting reactive energy requirements, improvement in metering, consumer services, collection efficiency, quality and reliability of supply etc.
- 6.8 The capital investment plan, in case of a generation company, will be commensurate with generation capacity growth, renovation & modernization requirements etc.
- In case of a transmission licensee, the capital investment plan will be commensurate with load/generation capacity growth and will be linked to improvement in quality of transmission service, reliability, metering and reduction in transmission losses.
- The capital investment plan in case of a distribution licensee shall be commensurate with sales forecast (MUs) / load growth of the state, distribution/non-technical loss reduction targets, improvements envisaged in metering, collection efficiency, reliability and quality of supply etc.
- 6.9 Capital Investment for renovation and modernization in case of a transmission licensee and a generation company shall be made through an application with a detailed project report (DPR) elaborating the following elements: (i) Complete scope and justification; (ii) Estimated life extension of the generation/transmission asset; (iii) Improvement in performance parameters; (iv) Cost-benefit analysis; (v) Phasing of expenditure; (vi) Milestones/Time lines (vii) Schedule of completion; (viii) Estimated completion cost; (ix) Other aspects.
- 6.10 Capital investment plan shall incorporate list of schemes in order of priority so as to enable the Commission to approve the schemes in that order and in case lesser amount of capital expenditure is to be approved then the schemes of lower priority could be disapproved
- 6.11 The generation company and licensee shall submit all information / data required by the Commission for approval of the capital investment plan.

- 6.12 In the normal course, the Commission shall not revisit the approved capital investment plan during the control period. However, during the annual performance review and true-up, the Commission shall monitor the year wise progress of the actual capital expenditure incurred by the generating company or the licensee vis-à-vis the approved capital expenditure and in case of significant difference between the actual expenditure viz-a-viz the approved expenditure, the Commission may true up the capital expenditure, subject to prudence check, as a part of annual true up exercise or without an application to this effect by the generation company/licensee. The generating company and the licensee shall submit the scheme-wise actual capital expenditure incurred along with the annual performance review and true-up filing.
- 6.13 In case during execution of the project, the Capital Expenditure is estimated to cross 110% of the approved limit, the Licensee or company shall take approval of the Commission within one month.
- 6.14 In case during the annual performance review, large variations are observed in the actual cumulative capital expenditure incurred up to the current year starting from first year of the control period as against the approved capital expenditure, the Commission may revisit the costs incidental to the actual capital expenditure in the current year and remaining years of the control period.
- Provided that the actual capital expenditure incurred shall be only for the schemes as per the approved capital investment plan.
- Provided that if the actual capital expenditure incurred is more than the approved capital expenditure (whether at the time of MYT Order or separate approval before investment), the Commission may take appropriate decision at the of time true-up of the cost incidental to such variations.
- 6.15 In case the capital expenditure is required for emergency work which has not been approved in the Capital Investment Plan, the licensee shall submit an application, containing all relevant information along with reasons justifying emergency nature of the proposed work, seeking approval by the Commission. The licensee shall take up the work prior to the approval of the Commission provided that the emergency nature of the scheme has been certified by its Board of Directors.
- 6.16 The generation company and the licensee shall submit all information / data as required by the Commission for necessary approval of the Capital Investment plan.

7 Forecast of Aggregate Revenue Requirement

- 7.1 The applicant shall develop the forecast of Aggregate Revenue Requirement using the assumptions relating to the behavior of individual variables that comprise the Aggregate Revenue Requirement during the Control Period.
- 7.2 Forecast of expected revenue from tariff and charges

The applicant shall develop the forecast of expected revenue from tariff and charges based on the following:

- a) In the case of a Generating Company, estimates of expected energy generation and capacity allocated to Distribution Licensees and Open Access Customers for each financial year within the Control Period;
- b) In the case of a Transmission Licensee, estimates of transmission capacity allocated to Transmission System Users for each financial year within the Control Period;
- c) In the case of a Distribution Licensee, estimates of quantum of electricity to be supplied to consumers and wheeled on behalf of Distribution System Users for each financial year within the Control Period;
- d) In case of SLDC, estimates of allocated transmission capacity to users of intra State Transmission System for each financial year within the Control Period; and
- e) Prevailing tariff as at the date of making the application.

7.3 Based on the forecast of Aggregate Revenue Requirement and expected revenue from tariff and charges, the Generating Company or Transmission Licensee or Distribution Licensee or SLDC shall submit the forecast of tariff, that would meet the gap, if any, in the Aggregate Revenue Requirement.

7.4 The applicant shall provide full details supporting the forecast, including but not limited to details of past performance, proposed initiatives for achieving efficiency or productivity gains, technical studies, contractual arrangements and/or secondary research, to enable the Commission to assess the reasonableness of the forecast.

7.5 On receipt of application, the Commission shall either-

- a) Issue an order approving the tariff for the Control Period, subject to such modifications and conditions as it may specify in the said Order; or
- b) Reject the application for reasons to be recorded in writing, as the Commission may deem appropriate.

Provided that the applicant shall be given a reasonable opportunity of being heard before rejecting its application.

7.6 The Commission, in these Regulations, has specified the variables to be considered in the tariff determination of the applicant that shall be reviewed by the Commission as part of the Annual Performance Review in accordance with Regulation 8.

8 Annual Performance Review and True Up

8.1 Where the aggregate revenue requirement and expected revenue from tariff and charges of a Generating Company or Transmission Licensee or Distribution Licensee or SLDC is covered under a Multi-Year Tariff framework, then such Generating Company or Transmission Licensee

or Distribution Licensee or SLDC, as the case may be, shall be subject to an annual performance review and true up during the Control Period in accordance with this Regulation.

- 8.2 The Generating company, Transmission Licensee, SLDC and the Distribution Licensee shall file an application for annual performance review of current year, true-up of previous year and tariff for the ensuing year not less than 120 days before the close of each year of the control period.

Provided that the Generating Company or Transmission Licensee or Distribution Licensee or SLDC, as the case may be, submit to the Commission information in such form as may be stipulated by the Commission, together with the Accounting Statements, extracts of books of account and such other details as the Commission may require to assess the reasons for and extent of any variation in financial performance from the approved forecast of Aggregate Revenue Requirement and actual revenue from tariff and charges.

Provided further that the Petition for Truing Up shall be accompanied by Audited Annual Accounts. However, the Petitioner shall make available the CAG report whenever the Commission asks for.

Provided also that the information sought by the Commission shall be submitted in the formats as prescribed by the Commission.

- 8.3 The scope of the Annual Performance review and True up shall be a comparison of the actual performance of the Generating Company or Transmission Licensee or SLDC or Distribution Licensee with the approved forecast of Aggregate Revenue Requirement and expected revenue from tariff and charges and shall comprise the following:

- a) **True Up:** a comparison of the audited performance of the applicant for the previous financial year with the approved forecast for that financial year and truing up of expenses and revenue in line with Regulation 10 of this regulation including pass through of gain/loss pertaining to controllable and uncontrollable items;
- b) **Annual Performance Review:** a comparison of the performance targets estimated to be achieved for the current financial year (based on 6 months actual data) with the approved forecast for that financial year including adjusting trajectories of uncontrollable if needed.
- c) Categorisation of variations in performance with reference to approved forecast into factors within the control of the applicant (controllable items) and those caused by factors beyond the control of the applicant (un-controllable items):

Provided such categorization of the controllable and uncontrollable items shall be done in accordance with Regulation 10 of this regulation.

- 8.4 Upon completion of the review, the Commission shall attribute any variations or expected variations in performance, for variables specified under Regulation 10 below, to factors within

the control of the applicant (controllable items) or to factors beyond the control of the applicant (uncontrollable items):

Provided that any variations or expected variations in performance, for variables other than those specified under Regulation 10 below, shall not be reviewed by the Commission during the Control Period and shall be attributed entirely to controllable items:

Provided however, that where the applicant or any interested or affected party believes, for any variable not specified under Regulation 10 below that there is a material variation or expected variation in performance, for any financial year, on account of uncontrollable items, such applicant or interested or affected party may apply to the Commission for inclusion of such variable, during the Annual Performance Review for such financial year.

- 8.5 Upon completion of the True-Up and Annual Performance Review, the Commission shall pass an order recording-
- a) The approved aggregate gain or loss to the Generating Company or Transmission Licensee or Distribution Licensee or SLDC on account of controllable items and the amount of such gains or such losses that may be shared in accordance with Regulation 12;
 - b) The approved modifications to the forecast of the Generating Company or Transmission Licensee or Distribution Licensee or SLDC for the ensuing financial year; and
 - c) Revision of estimates for the ensuing financial year, if required, based on the audited financial results for the previous financial year.

9 Specific trajectory for certain variables

- 9.1 The Commission shall stipulate a trajectory while approving the MYT Petition for certain variables having regard to the reorganization, restructuring and development of the electricity industry in the State.
- 9.2 Provided that the variables for which a trajectory to be stipulated may include, but are not limited to,
- a) In case of Generating Stations:
Generating station's availability, station heat rate, secondary oil consumption, auxiliary consumption, transit losses, etc.
 - b) In case of Transmission Licensee:
Transmission losses, transmission system availability, etc.
 - c) In case of Distribution Licensee:
Supply availability, wheeling availability, distribution losses, Aggregate Technical and Commercial Losses (AT&C Loss), collection efficiency, and billing efficiency, etc.

10 Controllable and uncontrollable items

- 10.1 For the purpose of this regulation, the items of ARR shall be identified as 'controllable' or 'uncontrollable'. The variation on account of uncontrollable items shall be treated as a pass-through subject to prudence check/validation and approval by the Commission;

Provided that the Commission may allow variations in controllable items on account of Force Majeure events as pass-through in the ARR for the ensuing year based on actual values submitted by the generating company and licensees and subsequent validation and approval by the Commission during true-up.

Provided further that the Commission may allow variations in uncontrollable items as pass-through in the ARR for the ensuing year based on actual values submitted by the generating company and licensees and subsequent validation and approval by the Commission during true-up.

- 10.2 The items in the ARR shall be treated as 'controllable' or 'uncontrollable' as follows:

Controllable Items

ARR Element	Controllable
Availability	Controllable
Plant Load factor / Plant availability factor	Controllable
Heat Rate	Controllable
Auxiliary Energy Consumption	Controllable
Secondary Fuel Oil Consumption (SFC)	Controllable
O&M Expenses (excluding terminal liabilities with regard to employees on account of changes in pay scales or dearness allowance due to inflation)	Controllable
Depreciation	Controllable
Interest and Finance Charges	Controllable
Return on Equity	Controllable
Transit loss of coal	Controllable
Capital Expenditure	Controllable
Distribution Losses/ AT & C losses	Controllable
Collection Efficiency	Controllable
Intra State Transmission losses	Controllable (for Transmission Licensee)
Quality of Supply	Controllable
Delay in execution of the new projects on account of contractor or supplier or agency of the generating company or transmission/ distribution licensee	Controllable
Efficiency in the implementation of the new projects not involving an approved change in scope of such	Controllable

ARR Element	Controllable
new projects or change in statutory levies or change in law or force majeure events;	

Uncontrollable Items

ARR Element	Uncontrollable
Terminal liabilities with regard to employees on account of changes in pay scales or dearness allowance due to inflation	Uncontrollable
One-time expenses such as expense due to change in accounting policy & estimates, arrears paid due to revision of pay based on pay commission recommendations and interim relief etc.,	Uncontrollable
All statutory levies and taxes, if any excluding tax on Income	Uncontrollable
Land acquisition except where the delay is attributable to the generating company or the transmission/distribution licensee.	Uncontrollable
Fuel Price	Uncontrollable
Calorific Value of Fuel	Uncontrollable
Energy Sales	Uncontrollable
Power Purchase Price	Uncontrollable
Power Purchase Quantum (MUs)	Uncontrollable
Inter State Transmission losses	Uncontrollable
Intra State Transmission losses	Uncontrollable (for Distribution Licensee)
Non-Tariff income	Uncontrollable
Force Majeure events	Uncontrollable
Change in law, judicial pronouncements and Orders of the Central Government, State Government or Commission;	Uncontrollable

11 Mechanism for pass through of gains or losses on account of Uncontrollable items

- 11.1 The approved aggregate gain or loss to the Generating Company or Transmission Licensee or Distribution Licensee or SLDC on account of uncontrollable items shall be passed through as an adjustment in the tariff of the Generating Company or Transmission Licensee or Distribution

Licensee or SLDC over such period as may be specified in the Order of the Commission passed under these Regulations.

- 11.2 The Generating Company or Transmission Licensee or Distribution Licensee or SLDC shall submit such details of the variation between expenses incurred and revenue earned and the figures approved by the Commission, in the prescribed format to the Commission, along with the detailed computations and supporting documents as may be required for verification by the Commission.
- 11.3 Nothing contained in this Regulation shall apply in respect of any gain or loss arising out of variations in the price of fuel and power purchase, which shall be dealt with as specified by the Commission from time to time.

12 Mechanism for pass through of gains or losses on account of Controllable items

- 12.1 The approved aggregate gain to the Generating Company or Transmission Licensee or Distribution Licensee or SLDC on account of controllable items shall be dealt with in the following manner:
- a) Half (ratio of 50:50) of the amount of such gain shall be passed on as a rebate in tariff over such period as may be stipulated in the Order of the Commission.
 - b) The balance amount, which will amount to half (ratio of 50:50) of such gain, may be utilised at the discretion of the Generating Company or Transmission Licensee or Distribution Licensee or SLDC.
- 12.2 The approved aggregate loss to the Generating Company or Transmission Licensee or Distribution Licensee or SLDC on account of controllable items shall be dealt with in the following manner:
- a) One-third of the amount of such loss may be passed on as an additional charge in tariff over such period as may be stipulated in the Order of the Commission; and
 - b) The balance amount of loss shall be absorbed by the Generating Company or Transmission Licensee or Distribution Licensee or SLDC.

13 Carrying Cost or Holding Cost

The Commission shall allow Carrying Cost or Holding Cost, as the case may be, on the admissible amounts, with simple interest, at State Bank of India (SBI) MCLR prevailing during the concerned year plus 300 basis points.

Provided that Carrying Cost or Holding Cost shall be allowed on the net entitlement after sharing of efficiency gains and losses as approved after true-up:

Provided further that in case of Distribution Licensees, the Incentive on account of Distribution Losses, as applicable, shall be deducted from the net entitlement, for the purpose of computing Carrying Cost or Holding Cost.

Provided further that in case of Distribution Licensees, the carrying cost shall not be allowed on the gap in power purchase cost if the Distribution Licensee fails to recover the variation in power purchase cost in accordance with the AERC (Fuel and Power Purchase Price Adjustment) Regulations, 2024 and its amendments thereof.

14 Suo Motu

The Commission shall, at all times, have the authority, either Suo-Motu or on a petition filed by any interested or affected party, to determine the Tariff, including terms and conditions thereof, of Generation Company, Transmission Licensee, SLDC and Distribution Licensees and shall initiate the process of such determination in accordance with the procedure as specified:

Provided that the proceedings for such determination of Tariff, including terms and conditions thereof, shall be in the same manner as set out in the AERC (Conduct of Business Regulations) 2004, as amended from time to time.

CHAPTER 3: PROCEDURE FOR DETERMINATION OF TARIFF

15 Procedures relating to making an application for determination of Tariff

- 15.1 An application for determination of tariff shall be made in such form and in such manner as specified in this Regulation, and accompanied by such fees as may be specified under the AERC (Payment of Fees etc.) Regulations, 2024, as amended from time to time.
- 15.2 An application for determination of tariff for first year of the Control Period shall be made along with the Multi Year Tariff Petition for the Control Period under Regulation 5 and the Petition for determination of Tariff for subsequent years of the Control Period shall be made along with Petition for Annual Performance Review under Regulation 8.
- 15.3 The formats for furnishing information for calculating expected revenue and expenditure and for determining tariff shall be specified separately for Generation, Transmission, Distribution and SLDC charges. Information submitted in these formats should be accompanied by supporting documents/calculations and soft copies.
- 15.4 The proceedings to be held by the Commission for determination of tariff shall be in accordance with the AERC (Conduct of Business) Regulations, 2004, as amended from time to time.
- 15.5 Notwithstanding anything contained in these Regulations, the Commission shall at all times have the authority, either on suo-motu basis or on a Petition filed by any interested or affected Party, to determine the tariff, including terms and conditions thereof, of any Generating Company or Transmission Licensee or Distribution Licensee or SLDC:

Provided that such determination of tariff may be pursuant to an agreement or arrangement or otherwise whether or not previously approved by the Commission and entered into at any time before or after the commencement of the Act.

16 Review at the End of Control Period

- 16.1 At the end of the control period, the Commission shall review the achievement of objectives and implementation of the principles of MYT laid- down in these Regulations.
- 16.2 The end of the one control period may be the beginning of the next control period or as decided by the Commission. The Commission shall analyse the performance with respect to the targets set out at the beginning of the control period and shall determine the base value for the next control period, based on actual performance achieved, expected improvement and other relevant factors.

17 Determination of Generation Tariff

Existing Generating Station

- 17.1 Where the Commission has, at any time prior to the date of effect of these Regulations, approved a power purchase agreement or arrangement between a Generating Company and a Distribution Licensee or has adopted the tariff contained therein for supply of electricity from an existing generating Unit/Station, then the tariff for supply of electricity by the Generating Company to the Distribution Licensee shall be in accordance with tariff mentioned in such power purchase agreement or arrangement for such period as approved or adopted by the Commission.
- 17.2 Where, as on the date of effect of these Regulations, the power purchase agreement or arrangement between a Generating Company and a Distribution Licensee for supply of electricity from an existing generating Unit/Station has not been approved by the Commission or the tariff contained therein has not been adopted by the Commission or where there is no power purchase agreement or arrangement, then the supply of electricity by such Generating Company to the Distribution Licensee after the date of effectiveness of these Regulations shall be in accordance with a power purchase agreement approved by the Commission in accordance with Chapter 4 of these Regulations

Provided that an application for approval of such power purchase agreement or arrangement shall be made by the Distribution Licensee to the Commission within a period of three (3) months from the date of notification of these Regulations:

Provided further that the supply of electricity shall be allowed to continue under the present agreement or arrangement, as the case may be, until such time as the Commission approves of such power purchase agreement and shall be discontinued forthwith if the Commission rejects, for reasons recorded in writing, such power purchase agreement or arrangement.

New Generating Stations

- 17.3 The tariff for the supply of electricity by a Generating Company to a Distribution Licensee from a new generating Unit/Station shall be in accordance with tariff as per power purchase agreement approved by the Commission, except if such power purchase agreement has been exempted from requiring such approval in accordance with Chapter 4 of these Regulations.

Own Generating Stations

- 17.4 Where the Distribution Licensee also undertakes the business of generation of electricity, the transfer price at which electricity is supplied by the Generation Business of the Distribution Licensee to its Retail Supply Business shall be determined by the Commission:

Provided that the Commission shall have regard to the terms and conditions specified in Chapter 5 of these Regulations in determining the transfer price for such supply.

- 17.5 The Distribution Licensee also carrying out the generation business shall segregate the accounts of the Company into generation business (separate for each of the generating plant) and distribution business.
- 17.6 Until accounts are segregated, Distribution Licensee shall prepare an Allocation Statement to apportion costs and revenues to respective businesses so as to enable the Commission to clearly identify the direct and indirect costs relating to such business and return on equity capital accruing to such business.

The Allocation Statement shall be considered by the Commission only if it is certified by the Statutory Auditor/Cost Auditor and approved by the Board of Directors of the Distribution Licensee, and it shall be accompanied with an explanation of the methodology which shall be consistent over the Control Period.

- 17.7 The Distribution Licensee shall submit, along with the separate application for determination of tariff for retail supply of electricity, the information required under Chapter 5 of these Regulations relating to the Generation Business,
- 17.8 Notwithstanding anything contained in this Regulation 17, the Commission shall adopt the tariff for supply of electricity by a Generating Company to a Distribution Licensee if such tariff has been determined through transparent process of bidding in accordance with the guidelines issued by the Central Government:

Provided that the applicant shall furnish such information as the Commission may require to satisfy itself that the guidelines issued by the Central Government have been duly followed.

18 Determination of Tariff for Transmission, Distribution Wheeling Business, Retail Supply Business and SLDC

- 18.1 The Commission shall determine the tariff for Transmission, Distribution Wheeling Business, Retail Supply Business and SLDC based on an application made by the Licensee in accordance with the procedure contained in this Regulation 18.
- 18.2 The Commission shall determine the tariff for -
- a) Transmission of electricity, in accordance with the terms and conditions contained in Chapter 7 of these Regulations;
 - b) Distribution Wheeling Business, in accordance with the terms and conditions contained in Chapter 8 of these Regulations; and
 - c) Retail Supply Business, in accordance with the terms and conditions contained in Chapter 9 of these Regulations.
 - d) SLDC Business, in accordance with the terms and conditions contained in Chapter 10 of these Regulations.
- 18.3 The applicant shall provide as part of its application to the Commission, in such form as may be stipulated by the Commission from time to time, full details of its calculation of the Aggregate

Revenue Requirement and expected revenue from tariff and charges pursuant to the terms of its license, and thereafter he shall furnish such further information or particulars or documents as the Commission or the Secretary or any Officer designated for the purpose by the Commission may reasonably require to assess such calculation

Provided that the application shall be accompanied where relevant, by a detailed tariff revision proposal showing category-wise tariff and how such revision would meet the gap, if any, in Aggregate Revenue Requirement for each year of the Control Period.

Provided further that the Commission may specify additional/alternative formats for details to be submitted by the applicant, from time to time, as it may reasonably require for assessing the Aggregate Revenue Requirement and for determining the tariff.

18.4 Upon receipt of a complete application accompanied by all requisite information, particulars and documents in compliance with all the requirements specified in these Regulations, the application shall be deemed to be received and the Commission or the Secretary or the designated Officer shall intimate to the applicant that the application is ready for publication.

18.5 The applicant shall, within seven (7) days of an intimation given to him in accordance with Regulation 18.4, publish a notice, in at least two (2) English, and two (2) Assamese daily newspapers in English and Assamese language respectively. Publication of notice may also be done in other official languages of the State in newspapers widely circulated in the area to which the application pertains, outlining the proposed tariff, and such other matters as may be stipulated by the Commission, and inviting suggestions and comments from the public. The Commission may give separate direction in this regard.

Provided that the applicant shall also put up on its website, in downloadable spreadsheet format showing detailed computations, the application made to the Commission along with all regulatory filings, information, particulars and documents in the manner so stipulated by the Commission along with the public notice:

Provided further that the web-link to the information mentioned in the second proviso to Regulation 18.5 above shall be easily accessible, archived for downloading and shall be prominently displayed on the applicant's website:

Provided also that the applicant may not provide or put up any such information, particulars or documents, which are confidential in nature, with the prior approval of the Commission.

Explanation – for the purpose of this Regulation, the term “downloadable spreadsheet format” shall mean one (or multiple, linked) spreadsheet software files containing all assumptions, formulae, calculations, software macros and outputs forming the basis of the application.

18.6 The applicant shall furnish to the Commission all such books and records (or certified true copies thereof), including the Accounting Statements, operational and cost data, as may be required by the Commission for determination of tariff.

- 18.7 The Commission may, if it considers necessary, make or cause to be made available to any person, at any time, such information as has been provided by the applicant to the Commission including abstracts of such books and records (or certified true copies thereof) on such terms and conditions as may be specified in the AERC (Conduct of Business) Regulations, 2004, as amended from time to time:
- 18.8 The procedural aspects pertaining to applications contained in this Regulation 19 shall apply, only to such extent as may be required by the Commission having regard to the circumstances of an individual case, to -
- an application made by a Licensee under the proviso to sub-section (1) of Section 36 of the Act;
 - an application made by a Distribution Licensee under sub-section (5) of Section 64 of the Act.

19 Time limit for making an application for determination of Tariff

- 19.1 Generating company and the licensee shall adhere to the following schedule for various activities for the Control Period:

Time Schedule for various activities for the Control Period

S. No.	Description	Filing of the Document	Obtaining additional information and acceptance by the Commission	Approval of the Document by the Commission
1	Filing of MYT Petition (ARR and Tariff Proposal for the control period) along with Capital Investment Plan	By 30 th November of the year preceding the first year of the control period	Within 30 days of filing of document	Within 120 days of the admission of the petition
2	Annual Performance Review/ True-up	By 30 th November of each year of the control period	Within 30 days of filing of document	Within 120 days of admission of the petition

20 Tariff Order

- 20.1 The Commission shall, within one hundred and twenty (120) days from the receipt of a complete application & admission as per the AERC (Conduct of Business) Regulations, 2004 & amendment if any, and after considering all suggestions and objections received from the public under Section 64 of the Act:
- Issue a Tariff Order accepting the application with such modifications or such conditions as may be specified in that Order; or
 - Reject the application for reasons to be recorded in writing if such application is not in accordance with the provisions of the Act and the rules and Regulations made there under or the provisions of any other law for the time being in force:

Provided that an applicant shall be given a reasonable opportunity of being heard before rejecting his application.

- 20.2 The tariffs so determined shall be in force from the date specified in the said Order and shall, unless amended or revoked, continue to be in force for such period as may be stipulated therein.

21 Publication of Approved Tariff

- 21.1 The applicant shall within the time specified in the Order of the Commission, publish the salient features of the tariff approved by the Commission in at least two (2) English and two (2) Assamese language daily newspapers in English and Assamese language, respectively having wide circulation in the area of licensee and shall put up the approved tariff / tariff schedule on its website and make available for sale, a booklet containing such tariff or tariff, as the case may be, to any person upon payment of reasonable reproduction charges;
Provided that where the applicant is a Generating Company, the publication shall be in such newspapers as are widely circulated in the area of supply of the Distribution Licensee to whom the electricity is proposed to be supplied in terms of the Tariff Order and shall also be put up on the website of such Generation Company.

22 Communication of Tariff Order

- 22.1 The Commission shall, within seven days of passing the Order, send a copy of the Order to the Government of Assam, the Central Electricity Regulatory Commission, the Central Electricity Authority, SERC's, concerned licensees and generating company. The Commission shall also make available copy of the said Order to any person on payment of a fee fixed by the Commission.

23 Adherence to Tariff Order

- 23.1 No tariff or part of any tariff may be ordinarily amended, more frequently than once in the year, except in respect of any changes expressly permitted under the terms of fuel and power purchase price adjustment as may be specified in under the AERC (Fuel and Power Purchase Price Adjustment) Regulations, 2024 and Amendments if any, on account of fuel cost and power purchase cost.
- 23.2 The Commission, may, after satisfying itself for reasons to be recorded in writing, allow for the revision of tariff.
- 23.3 If any Generating Company or Transmission Licensee or Distribution Licensee or SLDC recovers a price or charge exceeding the tariff determined under Section 62 of the Act and in accordance with these Regulations, the excess amount shall be payable to the person who has paid such price or charge, along with interest equivalent to the base rate of the State Bank of India without prejudice to any other liability incurred by such Generating Company or Transmission Licensee or Distribution Licensee or SLDC.

-
- 23.4 The Generation Company or Transmission Licensee or Distribution Licensee or SLDC shall submit periodic information such as compliance to directives, etc. as may be directed by the Commission, containing operational and cost data to enable the Commission to monitor the implementation of its Order.

CHAPTER 4: POWER PURCHASE AND PROCUREMENT

24 Applicability

- 24.1 The Regulations contained in this Chapter shall apply to electricity purchase and procurement by a Distribution Licensee from a Generating Company or Trading Licensee or Distribution Licensee or from any other source through agreement or arrangement for purchase of power for distribution and supply within the State.

25 Power procurement guidelines

- 25.1 The Distribution Licensee shall undertake its power procurement during the year in accordance with the power procurement plan for the Control Period, which may include long-term, medium-term and short-term power procurement, approved by the Commission in accordance with these Regulations.
- 25.2 A Distribution Licensee shall follow the guidelines contained in this Chapter with respect to:
- a) Procurement of power under any arrangement or agreement with a term or duration exceeding seven (7) years (i.e., long-term power procurement);
 - b) Procurement of power under any arrangement or agreement with a term or duration exceeding three (3) months but not exceeding five years (i.e., medium-term power procurement); and
 - c) Procurement of power under any arrangement or agreement with a term or duration less than or equal to one (1) month at a time (i.e., short-term power procurement).

26 Power Procurement Plan

- 26.1 The Distribution Licensee shall prepare a plan for procurement of power (in MW/ MU) to serve the demand for electricity in its area of supply for the Control Period and submit such plan to the Commission for approval:

Provided that such power procurement plan shall be submitted for the Control Period commencing on April 1st of the first year of the respective Control Period.

Provided further that the power procurement plan shall be submitted along with the application for determination of tariff, in accordance with Chapter 2 of these Regulations.

Provided also that the power procurement plan submitted by the Distribution Licensee may include long-term, medium-term and short-term power procurement sources of power, in accordance with these Regulations.

- 26.2 The power procurement plan of the Distribution Licensee shall comprise of the following:
- a) A quantitative forecast of the unrestricted Base load and Peak Load demand for electricity for each tariff category, within its area of supply over the Control Period;

- b) An estimate of the quantities of electricity supply from the identified sources of generation and power purchase, including own generation, if any;
- c) An estimate of availability of power to meet the base load and Peak load requirement; Provided that such estimate of demand and supply shall be on month-wise basis in Mega Watt (MW) as well as expressed in Million Units (MU);
- d) Standards to be maintained with regard to quality and reliability of supply, in accordance with the AERC (Distribution Licensees' Standards of Performance) Regulations, 2021, as amended from time to time;
- e) Measures proposed for Renewable Purchase Obligation (RPO), energy conservation, energy efficiency and Demand Side Management; Provided that the utility shall maintain separate records of revenue/ expenditure related to individual DSM schemes/ PAT/ RPO approved by the Commission.
- f) The requirement for new sources of power generation and/or procurement, including augmentation of generation capacity and identified new sources of supply, based on (a) to (e) above;
- g) The impact of Open Access;
- h) The plan for procurement of power including quantities and cost estimates for such procurement;
- i) Impact of Storage capacities including Batteries, Electric Vehicle Charging Stations, etc.;

Provided that the forecast/estimate contained in the long-term procurement plan shall be stated for each year of the Control Period, in terms of quantities of power to be procured (in millions of units of electricity) and maximum demand (in MW / MVA):

Provided further that the forecasts/estimates shall be prepared for each month over the Control Period:

Provided also that the long-term procurement plan shall be a cost-effective plan based on available information regarding costs of various sources of supply.

- j) Short-term power procurement proposed shall be in accordance with Regulation 28 of these Regulations.

26.3 The forecasts/ estimates shall be prepared using forecasting techniques based on past data and reasonable assumptions regarding the future:

Provided that the forecasts/estimates shall take into account factors such as overall economic growth, consumption growth of electricity-intensive sectors, advent of competition in the electricity industry, trends in captive power, impact of loss reduction initiatives, improvement in Generating Station Plant Load Factors and other relevant factors.

26.4 Where the Commission has stipulated a percentage of the total consumption of electricity in the area of a Distribution Licensee to be purchased from co-generation and renewable sources

of energy, the power procurement plan of such Distribution Licensee shall include the plan for procurement from such sources at least upto the stipulated level.

- 26.5 The Distribution Licensee shall be required to forward a copy of the power procurement plan to the State Transmission Utility for verification of its consistency with the transmission system plan for the intra-State transmission system, prepared in accordance with the AERC (Terms and Conditions for Open Access) Regulations as amended from time to time;

Provided that the Distribution Licensee may also consult the State Transmission Utility at the time of preparation of the power procurement plan to ensure consistency of such plan with the transmission system plan.

- 26.6 The Distribution Licensee may, as a result of additional information not previously known or available to him at the time of submission of the procurement plan under Regulation 26.1, apply for a modification in the power procurement plan, for the remainder of the Control Period, as part of the application for Annual Performance Review under Regulation 8.

Provided that the Distribution Licensee may be allowed a modification of the power procurement plan under this Regulation not more than once in a financial year, i.e., during the Annual Performance Review.

- 26.7 The Commission may, as a result of additional information not previously known or available to the Commission at the time of submission of the procurement plan under Regulation 26.1, if it so deems, either on suo motu basis or on an application made by any interested or affected party, modify the procurement plan of the Distribution Licensee, for the remainder of the Control Period, as part of the Annual Performance Review.

Provided that the Commission may modify the power procurement plan under this Regulation as and when required.

- 26.8 The Commission shall review the power procurement plan of the Distribution Licensee, or any proposed modification thereto, and upon such review being completed, the Commission shall either-

- a) issue an order approving the power procurement plan, or modifications thereto, subject to such modifications and conditions as it may deem appropriate; or
- b) reject the power procurement plan or application for modification thereto, for reasons recorded in writing, if such plan is not in accordance with the guidelines contained in this Chapter, and direct the Distribution Licensee to submit a revised plan based on such considerations as it may specify:

Provided that the Distribution Licensee shall be given reasonable opportunity of being heard before rejecting its power procurement plan.

27 Approval of power purchase agreement/arrangement

27.1 Every agreement or arrangement for power procurement by a Distribution Licensee from a Generating Company or Licensee or from other source of supply entered into after the date of effect of these Regulations shall come into effect only with the prior approval of the Commission.

Provided that the prior approval of the Commission shall be required in respect of any agreement or arrangement for power procurement by the Distribution Licensee from a Generating Company or Licensee or from any other source of supply on a standby basis:

Provided further that the prior approval of the Commission shall also be required for any change to an existing arrangement or agreement for power procurement, whether or not such existing arrangement or agreement was approved by the Commission.

27.2 The Commission shall review an application for approval of power procurement agreement/arrangement having regard to the approved power procurement plan of the Distribution Licensee and the following factors:

- a) Requirement for power procurement under the approved power procurement plan;
- b) Adherence to a transparent process of bidding in accordance with guidelines issued by the Central Government;
- c) Adherence to the terms and conditions for determination of tariff specified under Chapter 5 of these Regulations where the process specified in (b) above has not been adopted;
- d) Availability (or expected availability) of capacity in the intra-State transmission system for evacuation and supply of power procured under the agreement/arrangement;
- e) Need to promote co-generation and generation of electricity from renewable sources of energy.

27.3 Where the terms and conditions specified under Chapter 5 of these Regulations are proposed to be adopted, the approval of the power purchase agreement between a Generating Company and a Distribution Licensee for supply of electricity from a new Generating Station may comprise of two steps, at the discretion of the applicant:

- a) Approval of a provisional tariff, on the basis of an application made to the Commission at any time prior to the application made under clause (b) below; and
- b) Approval of the final tariff, on the basis of an application made not later than three (3) months from the cut-off date.

28 Additional Short-term power procurement

28.1 The Distribution Licensee can undertake additional short-term power procurement during the year, over and above the power procurement plan for the Control Period approved by the Commission, in accordance with this Regulation.

- 28.2 Where there has been a shortfall or failure in the supply of electricity from any approved source of supply during the financial year, the Distribution Licensee may enter into additional short-term arrangement or agreement for procurement of power (short-term means upto period of one year):

Provided that if the total power purchase cost for any block of six months including such short-term power procurement exceeds 105% of the power purchase cost approved by the Commission for the respective block of six months, the Distribution Licensee shall have to obtain prior approval of the Commission; and

Provided further that the proposed short-term power procurement shall be in accordance with the AERC (Fuel and Power Purchase Price Adjustment) Regulations, 2024 and amendments thereof.

- 28.3 Where the Distribution Licensee has identified a new short-term source of supply from which power can be procured at a tariff that reduces its approved total power procurement cost, the Distribution Licensee may enter into a short-term power procurement agreement or arrangement with such supplier without the prior approval of the Commission.

- 28.4 The Distribution Licensee may enter into a short-term arrangement or agreement for procurement of power without the prior approval of the Commission when faced with emergency conditions that threaten the stability of the distribution system or when directed to do so by the State Load Despatch Centre to prevent grid failure.

- 28.5 Within fifteen (15) days from the date of entering into an agreement or arrangement for short-term power procurement for which prior approval is not required, the Distribution Licensee shall provide the Commission, full details of such agreement or arrangement, including quantum, tariff calculations, duration, supplier details, method for supplier selection and such other details as the Commission may require with regard to such agreement/arrangement to assess that the conditions specified in this Regulation 28 have been complied with:

Provided that where the Commission has reasonable grounds to believe that the arrangement or agreement entered into by the Distribution Licensee does not meet the criteria specified in Regulation 28.2 to Regulation 28.4 above, the Commission may disallow any increase in the total cost of power procurement (net of additional revenue) over the approved level arising there from or any loss incurred by the Distribution Licensee as a result, from being passed through to consumers.

- 28.6 Subject to the cases specified in Regulation 28.2 to Regulation 28.4 above, where the Distribution Licensee enters into any agreement or arrangement for short-term power procurement without the approval of the Commission, any increase in the total cost of power procurement (net of additional revenue) over the approved level arising there from shall be deemed to be a variation in performance attributable entirely to controllable factors.

CHAPTER 5: FINANCIAL PRINCIPLES

29 Capital Cost and capital structure

29.1 Capital cost for a project shall include -

- a) the expenditure incurred or projected to be incurred upto the date of commercial operation of the project,
- b) any gain or loss on account of foreign exchange risk variation on the loan during construction up to the date of commercial operation of the project, as admitted by the Commission, after prudence check
- c) interest during construction and financing charges, on the loans (i) being equal to 70% of the funds deployed, in the event of the actual equity in excess of 30% of the funds deployed, by treating the excess equity as normative loan, or (ii) being equal to the actual amount of loan in the event of the actual equity less than 30% of the funds deployed
- d) increase in cost in contract packages as approved by the Commission;
- e) interest during construction and incidental expenditure during construction as computed in accordance with Regulation 30.7 of these regulations
- f) capitalised initial spares subject to the ceiling rates specified in this Regulation; and
- g) additional capital expenditure or de-capitalization determined under Regulation 30;
- h) adjustment of revenue due to sale of infirm power in excess of fuel cost prior to the COD as specified under Regulation 45 of these regulations; and
- i) adjustment of any revenue earned by the transmission licensee by using the assets before COD.
- j) capital expenditure on account of ash disposal and utilization including handling and transportation facility;
- k) capital expenditure incurred towards railway infrastructure and its augmentation for transportation of coal upto the receiving end of the generating station but does not include the transportation cost and any other appurtenant cost paid to the railway;
- l) capital expenditure on account of biomass handling equipment and facilities, for co-firing;
- m) expenditure on account of fulfilment of any conditions for obtaining environment clearance for the project;
- n) expenditure on account of change in law and force majeure events;
- o) the capital cost admitted by the Commission prior to 01.04.2025 duly trued up by excluding liability, if any, as on 01.04.2025;
- p) Capital Cost incurred or projected to be incurred by a thermal generating station and distribution licensee on account of implementation of the norms under the Perform, Achieve and Trade (PAT) scheme of the Government of India shall be considered by the Commission subject to sharing of benefits accrued under the PAT scheme with the beneficiaries.

- q) expenditure on account of renovation and modernization as admitted by this Commission in accordance with regulation 30.5;
- r) additional capital expenditure or de-capitalization determined under Regulation 30;

Provided that the cost of the common assets forming part of the project, should be considered based on the suitable allocation and such allocated cost shall form part of the capital cost:

Provided further that the assets forming part of the project, but not in use, shall be excluded from the capital cost:

- 29.2 The capital cost admitted by the Commission after prudence check shall form the basis for determination of tariff:

Provided that where the Power Purchase Agreement entered into between the Generating Company and the Distribution Licensee provides a ceiling of actual expenditure, the original cost of project shall not exceed such ceiling for the purpose of these Regulations:

Provided further that prudence check may include scrutiny of the reasonableness of the capital expenditure, financing plan, interest during construction, use of efficient technology, cost over-run and time over-run and such other matters as may be considered appropriate by the Commission for determination of tariff:

Provided also that in case the site of a Hydro Generating Station is awarded to a developer (not being a State controlled or owned company) by the State Government by following a transparent process of bidding, any expenditure incurred or committed to be incurred including the premium payable to the State Government by the project developer for getting the project site allotted, shall not be included in the capital cost:

Provided also that the capital cost in case of such hydro Generating Station shall include:

- a) cost of approved Rehabilitation and Resettlement (R&R) plan of the project in conformity with National R&R Policy and R&R package as approved; and
- b) cost of the developer's 10% contribution towards Rajiv Gandhi Grameen Vidyutikaran Yojana (RGGVY) and Deen Dayal Upadhyay Grameen Vidyutikaran Yojana project in the affected area.
- c) For uninterrupted and timely development of Hydro projects, expenditure incurred towards developing local infrastructure in the vicinity of the power plant not exceeding Rs. 10 lakh/MW shall be considered as part of the Capital cost, and in case the same work is covered under budgetary support provided by the Government of India, the funding of such works shall be adjusted on receipt of such funds.

Provided that such funds shall be allowed only if the funds are spent through Indian Governmental Instrumentality;

- 29.3 The approved Capital Cost shall be considered for determination of tariff and if sufficient justification is provided for any escalation in the Project Cost, the same may be considered by the Commission subject to the prudence check:

Provided that in case the actual capital cost is lower than the approved capital cost, then the actual capital cost shall be considered for determination of tariff of the Generating Company or Transmission Licensee or Distribution Licensee or SLDC.

- 29.4 The actual capital expenditure on COD for the original scope of work based on audited accounts of the Company limited to original cost may be considered subject to the prudence check by the Commission.

- 29.5 The capital cost may include initial spares which shall be capitalized as a percentage of the Plant and Machinery cost upto the cut-off date, subject to the following ceiling norms:

- a) Coal-based fired thermal generating stations – 4.0%
- b) Gas Turbine/Combined Cycle thermal generating stations – 4.0%
- c) Hydro generating stations including pumped storage hydro generating station – 4.0%
- d) Transmission system
 - (i) Transmission line – 1.0%
 - (ii) Transmission Sub-station (Green Field) – 4.0%
Transmission Sub-station (Brown Field) – 6.0%
 - (iii) Series Compensation devices and HVDC Station – 4.0%
 - (iv) Gas Insulated Sub-station (GIS) (Green Field) – 5.0%
Gas Insulated Sub-station (GIS) (Brown Field) – 7.0%
 - (v) Communication System – 3.5%
 - (vi) Static Synchronous Compensator – 6.0%

Provided that:

Where the benchmark norms for initial spares have been published as part of the benchmark norms for capital cost by the Commission, such norms shall apply till the exclusion of the norms specified above:

Where the generating station has any transmission equipment forming part of the generation project, the ceiling norms for initial spares for such equipments shall be as per the ceiling norms specified for transmission system under these regulations:

Once the transmission project is commissioned, the cost of initial spares shall be restricted on the basis of plant and machinery cost corresponding to the transmission project at the time of truing up:

For the purpose of computing the cost of initial spares Plant and Machinery cost shall be considered as project cost as on cut-off date excluding IDC, IEDC, Land Cost and cost of civil works. The transmission licensee shall submit the breakup of head wise IDC & IEDC in its tariff application.

- 29.6 Scrutiny of the cost estimates by the Commission shall be limited to the reasonableness of the capital cost, financing plan, interest during construction, use of efficient technology, and such other matters for determination of tariff.
- 29.7 Any expenditure on replacement, renovation and modernization or extension of life of old fixed assets, as applicable to Generating Companies, Transmission Licensees, Distribution Licensees and SLDC, shall be considered after writing off the net value of such replaced assets from the original capital cost and shall be calculated as follows:

Net Value of Replaced Assets = OCFA – AD; Where; OCFA: Original Capital Cost of Replaced Assets; AD: Accumulated depreciation pertaining to the Replaced Assets.

- 29.8 The capital cost incurred or projected to be incurred on account of the Perform, Achieve and Trade (PAT) scheme or sewage treatment plant or to achieve revised Environment Norms/Statutory Norms of Government of India will be considered by the Commission on case to case basis subject to prudence check.
- 29.9 The following shall be excluded or removed from the capital cost of the existing and new project:

- a) the assets forming part of the project, but not in use as declared in the tariff petition;
- b) decapitalisation of Asset after the date of commercial operation on account of replacement or removal on account of obsolescence or shifting from one project to another project:

Provided that in case replacement of transmission asset is recommended by Regional Power Committee, such asset shall be de-capitalised only after its redeployment;

Provided further that unless shifting of an asset from one project to another is of permanent nature, there shall be no de-capitalization of the concerned assets.

- c) in case of hydro generating station any expenditure incurred or committed to be incurred by a project developer for getting the project site allotted by the State government ; and
- d) the proportionate cost of land which is being used for generating power from generating station based on renewable energy:

Provided that any grant received from the Central or State Government or any statutory body or authority for the execution of the project which does not carry any liability of repayment shall be excluded from the Capital Cost for the purpose of computation of interest on loan, return on equity and depreciation;

Provided further that all grant which were originally received as grant for execution of projects, and subsequently converted to equity on or after 01.04.2025, shall continue to be treated as grant for the purpose of tariff determination.

Provided further that the capital cost of the assets forming part of the Project but not put to use or not in use, shall be excluded from the capital cost of Generation Project and transmission/ distribution / SLDC system:

Provided also that any capitalisation done by mere book entries / presentation in the financial statements in order to comply with any statute / rules etc. and not in accordance with the Capital Expenditure approved under these Regulations, shall not be allowed by the Commission.

Provided also that the Generating Company or Transmission Licensee or SLDC or Distribution licensee, as the case may be, shall submit documentary evidence in support of its claim of assets being put to use:

Provided also that the Commission may undertake a verification to check if the assets are put to use as submitted by the Generating Company or Transmission Licensee or SLDC or Distribution licensee, as the case may be, independent of the tariff determination process.

30 Additional capitalisation and de-capitalization

30.1 Additional Capitalisation within the original scope and upto the cut-off date

- (i) The additional capital expenditure in respect of a new project or an existing project incurred or projected to be incurred, on the following counts within the original scope of work, after the date of commercial operation and up to the cut-off date may be admitted by the Commission, subject to prudence check:
 - a) Undischarged liabilities recognized to be payable at a future date;
 - b) Works deferred for execution;
 - c) Procurement of initial capital spares within the original scope of work, in accordance with the provisions of Regulation 29.5 of these regulations;
 - d) Liabilities to meet award of arbitration or for compliance of the directions or order of any statutory authority or order or decree of any court of law;
 - e) Change in law or compliance of any existing law; and
 - f) Force Majeure events:

Provided that in case of any replacement of the assets, the additional capitalization shall be worked out after adjusting the gross fixed assets and cumulative depreciation of the assets replaced on account of de-capitalization.

- (ii) The generating company, transmission licensee, SLDC or Distribution Licensee as the case may be shall submit the details of works asset wise/work wise included in the original scope of work along with estimates of expenditure, liabilities recognized to be payable at a future date and the works deferred for execution.

30.2 Additional Capitalisation within the original scope and after the cut-off date:

- (i) The additional capital expenditure incurred or projected to be incurred in respect of an existing project or a new project on the following counts within the original scope of work and after the cut-off date may be admitted by the Commission, subject to prudence check:
 - a) Liabilities to meet award of arbitration or for compliance of the directions or order of any statutory authority, or order or decree of any court of law;
 - b) Change in law or compliance of any existing law;
 - c) Deferred works relating to ash pond or ash handling system in the original scope of work;
 - d) Liability for works executed prior to the cut-off date;
 - e) Force Majeure events;
 - f) Liability for works admitted by the Commission after the cut-off date to the extent of discharge of such liabilities by actual payments; and
 - g) Raising of ash dyke as a part of ash disposal system.

- (ii) In case of replacement of assets deployed under the original scope of the existing project after cut-off date, the additional capitalization may be admitted by the Commission, after making necessary adjustments in the gross fixed assets and the cumulative depreciation, subject to prudence check on the following grounds:
 - a) The useful life of the assets is not commensurate with the useful life of the project and such assets have been fully depreciated in accordance with the provisions of these regulations;
 - b) The replacement of the asset or equipment is necessary on account of change in law or Force Majeure conditions;
 - c) The replacement of such asset or equipment is necessary on account of obsolescence of technology; and
 - d) The replacement of such asset or equipment has otherwise been allowed by the Commission.
 - e) The additional expenditure, excluding recurring expenses covered in O&M expenses, involved in relation to the renewal of lease of lease hold land on case-to-case basis.

Provided that any claim of additional capitalisation with respect to the replacement of assets under the original scope and on account of obsolescence of technology, which is less than Rs. 20 lakhs shall not be considered as part of Capital cost and shall be met through normative O&M expenses.

30.3 Additional Capitalisation beyond the original scope

- (i) The capital expenditure, in respect of existing generating station or the transmission system including communication system, incurred or projected to be incurred on the following counts beyond the original scope, may be admitted by the Commission, subject to prudence check:
- a) Liabilities to meet award of arbitration or for compliance of order or directions of any statutory authority, or order or decree of any court of law;
 - b) Change in law or compliance of any existing law;
 - c) Force Majeure events;
 - d) Need for higher security and safety of the plant as advised or directed by appropriate Indian Government Instrumentality or statutory authorities responsible for national or internal security;
 - e) Deferred works relating to ash pond or ash handling system in additional to the original scope of work, on case-to-case basis:

Provided also that if any expenditure has been claimed under Renovation and Modernisation (R&M) or repairs and maintenance under O&M expenses, the same shall not be claimed under this Regulation;

- f) Usage of water from the sewage treatment plant in the thermal generating station.
- g) Works required towards biomass handling system to enable biomass co-firing and towards enabling flexible operation of the generating station as may be required.
- h) Any additional capital expenditure which has become necessary for efficient operation of generating station or transmission/ distribution system as the case may be, including the works required towards projects acquired through NCLT process. The claim shall be substantiated with the technical justification and cost benefit analysis.

Provided that the utilities shall have to mandatorily seek prior approval of the Commission before implementing such works based on a detailed cost-benefit analysis of such schemes;

- (ii) In case of de-capitalisation of assets of a generating company, transmission licensee, SLDC or Distribution Licensee as the case may be, the original cost of such asset as on the date of de-capitalisation shall be deducted from the value of gross fixed asset and corresponding loan as well as equity shall be deducted from outstanding loan and the equity respectively in the year such de-capitalisation takes place with corresponding adjustments in cumulative depreciation and cumulative repayment of loan, duly taking into consideration the year in which it was capitalised.

Provided that in cases where an asset forming part of a scheme is de-capitalised and wherein the historical value of such asset is not available, the value of de-capitalisation shall be computed by de-escalating the value of the new asset by 5% per year until the year of capitalisation of the old asset subject to a minimum of 10% of the replacement cost of the asset.

30.4 Additional Capitalization on account of Revised Emission Standards:

- (i) A generating company requiring to incur additional capital expenditure in the existing generating station for compliance of the revised emissions standards shall share its proposal with the beneficiaries and file a petition for undertaking such additional capitalization.
- (ii) The proposal under clause (i) above shall contain details of proposed technology as specified by the Central Electricity Authority, scope of the work, phasing of expenditure, schedule of completion, estimated completion cost including foreign exchange component, if any, detailed computation of indicative impact on tariff to the beneficiaries, and any other information considered to be relevant by the generating company.
- (iii) Where the generating company makes an application for approval of additional capital expenditure on account of implementation of revised emission standards, the Commission may grant approval after due consideration of the reasonableness of the cost estimates, financing plan, schedule of completion, interest during construction, use of efficient technology, cost-benefit analysis, and such other factors as may be considered relevant by the Commission.
- (iv) After completion of the implementation of revised emission standards, the generating company shall file a petition for determination of tariff. Any expenditure incurred or projected to be incurred and admitted by the Commission after prudence check based on reasonableness of the cost and impact on operational parameters shall form the basis of determination of tariff.

30.5 Renovation & Modernisation (R&M):

- (i) The generating company or the transmission licensee, as the case may be, for meeting the expenditure on intending to undertake renovation and modernisation (R&M) of the generating station or unit thereof or transmission system or element thereof for the purpose of extension of life beyond the originally recognized useful life for the purpose of tariff, shall file a petition of the generating station or a unit thereof or the transmission system, shall make an application before the Commission for approval of the proposal with a Detailed Project Report giving complete scope, justification, cost-benefit analysis, estimated life extension from a reference date, financial package, phasing of expenditure, schedule of completion, reference price level, estimated completion cost including foreign exchange component, if any, record of consultation with beneficiaries and any other information considered to be relevant by the generating company or the transmission licensee:

Provided that the generating company making the applications for renovation and modernization (R&M) shall not be eligible for Special Allowance under Regulation 29.6 of these regulations;

Provided further that the generating company or the transmission licensee intending to undertake renovation and modernization (R&M) shall be required to obtain the consent of the beneficiaries or the long term customers, as the case may be, for such renovation and modernization (R&M) and submit the same along with the petition;

Provided also that if the beneficiaries or the long term customers, as the case may be, fail to give their consent within specified time, the generating company or the transmission licensee may carry out R&M subject to approval of the Commission.

- (ii) Where the generating company or the transmission licensee, as the case may be, makes an application for approval of its proposal for renovation and modernisation, the approval shall be granted after due consideration of reasonableness of the proposed cost estimates, financing plan, schedule of completion, interest during construction, use of efficient technology, cost-benefit analysis, expected duration of life extension, consent of the beneficiaries or long term customers, and such other factors as may be considered relevant by the Commission.
- (iii) In case of gas/ liquid fuel based open/ combined cycle thermal generating station, after 25 years of operation from its COD, any additional capital expenditure which has become necessary for renovation of gas turbines/steam turbine or additional capital expenditure necessary due to obsolesce or non-availability of spares for efficient operation of the stations shall be allowed:

Provided that any expenditure included in the R&M on consumables and cost of components and spares which is generally covered in the O&M expenses during the major overhaul of gas turbine shall be suitably deducted after due prudence from the R&M expenditure to be allowed.

- (iv) After completion of the renovation and modernisation (R&M), the generating company or the transmission licensee, as the case may be, shall file a petition for determination of tariff expenditure incurred or projected to be incurred and admitted by the Commission after prudence check, and after deducting the accumulated depreciation already recovered from the admitted project cost, shall form the basis for determination of tariff.

Provided that in case of renovation and modernization and up rating of old generating station where capital investment plan has been approved by the Commission, may revise the performance parameters of the said station.

Also provided that proper diagnostic maintenance tools should be in place to detect any malfunctioning of the equipments of a generating plant and take up preventive maintenance work by the generating company as necessary.

30.6 Special Allowance for Coal-based fired Thermal Generating station

- (i) In case of coal fired thermal generating station, the generating company, instead of availing R&M may opt to avail a "special allowance" in accordance with the norms specified in this regulation, as compensation for meeting the requirement of expenses including renovation and modernisation beyond the useful life of the generating station or a unit thereof, and in such an event, revision of the capital cost shall not be allowed and the applicable operational norms shall not be relaxed but the special allowance shall be included in the annual fixed cost:

Provided that such option shall not be available for a generating station or unit for which renovation and modernization has been undertaken and the expenditure has been admitted by the Commission before commencement of these regulations, or for a generating station or unit which is in a depleted condition or operating under relaxed operational and performance norms.

- (ii) The Special Allowance admissible to a generating station shall be @ Rs 10.75 lakh per MW per year for the control period.
- (iii) In the event of a generating station availing Special Allowance, the expenditure incurred upon or utilized from Special Allowance shall be maintained separately by the generating station and details of same shall be made available to the Commission as and when directed.
- (iv) The Special Allowance allowed under this Regulation shall be transferred to a separate fund for utilization towards Renovation & Modernisation activities, for which detailed methodology shall be issued separately.

30.7 Interest during construction (IDC), Incidental Expenditure during Construction (IEDC)**A. Interest during Construction (IDC):**

- (i) Interest during construction shall be computed corresponding to the loan from the date of infusion of debt fund, and after taking into account the prudent phasing of funds upto SCOD (Scheduled Commercial Operation Date).
- (ii) In case of additional costs on account of IDC due to delay in achieving the SCOD, the generating company or the transmission licensee as the case may be, shall be required to furnish detailed justifications with supporting documents for such delay including prudent phasing of funds:

Provided that if the delay is not attributable to the generating company or the transmission licensee as the case may be, and is due to uncontrollable factors, IDC may be allowed after due prudence check:

Provided further that only IDC on actual loan may be allowed beyond the SCOD to the extent, the delay is found beyond the control of generating company or the transmission licensee, as the case may be, after due prudence and taking into account prudent phasing of funds.

B. Incidental Expenditure during Construction (IEDC):

- (i) Incidental expenditure during construction shall be computed from the zero date and after taking into account pre-operative expenses upto SCOD:

Provided that any revenue earned during construction period up to SCOD on account of interest on deposits or advances, or any other receipts may be taken into account for reduction in incidental expenditure during construction.

- (ii) In case of additional costs on account of IEDC due to delay in achieving the SCOD, the generating company or the transmission licensee as the case may be, shall be required to furnish detailed justification with supporting documents for such delay including the details of incidental expenditure during the period of delay and liquidated damages recovered or recoverable corresponding to the delay:

Provided that if the delay is not attributable to the generating company or the transmission licensee, as the case may be, and is due to uncontrollable factors, IEDC may be allowed after due prudence check:

Provided further that where the delay is attributable to an agency or contractor or supplier engaged by the generating company or the transmission licensee, the liquidated damages recovered from such agency or contractor or supplier shall be taken into account for computation of capital cost.

- (iii) In case the time over-run beyond SCOD is not admissible after due prudence, the increase of capital cost on account of cost variation corresponding to the period of time over run may be excluded from capitalization irrespective of price variation provisions in the contracts with supplier or contractor of the generating company or the transmission licensee.

31 Treatment of Consumer contribution, Deposit work and Grant

- 31.1 The following nature of work carried out by the Transmission Licensee or Distribution Licensee shall be classified under this category:

- a) Works after obtaining a part or all of the funds from the users in the context of deposit works.
- b) Capital works undertaken by utilising grants received under various schemes / programs of the State and Central Governments.
- c) Any other grant of similar nature and such amount received without any obligation to return the same and with no interest costs attached to such subvention.

- 31.2 Principles for treatment of the expenses on such capital expenditure shall be as follows:

- a) Normative O&M expense as specified in these Regulations shall be allowed.
- b) Provisions related to Depreciation, as specified in Regulation 33.
- c) Provisions related to Return on Equity Capital, as specified in Regulation 34.

32 Debt-equity ratio

- 32.1 For a project declared under commercial operation on or after April 1st, 2025, if the equity actually deployed is more than 30% of the capital cost, equity in excess of 30% shall be treated as normative loan for the Generating Company, Transmission Licensee and Distribution Licensee.

Provided that where equity actually deployed is less than 30% of the capital cost of the capitalised asset, the actual equity shall be considered for determination of tariff.

Provided further that the equity invested in foreign currency shall be designated in Indian rupees on the date of each investment.

Provided also that any grant obtained for the execution of the project shall not be considered as part of capital structure for the purpose of debt: equity ratio.

Provided further that any addition to Gross Fixed Assets originally funded by grant and subsequently converted to equity on or after 01.04.2025, shall continue to be treated as grant for the purpose of tariff determination under these Regulations.

Explanation.- The premium, if any, raised by the Generating Company or the Transmission Licensee or the Distribution Licensee, as the case may be, while issuing share capital and investment of internal resources created out of its free reserve, for the funding of the project, shall be reckoned as paid up capital for the purpose of computing return on equity, provided such premium amount and internal resources are actually utilised for meeting the capital expenditure of the Generating Station or the transmission system or the distribution system.

- 32.2 In case of the Generating Company, Transmission Licensee, Distribution Licensee and SLDC, if any fixed asset is capitalised on account of capital expenditure prior to April 1st, 2025, debt-equity ratio allowed by the Commission for determination of tariff for the period ending March 31st, 2025, shall be considered:

Provided that in case of retirement or replacement of the assets, the equity capital approved as mentioned above, shall be reduced to the extent of 30% (or actual equity component based on documentary evidence, if it is lower than 30%) of the original cost of the retired or replaced asset.

- 32.3 Any expenditure incurred or projected to be incurred on or after April 1st, 2025, as may be admitted by the Commission as additional capital expenditure for determination of tariff, and renovation and modernisation expenditure for life extension, shall be serviced in the manner specified in this Regulation.

33 Depreciation

- 33.1 The value base for the purpose of depreciation shall be the Capital Cost of the asset admitted by the Commission.

Provided that depreciation shall not be allowed on assets funded through Consumer contribution, Capital Subsidies/Grants, and conversion of grant to equity on or after 01.04.2025.

- 33.2 The salvage value of the asset shall be considered as 10% and depreciation shall be allowed up to maximum of 90% of the capital cost of the asset.

Provided that in case of hydro generating stations, the salvage value shall be as provided in the agreement signed by the developers with the State Government for creation of the site:

Provided further that the capital cost of the assets of the hydro generating station for the purpose of computation of depreciable value shall correspond to the percentage of sale of electricity under long-term power purchase agreement at regulated tariff.

Provided also that any depreciation disallowed on account of lower availability of the generating station or generating unit or transmission system as the case may be, shall not be allowed to be recovered at a later stage during the useful life and the extended life.

- 33.3 Land, other than the land held under lease and the land for reservoir in case of hydro Generating Station, shall not be a depreciable assets and its cost shall be excluded from the capital cost while computing depreciable value of the assets.

- 33.4 Depreciation of the existing projects shall be calculated annually based on Straight Line Method and at rates specified in Appendix-I to these Regulations:

Provided that, the remaining depreciable value as on 31st, March of the year closing after a period of 12 years from date of commercial operation shall be spread over the balance useful life of the assets.

- 33.5 In case of the existing projects, the balance depreciable value as on April 1st, 2025, shall be worked out by deducting the cumulative depreciation including Advance Against Depreciation as admitted by the Commission upto March 31st, 2025, from the gross depreciable value of the assets.

- 33.6 Depreciation for New Projects shall be calculated annually based on the Straight Line Method and at rates specified in Appendix-II to these regulations for the assets of the generating station, transmission and distribution system:

Provided that the remaining depreciable value as on 31st March of the year closing after a period of 15 years from the effective date of commercial operation of the generating station or the transmission or distribution system, as the case may be, shall be spread over the balance useful life of the assets.

- 33.7 Depreciation shall be chargeable from the first year of commercial operation. In case of commercial operation of the asset for part of the year, depreciation shall be charged on pro rata basis.

- 33.8 In case of de-capitalization of assets, the cumulative depreciation shall be adjusted by taking into account the depreciation recovered in tariff by the decapitalized asset during its useful services.

34 Return on Equity Capital

- 34.1 Return on equity capital shall be computed on the equity capital determined in accordance with Regulation 32.

- 34.2 Return on equity shall consist of two parts i.e base ROE and additional ROE as below –

I. For Generating Station

- a) For the Generating stations commissioned on or after 1st April, 2025 base ROE rate of 13.50% shall be allowed on a post- tax basis.
- b) Additional ROE of 1% shall be allowed for the project completed within the schedule date of commissioning.
- c) Additional ROE of 2% shall be allowed for the project completed before six months of the schedule date of commissioning.
- d) The maximum ROE admissible for Generating Station shall be 15.5%.

Provided that the rate of ROE shall be 15.5% on a post- tax basis for the Generating stations commissioned before 1st April, 2022.

II. For Transmission Licensee

- a) Base ROE rate of 13.50% shall be allowed on a post- tax basis.
- b) Additional ROE of 1% shall be allowed on achieving 80% on the approved capitalization for previous year.
- c) Additional ROE of 2% shall be allowed on achieving 100% on the approved capitalization for previous year.
- d) The maximum ROE admissible for Transmission Licensee shall be 15.5%.

III. For SLDC

The rate of ROE for SLDC shall be 15.5% on a post- tax basis.

IV. For Distribution Licensee

- a) Base ROE rate of 14% shall be allowed on a post- tax basis.
- b) Additional ROE of 1% shall be allowed on achieving 80% on the approved capitalization for previous year.

- c) Additional ROE of 2% shall be allowed on achieving 100% on the approved capitalization for previous year.
- d) The maximum ROE admissible for Distribution Licensee shall be 16%.

Provided that:

- i. In case of a new project commissioned on or after 1st April, 2025, the rate of return on equity shall be reduced by 1.00% for such period as may be decided by the Commission if the generating station or transmission system is found to be declared under commercial operation without commissioning of any of the Free Governor Mode Operation (FGMO), data telemetry, communication system up to load dispatch centre or protection system based on the report submitted by the SLDC;

35 Interest on loan capital

- 35.1 The loans arrived at in the manner indicated in Regulation 32 shall be considered as gross normative loan for calculation of interest on loan.

Provided that in case of retirement or replacement of assets, the loan capital approved as mentioned above, shall be reduced to the extent of 70% (or actual loan component based on documentary evidence, if it is higher than 70%) of the original cost of the retired or replaced assets.

- 35.2 The normative loan outstanding as on April 1st, 2025, shall be worked out by deducting the cumulative repayment as admitted by the Commission up to March 31st, 2025, from the gross normative loan.
- 35.3 The repayment for each year of the Control period shall be deemed to be equal to the depreciation allowed for that year:
- 35.4 Notwithstanding any moratorium period availed by the Generating Company or the Transmission Licensee or the Distribution Licensee or the SLDC, as the case may be, the repayment of loan shall be considered from the first year of commercial operation of the project and shall be equal to the annual depreciation allowed.
- 35.5 The rate of interest shall be the weighted average rate of interest calculated on the basis of the actual loan portfolio at the beginning of each year applicable to the Generating Company or the Transmission Licensee or the Distribution Licensee or SLDC:

Provided that if there is no actual loan for a particular year but normative loan is still outstanding, the last available weighted average rate of interest shall be considered:

Provided further that if the Generating Company or the Transmission Licensee or the Distribution Licensee or SLDC, as the case may be, does not have actual loan, then the

weighted average rate of interest of the Generating Company or the Transmission Licensee or the Distribution Licensee or SLDC as a whole shall be considered.

- 35.6 The interest on loan shall be calculated on the normative average loan of the year by applying the weighted average rate of interest.
- 35.7 The utility shall make every effort to re-finance the loan as long as it results in net savings on interest and in that event the costs associated with such re-financing shall be borne by the beneficiaries and the net savings shall be shared between the beneficiaries and the generating company or the transmission licensee, as the case may be, in the ratio of 2:1.
- 35.8 The changes to the terms and conditions of the loans shall be reflected from the date of such re-financing.
- 35.9 Interest shall be allowed on the amount held as security deposit by the Distribution Licensee from consumers, at a rate equal to SBI base rate as on 1st April of the financial year.

Provided that at the time of truing-up, the interest on the amount of security deposit for the year shall be considered on the basis of the actual interest paid by the licensee during the year, subject to prudent check by the Commission.

36 Tax on Income

- 36.1 Income Tax, if any, on the income stream of the regulated business of Generating Companies, Transmission Licensees, Distribution Licensees and SLDC shall be reimbursed to the Generating Companies, Transmission Licensees, Distribution Licensees and SLDC as per actual income tax paid, based on the documentary evidence submitted at the time of truing up of each year of the Control Period, subject to the prudence check.

Provided that no Income Tax shall be considered on the amount of efficiency gains and incentive earned by the Generating Companies, Transmission Licensees, Distribution Licensees and SLDC.

37 Interest on Working Capital

37.1 Generation projects

- a) **In case of coal based/oil-based fired Generating Stations, working capital shall cover:**
- (i) Cost of coal or lignite, if applicable, for 10 days for pit-head generating stations and 20 days for non-pit-head generating stations for generation corresponding to the normative annual plant availability factor or the maximum coal/lignite stock storage capacity, whichever is lower;
 - (ii) Limestone towards stock for 15 days corresponding to the normative annual plant availability.

- (iii) Advance payment for 30 days towards the cost of coal or lignite and limestone for generation corresponding to the normative annual plant availability factor;
 - (iv) Cost of secondary fuel oil for two months for generation corresponding to the normative annual plant availability factor, and in case of use of more than one secondary fuel oil, cost of fuel oil stock for the main secondary fuel oil;
 - (v) Operation and Maintenance expenses, including water charges and security expenses, for one (1) month ;
 - (vi) Maintenance spares @ 20% of operation and maintenance expenses, including water charges and security expenses; and
 - (vii) Receivables equivalent to 45 days of capacity charges and energy charges for sale of electricity calculated on the normative annual plant availability factor;
- b) In case of Gas Turbine/Combined Cycle/ Gas-engine based Generating Stations, working capital shall cover:**
- (i) Fuel cost for 15 days corresponding to the normative annual plant availability factor, duly taking into account the mode of operation of the generating station on gas fuel and liquid fuel;
 - (ii) Liquid fuel stock for 15 days corresponding to the normative annual plant availability factor, and in case of use of more than one liquid fuel, cost of main liquid fuel duly taking into account mode of operation of the generating stations of gas fuel and liquid fuel;
- Provided that the above shall only be allowed to generating stations that have facilities to store liquid fuel.
- (iii) Maintenance spares @ 30% of operation and maintenance expenses, including water charges and security expenses;
 - (iv) Receivables equivalent to 45 days of capacity charge and energy charge for the sale of electricity calculated on the normative plant availability factor, duly taking into account the mode of operation of the generating station on gas fuel and liquid fuel;
 - (v) Operation and maintenance expenses, including water charges and security expenses, for one month.
- c) In case of Hydro power Generating Stations including pumped storage hydro-electric generating station and transmission system, working capital shall cover:**
- (i) Operation and maintenance expenses including security expenses for one (1) month;
 - (ii) Maintenance spares @15% of operation and maintenance expenses including security expenses; and
 - (iii) Receivables equivalent to 45 days of the annual fixed charges.

- d) Rate of interest shall be at interest rate equivalent to the normative interest rate of three hundred (300) basis points above the average State Bank of India MCLR (One Year Tenor) prevalent during the last available six months for the determination of tariff.

37.2 Transmission & SLDC

- a) The Transmission Licensee and SLDC shall be allowed interest on the estimated level of working capital for the financial year, computed as follows:
- (i) Operation and maintenance expenses for one (1) month;
 - (ii) Maintenance spares @15% of operation and maintenance expenses; and
 - (iii) Receivables equivalent to 45 days of the annual transmission charges and SLDC charges (for SLDC).
- b) Rate of interest shall be at interest rate equivalent to the normative interest rate of three hundred (300) basis points above the average State Bank of India MCLR (One Year Tenor) prevalent during the last available six months for the determination of tariff.

37.3 Distribution Wheeling Business

- a) The Distribution Licensee shall be allowed interest on the estimated level of working capital for the Distribution Wheeling Business for the financial year, computed as follows:
- (i) One month of the amount of Operation and Maintenance expenses for such financial year; plus
 - (ii) Maintenance Spares @15% of operation and maintenance expenses; plus
 - (iii) Receivables equivalent to 45 days of the expected revenue from charges for use of Distribution Wires;
Minus
 - (iv) Amount if any, held as security deposits under clause (b) of sub-section (1) of Section 47 of the Act from Distribution System Users except the security deposits held in the form of non cash instruments such as Bank Guarantee, Bank Mandate etc.
- b) Rate of interest shall be at interest rate equivalent to the normative interest rate of three hundred (300) basis points above the average State Bank of India MCLR (One Year Tenor) prevalent during the last available six months for the determination of tariff.

37.4 Retail Supply of Electricity

- a) The Distribution Licensee shall be allowed interest on the estimated level of working capital for the financial year, computed as follows:
- a) One month of the amount of Operation and Maintenance expenses for such financial year (O & M₁); plus
 - b) Maintenance Spares @15% of operation and maintenance expenses (MS); plus

- c) 45 days equivalent of the expected revenue from sale of electricity at the prevailing tariff (R_2) and including revenue from cross-subsidy surcharge and additional surcharge, if any;

Minus

- d) Amount held as security deposits under clause (a) and clause (b) of sub-section (1) of Section 47 of the Act from retail supply consumers (SD) except the security deposits held in the form of on cash instruments such as Bank Guarantee, Bank Mandate etc.;

Minus

- e) One (1) month equivalent of cost of power purchased, based on the annual power procurement plan (PP_1).

Thereby, total working capital considered shall be:

$$WC = (O + M_1 + MS + R_2) - SD - PP_1$$

Provided that in case of power procurement from own Generating Stations of the Retail Supply Business, no amount shall be reduced from the working capital requirement towards payables, to the extent of supply of power by the Generation Business to the Retail Supply Business, in the computation of working capital in accordance with these Regulations;

- b) Rate of interest shall be at interest rate equivalent to the normative interest rate of three hundred (300) basis points above the average State Bank of India MCLR (One Year Tenor) prevalent during the last available six months for the determination of tariff.

38 Operation and Maintenance Expense

- 38.1 The O&M for generating company and transmission licensee shall be determined as per Regulation 51 and Regulation 68.5 of these Regulations.

Provided that income generated from the sale of gypsum or other by-products shall be reduced from the operation and maintenance expenses.

- 38.2 The O&M Expense for the Distribution licensee shall be determined as follows:

- a) The licensee shall propose separate trajectories of norms for each of the components of O&M expenses viz., employee cost, R&M expense and A&G expense;
- b) Norms shall be defined in terms of combination of number of personnel for various activities such as per 1000 consumers and number of personnel per substation, line length along with annual expenses per personnel for Employee expenses combination of A&G expense per personnel and A&G expense per 1000 consumers for A&G expenses and R&M expense as percentage of gross fixed assets for estimation of R&M expenses;

- c) One-time expenses such as expense due to change in accounting policy, arrears paid due to pay commissions and interim relief etc., shall be excluded from the norms in the trajectory;
- d) The expenses beyond the control of the distribution licensee such as dearness allowance, pension liabilities and terminal benefits in Employee cost etc., shall be excluded from the norms in the trajectory;
- e) The One-time expenses and the expenses beyond the control of the Distribution Licensee as per sub-regulations (c) and (d) above shall be allowed by the Commission over and above normative Operation & Maintenance Expenses after prudence check;
- f) The norms in the trajectory shall be proposed over the control period with due consideration to productivity improvements and commercial viability;
- g) The norms shall be proposed at constant prices of base year and escalation on account of inflation shall be over and above the baseline;
- h) The Distribution Licensee shall also carry out absolute and relative analysis while proposing the norms;
- i) In absolute analysis, Distribution Licensee's audited accounts of operations for last three years, expenses claimed for control period, historically approved cost, and prudence check shall be used by the Commission to estimate values of norms;
- j) In relative analysis, performance parameters of other Distribution Licensees within the same state or in other states shall be considered by the commission to estimate norms. Provided that other Distribution Licensees so chosen shall have similar profile as that of the Distribution Licensee under consideration in terms of consumer mix, type of license area (city, state, etc.) type of distribution networks, viz, underground/overhead, HT-LT ratio, etc;
- k) Suitable average of outcomes of absolute and relative analysis may be taken by the licensee while proposing the norms over the control period for the distribution licensee;
- l) Based on the proposal submitted by the licensee, the Commission shall fix the norms for the said purposes which shall be taken into account for determining the trajectories for various components of O&M expenses for the remaining years of the control period;
- m) Till such time the norms are fixed by the Commission, the trajectories of various components of O&M expenses shall be submitted by the licensee and determined by the Commission on the basis of the actual costs for the previous years in accordance with the provisions of these regulations;

38.3 In absence of any proposal along with supporting documents, the Commission shall determine the O&M for the Wheeling and Retail Supply business as per the methodology provided below:

- a) Operation and Maintenance (O&M) expenses shall comprise of the following

- (i) Salaries, wages, pension contribution and other employee costs;
 - (ii) Administrative and general expenses including insurance charges if any;
 - (iii) Repairs and maintenance expenses;
- b) The O&M expenses for the first year of the Control Period shall be approved by the Commission taking into account the actual O&M expenses for last five years till Base Year subject to prudence check and any other factors considered appropriate by the Commission.
- c) The O&M expenses for the nth year and also for the year immediately preceding the Control Period, shall be approved based on the formula given below:-

$$O\&M_n = R\&M_n + EMP_n + A\&G_n$$

Where –

- $O\&M_n$ – Operation and Maintenance expense for the nth year;
 - EMP_n – Employee Costs for the nth year;
 - $R\&M_n$ – Repair and Maintenance Costs for the nth year;
 - $A\&G_n$ – Administrative and General Costs for the nth year;
- d) The above components shall be computed in the manner specified below:

$$EMP_n = (EMP_{n-1}) \times (1+G_n) \times (1+CPIinflation)$$

$$R\&M_n = K \times (GFA_{n-1}) \times (1+WPIinflation) \text{ and}$$

$$A\&G_n = (A\&G_{n-1}) \times (1+WPIinflation) + Provision$$

Where -

- EMP_{n-1} – Employee Costs for the (n-1)th year;
- $A\&G_{n-1}$ – Administrative and General Costs for the (n-1)th year;
- Provision: Cost for initiatives or other one-time expenses as proposed by the Distribution Licensee and validated by the Commission.
- 'K' is a constant specified by the Commission in %. Value of K for each year of the control period shall be determined by the Commission in the MYT Tariff order based on licensee's filing, benchmarking of repair and maintenance expenses, approved repair and maintenance expenses vis-à-vis GFA approved by the Commission in past and any other factor considered appropriate by the Commission;
- CP inflation – is the average increase in the Consumer Price Index (CPI) for immediately preceding three years;
- WP inflation – is the average increase in the Wholesale Price Index (CPI) for immediately preceding three years;

- GFA_{n-1} — Gross Fixed Asset of the transmission licensee for the n-1th year;
- G_n is a growth factor for the nth year. Value of G_n shall be determined by the Commission in the MYT tariff order for meeting the additional manpower requirement based on licensee's filings, benchmarking, and any other factor that the Commission feels appropriate.

39 Prior Period Expenses

- 39.1 The utility may submit to the Commission the prior period expenses as a part of the filing for truing up;
- 39.2 The Commission may allow prior period expenses at the time of truing up based on audited accounts, on case-to-case basis, if the expenses in that prior period have been allowed by the Commission on actual basis, subject to prudence check.

CHAPTER 6: COMPONENTS OF ARR AND TARIFF FOR GENERATION COMPANY

40 Applicability

40.1 The Regulations specified in this Chapter shall apply for determining the tariff for supply of electricity to a Distribution Licensee from the generating stations located in Assam:

Provided that determination of tariff for supply of electricity to a Distribution Licensee from Renewable Energy sources of generation shall be in accordance with terms and conditions as stipulated in the relevant Regulations/Orders of the Commission.

40.2 The Commission shall be guided by the terms and conditions contained in this Chapter in determining the tariff for supply of electricity by a Generating Company to a Distribution Licensee in the following cases:

- a) where such tariff is pursuant to a power purchase agreement or arrangement entered into subsequent to the date of effectiveness of these Regulations; or where such tariff is pursuant to a power purchase agreement or arrangement entered into prior to the date of effectiveness of these Regulations and either the Commission has not previously approved such agreement/arrangement or the agreement/arrangement envisages that the tariff shall be based on the Assam Electricity Regulatory Commission (Terms and Conditions for determination of Multi Year Tariff) Regulations, 2024, as amended from time to time; or
- b) where the Distribution Licensee is engaged in the business of generation of electricity, in determining the transfer price at which electricity is supplied by the Generation Business of the Distribution Licensee to its Retail Supply Business;

Provided that the Commission may deviate from the norms contained in this Chapter or specify alternative norms for particular cases, where it so deems appropriate, having regard to the circumstances of the case:

Provided further that the reasons for such deviation(s) shall be recorded in writing.

40.3 Notwithstanding anything contained in this Chapter 6, the Commission shall adopt the tariff if such tariff has been determined through transparent process of bidding in accordance with the guidelines issued by the Central Government.

41 Petition for determination of generation tariff

- 41.1 A Generating Company is required to file a Petition for determination of tariff for supply of electricity to Distribution Licensees in accordance with the provisions of Chapter 3 of these Regulations.
- 41.2 Tariff in respect of a Generating Station under these Regulations may be determined Stage-wise, Unit-wise or for the whole Generating Station. The terms and conditions for determination of tariff for Generating Stations specified in this Chapter shall apply in like manner to Stages or Units or for the Generating Station, as the case may be.
- 41.3 Where the tariff is being determined for Stage or Unit of a Generating Station, the Generating Company shall adopt a reasonable basis for allocation of capital cost relating to common facilities and allocation of joint and common costs across all Stages or Units, as the case may be;

Provided that the Generating Company shall maintain an Allocation Statement providing the basis for allocation of such costs, which shall be duly audited and certified by the statutory auditors, and submit such audited and certified statement to the Commission along with the application for determination of tariff.

- 41.4 A Generating Company may make a Petition for determination of provisional tariff in advance of the anticipated Date of Commercial Operation of Unit or Stage or Generating Station as a whole, as the case may be, based on the capital expenditure actually incurred up to the date of making the Petition or a date prior to making of the Petition, duly audited and certified by the statutory auditors/independent auditor and the provisional tariff shall be charged from the date of commercial operation of such Unit or Stage or Generating Station, as the case may be.
- 41.5 A Generating Company shall make a fresh Petition in accordance with these Regulations, for determination of final tariff based on actual capital expenditure incurred up to the date of commercial operation of the Generating Station duly certified by the statutory auditors based on Annual Audited Accounts.
- 41.6 Any difference in provisional tariff and the final tariff determined by the Commission and not attributable to the Generating Company may be adjusted at the time of determination of final tariff for the following year as directed by the Commission.

42 Components of Tariff

- 42.1 The tariff for sale of electricity from a thermal Power Generating Station shall comprise of two parts, namely, the recovery of Annual Fixed Charges and Energy (variable) Charges (for recovery of primary and secondary fuel cost).
- 42.2 The tariff for sale of electricity from a Hydro Generating Station shall comprise of two parts, namely, the recovery of Capacity Charge and Energy Charge.

43 Annual Fixed Charges

43.1 The Annual Fixed Charges shall comprise of the following elements:

- a) Return on Equity Capital;
- b) Interest on Loan Capital;
- c) Depreciation;
- d) Operation & Maintenance Expenses;
- e) Interest on Working Capital;

Minus:

- (a) Non-Tariff Income.

Provided that Depreciation, Interest on Loan Capital and Return on Equity Capital for Thermal and Hydro Generating Stations shall be considered in accordance with the provisions specified in Chapter 5 of these Regulations.

Provided further that special allowance in lieu of R&M where opted in accordance to Regulation 30.5 and/or separate compensation allowance in accordance to Regulation 30.6, wherever applicable shall be recovered separately and shall not be considered for computation of working capital.

44 Capital cost

44.1 For the purpose of determination of tariff, the Capital Cost for a generating station and additional capitalisation thereof, shall be allowed in accordance with the provisions outlined under Regulation 29 and Regulation 30 respectively.

44.2 The provisions of Accounting Standards (AS10): Accounting for Fixed Assets of the Institute of Chartered Accountants of India, as amended from time to time, shall apply, to the extent not inconsistent with these Regulations, in determining the original cost of capital expenditure projects and/or original cost of fixed assets capitalized.

45 Sale of Infirm Power

45.1 The tariff for sale of infirm power from the thermal Generating Station to the Distribution Licensee shall be equivalent to the actual fuel cost, including the secondary fuel cost, as the case may be, incurred during that period subject to prudence check.

Provided that any revenue other than the recovery of fuel cost earned by the generating company from sale of infirm power shall be taken as reduction in capital cost and shall not be treated as revenue.

45.2 The tariff for sale of infirm power for Hydro Stations to the Distribution Licensee shall be the lowest energy rate of the existing hydro-station in the state and the revenue recovered from sale of infirm power shall be deducted from the capital cost.

46 Non-Tariff Income

The amount of non-tariff income relating to the Generation Business as approved by the Commission shall be deducted from the Annual Fixed Cost in determining the Annual Fixed Cost of the Generation Company;

Provided that the Generation Company shall submit full details of its forecast of non-tariff income to the Commission in such form as may be stipulated by the Commission from time to time.

The indicative list of various heads to be considered for non-tariff income shall be as under:

- a) Income from rent of land or buildings;
- b) Income from sale of scrap;
- c) Income from statutory investments;
- d) Income from sale of Ash/rejected coal;
- e) Interest on delayed or deferred payment on bills;
- f) Interest on advances to suppliers/contractors;
- g) Rental from staff quarters;
- h) Rental from contractors;
- i) Income from hire charges from contractors and others;
- j) Income from advertisements, etc.;
- k) Interest on investments, fixed and call deposits and bank balances;*
- l) Interest on staff loans and advances;
- m) Income from Security Constrained Economic Despatch (SCED) & Market Based Economic Despatch (MBED);
- n) Any other non-tariff income.

*(*Note – Any income from fixed deposit made out of profit of the Generating Stations shall not be deducted as Non-Tariff Income, provided the details of the same, certified by the auditor is made available)*

47 Norms of operation for Thermal Generating Stations

47.1 Recovery of capacity charge, energy charge and incentive by the generating company shall be based on the achievement of the operational norms specified in the regulations 48.1 to 50.

47.2 The Commission may on its own revise the norms of Station Heat Rate In respect of any of the generating stations for which relaxed norms have been specified.

48 Norms of operation for Thermal Power Station

48.1 Normative Annual Plant Availability Factor (NAPAF) for recovery of full (fixed) charges:

- a) Existing Plants:

Name of Plant	MYT Period				
	FY 2025-26	FY 2026-27	FY 2027-28	FY 2028-29	FY 2029-30
i) Namrup TPS	50%	50%	50%	50%	50%
ii) Lakwa TPS with WHRU	50%	50%	50%	50%	50%
iii) Lakwa Replacement PP	85%	85%	85%	85%	85%
iv) Namrup Replacement PP	85%	85%	85%	85%	85%

b) New plants commissioned on or after 1st April, 2025 for recovery of full (fixed) charge:

Description	
Normative Annual Plant Availability Factor (NAPAF)	85%

48.2 Normative (Target) Plant Load Factor for incentive

a) Existing Plants:

Name of Plant	MYT Period				
	FY 2025-26	FY 2026-27	FY 2027-28	FY 2028-29	FY 2029-30
i) Namrup TPS	50%	50%	50%	50%	50%
ii) Lakwa TPS with WHRU	66%	66%	66%	66%	66%
iii) Lakwa Replacement PP	90%	90%	90%	90%	90%
iv) Namrup Replacement PP	85%	85%	85%	85%	85%

b) New plants commissioned on or after 1st April, 2025 for recovery of full (fixed) charge:

Description	(in %)
Coal based generating station	85%
Gas based generating station	85%
Gas-engine based generating station	90%

48.3 Auxiliary Energy Consumption

a) Existing Plants:

Name of Plant	MYT Period				
	FY 2025-26	FY 2026-27	FY 2027-28	FY 2028-29	FY 2029-30
(i) Namrup TPS	4.50%	4.50%	4.50%	4.50%	4.50%

Name of Plant	MYT Period				
	FY 2025-26	FY 2026-27	FY 2027-28	FY 2028-29	FY 2029-30
(ii) Lakwa TPS with WHRU	5.50%	5.50%	5.50%	5.50%	5.50%
(iii) Lakwa Replacement PP	3.5%	3.5%	3.5%	3.5%	3.5%
(iv) Namrup Replacement PP	5.00%	5.00%	5.00%	5.00%	5.00%

b) New plants commissioned on or after 1st April, 2025:

Description	MYT Period				
	FY 2025-26 (%)	FY 2026-27 (%)	FY 2027-28 (%)	FY 2028-29 (%)	FY 2029-30 (%)
(i) Coal-based Generating Stations					
(a) Below 200 MW cap.					
With cooling tower	9	9	9	9	9
Without cooling tower	8.5	8.5	8.5	8.5	8.5
(with natural draft cooling tower or without cooling tower)					
(b) 200 MW series	8.5	8.5	8.5	8.5	8.5
(c) 500 MW series					
i) With steam driven boiler feed	6	6	6	6	6
ii) With electrically driven boiler feed pump	8.5	8.5	8.5	8.5	8.5
(ii) Gas based Generating Stations					
Open Cycle	1	1	1	1	1
Combined Cycle	2.5	2.5	2.5	2.5	2.5
where electricity driven Gas Booster Compressor is used					
Open Cycle	4	4	4	4	4
Combined Cycle	5	5	5	5	5
(iii) Gas engine					
Open Cycle	2	2	2	2	2
with Gas Booster Compressor					
Open Cycle	3.5	3.5	3.5	3.5	3.5

48.4 Gross Station Heat Rate (GSHR):

a) Existing Plants:

Name of Plant	MYT Period				
	FY 2025-26 (kcal/kWh)	FY 2026-27 (kcal/kWh)	FY 2027-28 (kcal/kWh)	FY 2028-29 (kcal/kWh)	FY 2029-30 (kcal/kWh)
NTPS					
(i) O.C.	4300	4300	4300	4300	4300
(ii) Partially C.C.	3900	3900	3900	3900	3900
LTPS					
(i) O.C.	3900	3900	3900	3900	3900
(ii) Partially C.C.	3200	3200	3200	3200	3200
(iii) Lakwa Replacement PP					
O.C.	2150	2150	2150	2150	2150
(iv) Namrup Replacement PP					
O.C.	2927	2927	2927	2927	2927
Partially C.C.	1951	1951	1951	1951	1951

b) New plants commissioned on or after 1st April, 2025:

(i) Coal based thermal power Generating Stations = $1.045 \times \text{Design Heat Rate (kcal/kWh)}$

Where, the Design Heat Rate of a unit means the unit heat rate guaranteed by the supplier at conditions of 100% MCR, zero percent make up, design coal and design cooling water temperature/back pressure.

Provided that the design heat rate shall not exceed the following maximum design unit heat rates depending upon the pressure and temperature ratings of the units:

Pressure Rating (Kg/cm²)	150	170	170	247
SHT/RHT (OC)	535/535	537/537	537/565	565/593
Type of BFP	Electrical Driven	Turbine Driven	Turbine Driven	Turbine Driven
Max Turbine Cycle Heat rate (kCal/kWh)	1955	1950	1935	1850

Min. Boiler Efficiency				
Sub-Bituminous Indian Coal	0.86	0.86	0.86	0.86
Bituminous Imported Coal	0.89	0.89	0.89	0.89
Max Design Unit Heat rate (kCal/kWh)				
Sub-Bituminous Indian Coal	2273	2267	2250	2151
Bituminous Imported Coal	2197	2191	2174	2078

Provided further that in case pressure and temperature parameters of a unit are different from above ratings, the maximum design unit heat rate of the nearest class shall be taken:

Provided also that where unit heat rate has not been guaranteed but turbine cycle heat rate and boiler efficiency are guaranteed separately by the same supplier or different suppliers, the unit design heat rate shall be arrived at by using guaranteed turbine cycle heat rate and boiler efficiency:

Provided also that where the boiler efficiency is below 86% for Sub-bituminous Indian coal and 89% for bituminous imported coal, the same shall be considered as 86% and 89% respectively for Sub-bituminous Indian coal and bituminous imported coal for computation of station heat rate:

Provided also that maximum turbine cycle heat rate shall be adjusted for type of cooling system:

Provided also that if one or more units were declared under commercial operation prior to 01.04.2025, the heat rate norms for those units as well as units declared under commercial operation on or after 01.04.2025 shall be lower of the heat rate norms arrived at by above methodology and the norms as per Regulation 48.4 (b) of these Regulations;

Note: In respect of units where the boiler feed pumps are electrically operated, the maximum design unit heat rate shall be 40 kCal/kWh lower than the maximum design unit heat rate specified above with turbine driven BFP.

(ii) Gas-based / Liquid-based thermal generating unit(s)/ block(s)

= 1.05 X Design Heat Rate of the unit/block for Natural Gas and RLNG (kCal/kWh)

= 1.071 X Design Heat Rate of the unit/block for Liquid Fuel (kCal/kWh)

Where, the Design Heat Rate of a unit shall mean the guaranteed heat rate for a unit at 100% MCR and at site ambient conditions; and the Design Heat Rate of a block shall mean the guaranteed heat rate for a block at 100% MCR, site ambient conditions, zero percent make up, design cooling water temperature/back pressure.

(iii) Gas-Engine based generating station

Capacities	Heat Rate*
1 to 3MW	As per CEA Regulation
3 to 5MW	As per CEA Regulation
>5 MW	2150 kCal / kWh for open cycle
>5 MW	1825 kCal / kWh for closed cycle

*The Commission may decide to amend and notify the revised norms on case-to-case basis

48.5 Secondary Fuel Oil Consumption

New plants on or after 1st April, 2025:

- i) Coal based thermal generating plant – 0.5 ml/kWh
- ii) Coal based thermal generating plant with CFBC technology - 1ml/kWh

48.6 Stabilization period and availability levels:

In relation to a unit, stabilization period shall be reckoned commencing from the date of commercial operation of that unit as follows, namely:

	PAF(%)	Stabilization period
(i) Coal-based thermal generating stations	65	180 days
(ii) Gas turbine / combined cycle generating stations	65	90 days

48.7 Wherever the station is designed for combined cycle operation, the approval of SLDC shall be required for operation of the station in the open cycle mode.

48.8 The Commission may prescribe relaxed operational norms including the norms of Normative Annual Plant Availability Factor contained in these Regulations for a generating station in case of Renovation & Modernization undertaken for the generating station or recommendations on energy saving schemes/ performance improvement studied in house / other independent agencies, and these relaxed norms shall be applicable for determination of tariff for such generating station during the Control Period.

Provided further that if any Unit of any of APGCL's Generating Stations is shut-down due to implementation of Central Power Research Institute (CPRI) recommendations, the Target Availability calculation for recovery of annual fixed charges shall be computed after removing

the Capacity under shut-down for the actual period of shut-down subject to the prior approval of the Commission for the improvement scheme along-with the approval of Capital expenditure.

48.9 In case of renovation and modernisation, derating and rerating of the generating station, norms of operation shall be reviewed and modified accordingly by the Commission.

48.10 The Commission vide separate notification may specify norms for future years on case to case basis.

49 Transit and handling Losses

49.1 Transit and handling losses for coal based generating stations, as a percentage of quantity of coal dispatched by the coal supply company during the month shall be as given below:

- i) Pit head generating stations : 0.2%
- ii) Non-pit head generating stations : 0.8%

49.2 The above norms shall be applicable for all types of coal i.e., domestic coal, washed coal and imported coal.

Provided that for procurement of coal on delivery basis, no transit and handling loss shall be allowed.

50 Norms of operation for Hydro Generating Stations

50.1 The norms of operation as given hereunder shall apply for existing hydro stations in the state:

Parameters	KLHEP
NAPAF	85 %
PLF	44.5 %
Auxiliary Consumption	1.00 %

50.2 The norms of operation for hydro generating station except those specified in Regulation 50.1 shall be as under, namely:

Sl. No.	Particulars	Normative Annual Plant Availability Factor
i)	Storage and Pondage type plants with head variation between Full Reservoir Level (FRL) and Minimum Draw Down Level (MDDL) of up to 8%, and where plant availability is not affected by silt	90%

ii)	Storage and Pondage type plants with head variation between FRL and MDDL of more than 8%, where plant availability is not affected by silt	Month wise peaking capability as provided by the project authorities in the DPR (approved by CEA or the State Government) shall form basis of fixation of NAPAF.
iii)	Pondage type plants where plant availability is significantly affected by silt	85%
iv)	Run-of-river type plants	To be determined plant-wise, based on 10-day design energy data, moderated by past experience where available/relevant

In addition to the above :

- a) A further allowance may be made by the Commission in NAPAF determination under special circumstances, e.g. abnormal silt problem or other operating conditions, and known plant limitations.
- b) A further allowance of 5% may be allowed for difficulties in the State.
- c) In case of a new hydro electric project the developer shall have the option of approaching the Commission in advance for fixation of NAPAF based on the principles enumerated in Clause 50.2 and sub-clause a) and b) of this regulation.
- d) In case of Pumped storage hydro generating stations, the quantum of electricity required for pumping water from down-stream reservoir to up-stream reservoir shall be arranged by the beneficiaries duly taking into account the transmission and distribution losses etc. up to the bus bar of the generating station. In return, beneficiaries shall be entitled to equivalent energy of 75% of the energy utilized in pumping the water from the lower elevation reservoir to the higher elevation reservoir from the generating station during peak hours and the generating station shall be under obligation to supply such quantum of electricity during peak hours:

Provided that in the event of the beneficiaries failing to supply the desired level of energy during off-peak hours, there will be pro-rata reduction in their energy entitlement from the station during peak hours:

Provided further that the beneficiaries may assign or surrender their share of capacity in the generating station, in part or in full, or the capacity may be reallocated by the Central Government, and in that event, the owner or assignee of the capacity share shall be responsible for arranging the equivalent energy to the generating station in off-peak hours, and be entitled to corresponding energy during peak hours in the same way as the original beneficiary was entitled.

50.3 Auxiliary Energy Consumption

- a) Surface Hydro electric power Generating Stations
 - i. With rotating exciters mounted on the generator shaft - 0.7%
 - ii. With static excitation system: 1% (Capacity above 200 MW)
1.2% (Capacity upto 200 MW)

- b) Underground hydro Generating Station
 - i. With rotating exciters mounted on the generator shaft - 0.9%
 - ii. With static excitation system: 1.2% (Capacity above 200 MW)
1.3% (Capacity upto 200 MW)

50.4 Transformation losses

From generation voltage to transmission voltage - 0.5% of energy generated.

50.5 The Commission vide separate notification may specify norms for future years on case-to-case basis.

51 Operation and Maintenance cost (O&M)**51.1 Existing Old Generating Station**

- a) The Operation and Maintenance expenses including insurance shall be derived on the basis of the average of the actual Operation and Maintenance expenses for the last three (3) years ending March 31st, 2024, based on the audited financial statements, excluding Special Operation and Maintenance expenses, if any, subject to prudence check by the Commission.
- b) The average of such Operation and Maintenance expenses shall be considered as operation and maintenance expenses for the financial year ended March 31st, 2024 and shall be escalated based on the escalation factor as approved by the Commission for the respective years to arrive at operation and maintenance expenses for the base year commencing April 1st, 2025.
- c) The O&M expenses for each subsequent year shall be determined by escalating the base expenses determined above for previous FY at the escalation factor equal to average of last three years CPI and WPI inflation considered in the ratio of 60:40 to arrive at permissible O&M expenses for each subsequent year.

a) Hydro Generating Stations

Existing Hydro Generating Stations

- i. The O&M charges for existing hydro generating stations shall be computed similar to the methodology detailed in Regulation 51.1.

b) New Hydro Generating Stations

- i. In the case of the hydro generating stations declared under commercial operation on or after 1.4.2025, operation and maintenance expenses of the first year shall be fixed at 3.5% and 5.0% of the original project cost (excluding the cost of rehabilitation & resettlement works, IDC and IEDC) for stations with installed capacity exceeding 200 MW and for stations with installed capacity less than or equal to 200 MW, respectively and shall be subject to annual escalation of 5.47% per annum for the subsequent years.
- ii. In the case of hydro generating stations which have not completed a period of three years as on 1.4.2025, operation and maintenance expenses for 2025-26 shall be worked out by applying an escalation rate of 5.47% on the applicable operation and maintenance expenses as on 31.3.2025. The operation and maintenance expenses for subsequent years of the tariff period shall be worked out by applying an escalation rate of 5.47% per annum.
- iii. The Security Expenses, Capital Spares and Insurance expenses arrived through competitive bidding for hydro generating stations shall be allowed separately after prudence check:

Provided that the generating station shall submit the assessment of the security requirement, capital spares and insurance expenses along with its estimated expenses, which shall be trued up based on the details of year-wise actual capital spares consumed, actual insurance and security expenses incurred with appropriate justification.

Provided further that the value of capital spares exceeding Rs. 10 Lakh shall only be considered for reimbursement at the time of truing up with appropriate justification for incurring the same and substantiating that the same is not claimed as a part of additional capitalisation or consumption of stores and spares and renovation and modernization.

- iv. Any additional O&M expenses incurred by the generating company due to any change in law event shall be considered at the time of truing up of tariff.

Provided that such impact shall be allowed only in case the overall impact of such change in law event in a year is more than 5% of normative O&M expenses of the project for the year.

- v. In the case of a generating company owned by the Central or State Government, the impact on account of implementation of wage or pay revision shall be allowed at the time of truing up of tariff;

c) New Thermal Generating Stations

- i. Normative Operation and Maintenance expenses of thermal generating stations shall be as follows: (1) Coal based and lignite fired (including those based on Circulating Fluidised Bed Combustion (CFBC) technology) generating stations, other than the generating stations or units referred to in this Regulation,

(in Rs Lakh/MW)

Year	200/210/ 250 MW Series	300/330/ 350 MW Series	500 MW Series	600 MW Series	800 MW Series and above
FY 2025-26	43.07	35.83	28.60	27.13	24.42
FY 2026-27	45.33	37.71	30.10	28.56	25.70
FY 2027-28	47.71	39.69	31.68	30.06	27.05
FY 2028-29	50.21	41.78	33.34	31.64	28.47
FY 2029-20	52.85	43.97	35.09	33.30	29.96

Provided also that operation and maintenance expenses of generating station having a unit size of less than 200 MW not covered above shall be determined on a case-to-case basis.

- ii. Open Cycle Gas Turbine/Combined Cycle generating stations:

(in Rs Lakh/MW)

Year	Gas Turbine Combined Cycle generating stations other than small gas turbine power generating stations	Small gas turbine power generating stations	Advance F Class Machines
FY 2025-26	19.14	50.37	33.77
FY 2026-27	20.14	53.02	35.54
FY 2027-28	21.20	55.80	37.40
FY 2028-29	22.32	58.73	39.37
FY 2029-30	23.48	61.81	41.43

iii. Lignite-fired generating stations

(in Rs Lakh/MW)

Year	125 MW Sets
FY 2025-26	40.85
FY 2026-27	42.99
FY 2027-28	45.25
FY 2028-29	47.62
FY 2029-30	50.12

iv. Generating Stations based on coal rejects

(in Rs Lakh/MW)

Year	125 MW Sets
FY 2025-26	40.85
FY 2026-27	42.99
FY 2027-28	45.25
FY 2028-29	47.62
FY 2029-30	50.12

- v. The Water Charges, Security Expenses, Ash Transportation Expenses and Capital Spares for thermal generating stations shall be allowed separately after prudence check;

Provided that water charges shall be allowed based on water consumption depending upon type of plant and type of cooling water system or water agreement with state govt./utilities, and the norms specified by the Ministry of Environment, Forest and Climate Change subject to prudence check. The details regarding the same shall be furnished along with the petition;

Provided further that the generating station shall submit the assessment of the security requirement and estimated expenses along with the petition seeking the determination of tariff;

- vi. Any additional O&M expenses incurred by the generating company due to any change in law shall be considered at the time of truing up of tariff. Provided that such impact shall be allowed only in case the overall impact of such change in law event in a year is more than 5% of normative O&M expenses of the project allowed for the year.
- vii. In the case of a generating company owned by the Central or State Government, the impact on account of implementation of wage or pay revision shall be allowed at the time of truing up of tariff.

52 Computation and Payment of Annual Fixed Charges and Energy Charges for Thermal Generating Stations

52.1 Annual Fixed Charges

- a) The total Annual Fixed Charges shall be computed based on the norms specified under these Regulations and recovered on monthly basis.
- b) The full Annual Fixed Charges shall be recoverable at Normative Annual Plant Availability factor (NAPAF) specified in these Regulation. Recovery of Annual Fixed Charges below the level of NAPAF shall be on pro rata basis. At zero Availability, no Capacity Charges shall be payable.
- c) Payment of Annual Fixed Charges shall be on monthly basis in equal installments in proportion to contracted capacity subject to adjustment at the end of the year with respect to NAPAF.

52.2 Energy Charges

- a) The Energy (variable) Charges shall cover landed fuel costs and shall be computed as follows:

Energy (variable) Charges shall cover fuel costs and shall be worked out on the basis of ex-bus energy sent out from the Generating Station as per the following formula:

Energy Charges (Rs) = Rate of Energy Charges in Rs/kWh x Energy (ex-bus) for the month in kWh corresponding to actual generation.

- b) Energy charge rate (ECR) in Rupees per kWh on ex-power plant basis shall be determined to two decimal places in accordance with the following formulae:

For gas and liquid fuel based stations:

$ECR = SHR \times LPPF \times 100 / \{(CVPF) \times (100 - AUX)\}$ Where,

AUX = Normative auxiliary energy consumption in percentage.

CVPF = Weighted Average Gross calorific value of primary fuel as received, in kCal per kg, per litre or per standard cubic meter, as applicable for lignite, gas and liquid fuel based stations;

LPPF = Weighted average landed fuel cost of primary fuel, in Rupees per kg, per litre or per standard cubic metre, as applicable, during the month.

Energy Charges, for the purpose of billing/Fuel Surcharge shall be worked out station-wise based on weighted average rate based on actual generation from the Units of each Station

- 52.3 Adjustment of rate of energy charge (REC) [Fuel Surcharge Adjustment] on account of variation in price or calorific value of fuels

Any variation in Price and Gross Calorific Value of coal or gas or liquid fuel vis-à-vis approved values shall be adjusted on month to month basis on the basis of average Gross Calorific Value

of coal or gas or liquid fuel in stock, received and burnt and weighted average landed cost incurred by the Generating Company for procurement of coal, oil, or gas or liquid fuel, as the case may be for a power station. In its bills, the Generating Company shall indicate rate of energy charges at base price of primary and secondary fuel specified by the Commission and the Fuel Surcharge to it separately. The Generating Company should submit the computation to the Commission on monthly basis for analysis and approval of Fuel Surcharge Adjustment.

52.4 Landed Cost of fuel

The landed cost of fuel shall include price of fuel corresponding to the grade/ quality/ calorific value of fuel inclusive of royalty, taxes and duties as applicable, transportation cost by rail/road/gas pipe line or any other means, and, for the purpose of computation of energy charges, shall be arrived at after considering normative transit and handling losses as percentage of the quantity of fuel dispatched by the fuel supply company during the month as specified in Regulation 52.2.

53 Incentive

53.1 Incentive shall be payable at a flat rate of 50.0 paise/kWh for actual energy generation in excess of ex-bus energy corresponding to target Plant Load Factor.

Provided that the actual generation shall also consider the generation loss on account of any backing down instruction from the Assam State Load Despatch Centre.

53.2 The Incentive amount shall be computed and billed on monthly basis based on the cumulative Plant Load Factor till the respective month in a Year, subject to adjustment at the end of the year.

54 Computation and Payment of Annual Fixed Charges and Energy Charges for Hydro Generating Stations

54.1 The Annual Fixed Charges of a Hydro Generating Station shall be computed on annual basis, based on norms specified under these Regulations, and recovered on monthly basis under capacity charge (inclusive of incentive) and Energy Charge, which shall be payable by the beneficiaries in proportion to their respective share in the capacity of the Generating Station. Further, in addition to Annual Fixed Charges to be recovered through Capacity Charge and Energy Charge, the Lease Rent and Water Royalty shall be payable by the beneficiaries in proportion to their respective share in the capacity of the Generating Station on monthly basis.

54.2 The capacity charge (inclusive of incentive) payable to a Hydro Generating Station for a calendar month shall be

$$AFC \times 0.5 \times NDM / NDY \times (PAFM / NAPAF) \text{ (in Rupees)}$$

Where,

AFC = Annual fixed cost specified for the year, in Rupees.

NAPAF = Normative Annual Plant Availability Factor in percentage

NDM = Number of days in the month

NDY = Number of days in the year

PAFM = Plant availability factor achieved during the month, in Percentage

54.3 The PAFM shall be computed in accordance with the following formula:

$$\text{PAFM} = 10000 \times \sum \text{DC}_i / \{N \times \text{IC} \times (100 - \text{AUX})\} \% \quad i = 1$$

Where,

AUX = Normative auxiliary energy consumption in percentage

DC_i = Declared capacity (in ex-bus MW) for the ith day of the month which the station can deliver for at least three (3) hours, as certified by the Assam State Load Despatch Centre after the day is over.

IC = Installed capacity (in MW) of the complete Generating Station

N = Number of days in the month

The Energy Charge shall be payable by every beneficiary for the total energy supplied to the beneficiary, during the calendar month, on ex-power plant basis, at the computed Energy Charge rate.

Total Energy Charge payable to the Generating Company for a month shall be:

$$(\text{Energy Charge Rate in Rs. / kWh}) \times \{\text{Scheduled Energy (ex-bus) for the month in kWh}\} \times (100 - \text{FEHS}) / 100$$

54.4 Energy Charge Rate (ECR) in Rupees per kWh on ex-power plant basis, for a Hydro Generating Station, shall be determined up to three decimal places based on the following formula:

$$\text{ECR} = \text{AFC} \times 0.5 \times 10 / \{ \text{DE} \times (100 - \text{AUX}) \times (100 - \text{FEHS}) \}$$

Where,

DE = Annual Design Energy specified for the Hydro Generating Station, in MWh, subject to the provision as per Regulation 50.5.

FEHS = Free energy for home State, in percent.

54.5 In case actual total energy generated by a Hydro Generating Station during a year is less than the Design Energy for reasons beyond the control of the Generating Company, the following treatment shall be applied on a rolling basis:

- (i) in case the energy shortfall occurs within ten years from the date of commercial operation of a Generating Station, the ECR for the year following the year of energy shortfall shall be computed based on the formula specified in Regulation 49.4 with the modification that the DE for the year shall be considered as equal to the actual energy generated during the year of the shortfall, till the Energy Charge shortfall of the previous year has been made up, after which normal ECR shall be applicable;

Provided that in case actual generation from a hydro generating station is less than the design energy for a continuous period of 4 years on account of hydrology factor, the generating station shall approach CEA with relevant hydrology data for revision of design energy of the station.

- (ii) in case the energy shortfall occurs after ten years from the date of commercial operation of a Generating Station, the following shall apply:

Suppose the specified annual Design Energy (DE) for the station is DE MWh, and the actual energy generated during the concerned (first) and the following (second) financial years is A1 and A2 MWh, respectively, A1 being less than DE. Then, the design energy to be considered in the formula in Regulation 50.4 of these Regulations for calculating the ECR for the third financial year shall be moderated as $(A1 + A2 - DE)$ MWh, subject to a maximum of DE MWh and a minimum of A1 MWh.

- (iii) Actual energy generated (e.g., A1, A2) shall be arrived at by multiplying the net metred energy sent out from the station by $100 / (100 - AUX)$.

54.6 In case the actual saleable energy in a year exceeds $\{DE \times (100 - AUX) \times (100 - FEHS) / 10000\}$ MWh, the Energy Charge for the energy in excess of the above shall be billed equal to the lowest variable charges of the central sector thermal power generating stations in the north east region.

54.7 The Assam State Load Despatch Centre shall finalise the schedules for the hydro Generating Stations, in consultation with the beneficiaries, for optimal utilization of all the energy declared to be available, which shall be scheduled for all beneficiaries in proportion to their respective allocations in the Generating Station.

Pumped Storage Hydro Generating Stations:

54.8 The fixed cost of a pumped storage hydro generating station shall be computed on annual basis, based on norms specified under these regulations, and recovered on monthly basis as capacity charge. The capacity charge shall be payable by the beneficiaries in proportion to their respective allocation in the saleable capacity of the generating station, i.e, the capacity excluding the free power to the home State:

Provided that during the period between the date of commercial operation of the first unit of the generating station and the date of commercial operation of the generating station, the annual fixed cost shall be worked out based on the latest estimate of the completion cost for the generating station, for the purpose of determining the capacity charge payment during such period.

- 54.9 The capacity charge payable to a pumped storage hydro generating station for a calendar month shall be:

$(AFC \times NDM / NDY)$ (in Rupees), if actual Generation during the month is $\geq 75\%$ of the Pumping Energy consumed by the station during the month and $\{(AFC \times NDM / NDY) \times (\text{Actual Generation during the month during peak hours} / 75\% \text{ of the Pumping Energy consumed by the station during the month})\}$ (in Rupees), if actual Generation during the month is $< 75\%$ of the Pumping Energy consumed by the station during the month.

Where,

AFC = Annual fixed cost specified for the year, in Rupees

NDM = Number of days in the month

NDY = Number of days in the year

Provided that there would be adjustment at the end of the year based on actual generation and actual pumping energy consumed by the station during the year.

- 54.10 The energy charge shall be payable by every beneficiary for the total energy scheduled to be supplied to the beneficiary in excess of the design energy plus 75% of the energy utilized in pumping the water from the lower elevation reservoir to the higher elevation reservoir, at a flat rate equal to the average energy charge rate of 20 paise per kWh, excluding free energy, if any, during the calendar month, on ex power plant basis.

- 54.11 Energy charge payable to the generating company for a month shall be:

$= 0.20 \times \{ \text{Scheduled energy (ex-bus) for the month in kWh} - (\text{Design Energy for the month (DEm)} + 75\% \text{ of the energy utilized in pumping the water from the lower elevation reservoir to the higher elevation reservoir of the month}) \} \times (100 - \text{FEHS}) / 100.$

Where,

DEm = Design energy for the month specified for the hydro generating station, in MWh

FEHS = Free energy for home State, in per cent, as defined in regulation, if any.

Provided that in case the Scheduled energy in a month is less than the Design Energy for the month plus 75% of the energy utilized in pumping the water from the lower elevation reservoir to the higher elevation reservoir of the month, then the energy charges payable by the beneficiaries shall be zero.

Provided that if the energy for the pumping of water from lower reservoir to upper reservoir is arranged by the generating company, the charges for the pumping energy till the ex-Bus of the generating station shall be payable by the beneficiaries in proportion to their respective allocation in the saleable capacity of the generating station.

- 54.12 The generating company shall maintain the record of daily inflows of natural water into the upper elevation reservoir and the reservoir levels of upper elevation reservoir and lower elevation reservoir on hourly basis. The generator shall be required to maximize the peak hour supplies with the available water including the natural flow of water. In case it is established that generator is deliberately or otherwise without any valid reason, is not pumping water from lower elevation reservoir to the higher elevation during off-peak period or not generating power to its potential or wasting natural flow of water, the capacity charges of the day shall not be payable by the beneficiary. For this purpose, outages of the unit(s)/station including planned outages and the forced outages up to 15% in a year shall be construed as the valid reason for not pumping water from lower elevation reservoir to the higher elevation during off-peak period or not generating power using energy of pumped water or natural flow of water:

Provided that the total capacity charges recovered during the year shall be adjusted on pro-rata basis in the following manner in the event of total machine outages in a year exceeds 15%:

$$(ACC)_{adj} = (ACC) R \times (100 - ATO)/85$$

Where,

(ACC)_{adj} – Adjusted Annual Capacity Charges

(ACC) R – Annual Capacity Charges recovered

ATO - Total Outages in percentage for the year including forced and planned outages

Provided further that the generating station shall be required to declare its machine availability daily on day ahead basis for all the time blocks of the day in line with the scheduling procedure of Grid Code.

- 54.13 The concerned Load Despatch Centre shall finalise the schedules for the hydro generating stations, in consultation with the beneficiaries, for optimal utilization of all the energy declared to be available, which shall be scheduled for all beneficiaries in proportion to their respective allocations in the generating station.

55 Scheduling

The methodology for scheduling and dispatch for the generating plant shall be as per relevant rules and regulations notified by the Assam Electricity Regulatory Commission/CEA/CERC.

56 Deviation Settlement Mechanism (DSM) Charges.

DSM charges for intra-state transactions will be as per AERC (Deviation Settlement Mechanism and Related Matters) Regulations, 2019, as amended time to time.

57 Metering and Accounting

Metering arrangements, including installation, testing and operation and maintenance of metres and collection, transportation and processing of data required for accounting of energy exchanges and average frequency on time block basis shall be arranged by the State Transmission Utility/ State Load Despatch Centres. All concerned entities (in whose premises the special energy metres are installed), shall fully cooperate with the State Transmission Utility/ State Load Despatch Centre and extend the necessary assistance by taking weekly metre readings and transmitting them to the State Load Despatch Centre. The State Load Despatch Centre shall issue the Accounts for energy as specified in the relevant regulations notified by the Commission.

58 Demonstration of declared capacity

- 58.1 The Generating Company may be required to demonstrate the declared capacity of its Generating Station as and when asked by the Assam State Load Despatch Centre. In the event of the Generating Company failing to demonstrate the declared capacity, the capacity charges due to the Generating Company shall be reduced as a measure of penalty.
- 58.2 The quantum of penalty for the first mis-declaration for any duration/block in a day shall be the charges corresponding to two days fixed charges. For the second mis-declaration, the penalty shall be equivalent to fixed charges for four days. For the third mis-declaration, the penalty shall be equivalent to fixed charges for eight days and similarly for subsequent mis-declarations in the year, the penalty shall be computed progressively.
- 58.3 The operating logbooks of the Generating Station shall be available for review by the SLDC, as the case may be. These books shall keep record of machine operation and maintenance.

59 Payment Modalities

- 59.1 The Billing and Payment of Annual Fixed Charges, Energy Charges, Fuel Surcharge Adjustments and Incentive for Thermal Generating Stations shall be done on a monthly basis subject to adjustments at the end of the year.
- 59.2 The Billing and Payment of Capacity Charges and Energy Charges for Hydro Generating Stations shall be done on a monthly basis.
- 59.3 In case the payment of any bill for charges payable under these regulations is delayed by a beneficiary or long term customer as the case may be, beyond a period of 45 days from the date of presentation of bills, a late payment surcharge as specified in the Ministry of Power – Electricity (Late Payment Surcharge and Related Matters) Rules, 2022 as amended from time

to time shall be levied by the generating company or the transmission licensee, as the case may be:

Provided that in case a different LPS mechanism is provided in the PPA, the same shall be governed by the provisions of the PPA.

Unless otherwise agreed by the parties, the charges payable by a beneficiary or long term customer shall be first adjusted towards a late payment surcharge on the outstanding charges and, thereafter, towards monthly charges billed by the generating company or the transmission licensee, as the case may be, starting from the longest overdue bill.

CHAPTER 7: COMPONENTS OF ARR AND TARIFF FOR TRANSMISSION LICENSEE

60 Applicability

- 60.1 The Regulations contained in this Chapter shall apply in determining tariff for access and use of the intra-State transmission system of a Transmission Licensee pursuant to a Bulk Power Transmission Agreement or other arrangement entered into with a Transmission System User on or after the date of notification of these Regulations.

Provided that the Commission may revise the norms contained in this Chapter or stipulate alternative norms for particular cases, where it so deems appropriate, having regard to the circumstances of the case:

Provided further that the reasons for such revision shall be recorded in writing:

Provided also that in case of an existing transmission system, the Commission shall determine the tariff having regard to the historical performance of such transmission system and on the basis of application for determination of Aggregate Revenue Requirement submitted by the Transmission Licensees at the beginning of the Control Period with reasonable opportunities for improvement in performance, if any.

- 60.2 The Commission shall be guided by the terms and conditions contained in this Chapter in specifying the rates, charges, terms and conditions for use of intervening transmission facilities pursuant to an application made in this regard by a Transmission Licensee under the proviso to Section 36 of the Act.

61 Components of Tariff

- 61.1 The transmission charges for access to and use of the intra-State transmission system shall comprise any of the following components or a combination of the following components:

- a) transmission system access charges;
- b) annual transmission charges;
- c) per unit charges for energy transmitted; and
- d) reactive energy charges.

Transmission system access charges

- 61.2 Any person who is eligible to apply for access to the intra-State transmission system shall be entitled to obtain such access in accordance with the AERC (Terms and Conditions for Open Access) Regulations, 2024, as amended from time to time and shall be liable to pay the charges for obtaining such access as specified in this Regulation.

Explanation - For the purpose of this Regulation, such person who, being eligible for transmission open access, has applied for allocation of transmission capacity rights and has

agreed to the carrying out of works for obtaining such access shall hereinafter be referred to as the "intending Transmission System User", and may include an existing Transmission System User in respect of any increase in allocated transmission capacity rights applied for by such existing user.

- 61.3 Where the access of the intending Transmission System User to the intra-State transmission system entails works of transmission lines or other transmission assets dedicated to such User, the Transmission Licensee shall be entitled to recover, through the transmission system access charges, all expenses reasonably incurred on such works for providing access to such intending Transmission System User.
- 61.4 Where the access of the intending Transmission System User entails other works, not covered under Regulation 61.3 relating to the intra-State transmission system, the Transmission Licensee shall recover the expenses relating to such works through annual transmission charges for each year of the Control Period, in accordance with Regulation 61.10 below:
- 61.5 Where any works for obtaining access has been carried out by the intending Transmission System User, the Transmission Licensee shall be entitled to recover supervision charges at the rate of 15 per cent of the cost of labour employed for carrying out such works and shall not be entitled to recover any other expenses with regard to such works carried out by the intending Transmission System User.

Provided that such supervision charges shall form part of the Non-Tariff Income of the respective Transmission Licensee and also shall be treated as O&M expense incurred by the intending transmission system users, which shall be capitalised in the respective year of asset capitalisation.

- 61.6 The works for providing access to the intra-State transmission system shall be maintained by the Transmission Licensee for the duration of the Bulk Power Transmission Agreement between the Transmission Licensee and the Transmission System User.
- 61.7 Where the Transmission System User has paid for the works carried out to provide him access to the intra-State transmission system, the Transmission System User shall be entitled to the depreciated value of such works paid for by him upon termination of the Bulk Power Transmission Agreement:

Provided that where the Transmission System User has carried out the works to provide him access to the intra-State transmission system of the Transmission Licensee, the Transmission System User shall be entitled to retain such works upon termination of the Bulk Power Transmission Agreement.

- 61.8 The transmission system access charges may be recovered by any one of the following methods, in accordance with the terms of the Bulk Power Transmission Agreement:
- a) As a one-time payment by the Transmission System User at the time of obtaining access;
or

- b) As a series of payments over the duration of the Bulk Power Transmission Agreement; or
- c) As any combination of (a) and (b) above.

61.9 Any dispute between the Transmission Licensee and the intending Transmission System User with regard to the works to be carried out to give access to the intending Transmission System User or with regard to the transmission system access charges shall be referred to the Commission for adjudication or to such other forum as may be stipulated.

Annual transmission charges for each year of the Control Period

61.10 The annual transmission charges for each financial year of the Control Period shall provide for the recovery of the aggregate revenue requirement of the Transmission Licensee for the respective financial year of the Control Period, as reduced by the amount of non-tariff income and income from Other Business, as approved by the Commission and comprising the following:

Aggregate revenue requirement:

- a) Return on Equity Capital;
- b) Interest on Loan Capital;
- c) Depreciation;
- d) Operation and maintenance expenses;
- e) Interest on working capital and deposits from Transmission System Users;

Minus:

- f) Non-tariff income; and
- g) Income from Other Business, to the extent specified in these Regulations
Provided that in case of competitively awarded transmission system projects in pursuance of Section 63 of the Act and in accordance with guidelines for competitive bidding for transmission, the annual transmission charges shall be as per the Annual Transmission Service Charges (TSC) quoted by such competitively awarded transmission projects.

61.11 The annual transmission charges of the Transmission Licensee shall be determined by the Commission on the basis of an application for determination of aggregate revenue requirement or application for adoption of annual transmission charges in case of competitively awarded transmission system project, as the case may be, made by the Transmission Licensee in accordance with Chapter 3 of these Regulations.

62 Multi-Year Tariff

Except where exempted by the Commission, the Regulations contained in Chapter 3 of these Regulations shall apply to all Transmission Licensees and Transmission System Users in the State with effect from April 1st, 2025.

63 Financial Principles

Except where exempted by the Commission, the Regulations contained in Chapter 5 of these Regulations shall apply to all Transmission Licensees in the State with effect from April 1st, 2025.

64 Capital Investment Plan

- 64.1 Each Transmission Licensee shall submit a Capital Investment Plan, as part of MYT Petition, to the Commission in accordance with Regulation 6 of these Regulations including complete details of its capital expenditure projects.
- 64.2 The Commission shall review the Capital Investment Plan submitted by the Transmission Licensee taking into consideration the prudence of the proposed expenditure and estimated impact on transmission charges in accordance with Regulation 6.
- 64.3 The Transmission Licensee shall submit, along with the MYT Petition or along with the Petition for Annual Performance Review, as the case may be, details showing the progress of capital expenditure projects, together with such other information, particulars or documents as the Commission may require to assess such progress.

65 Tariff Based Competitive Bidding (TBCB)

- 65.1 The Commission hereby decides threshold limit for the new individual Intra-State Transmission projects (not package/schemes) of Rs 250 Crore (Two Hundred and Fifty Crores only). The transmission projects executed through Tariff Based Competitive Bidding (TBCB) process shall be carried out in accordance with the guidelines issued by the Ministry of Power, Government of India from time to time.

Provided that the projects which have already been approved, expansion and up-gradation of the existing substations and transmission lines of the licensee shall be excluded from the TBCB.

Provided further that the State Government may give exemption to specific projects of strategic importance and works required to be done on an urgent situation on case to case basis.

66 Capital Cost.

- 66.1 For the purpose of determination of tariff, the Capital Cost for a Transmission Project and additional capitalisation thereof, shall be allowed in accordance with the provisions outlined under Regulation 29 and Regulation 30 respectively.
- 66.2 The provisions of Accounting Standards (AS10) / Indian Accounting Standard (IAS 16): Accounting for Fixed Assets as per applicable, shall apply, to the extent not inconsistent with these Regulations, in determining the original cost of capital expenditure projects and/or original cost of fixed assets capitalized.

- 66.3 The amount of any contributions made by Transmission System Users towards works for access to the intra-State transmission system of the Transmission Licensee shall be deducted from the original cost for such project for the purpose of calculating the Equity Capital as provided in these Regulations.

67 Norms for operation

- 67.1 Target availability for full recovery of annual transmission charges

(a) AC system : 98%

(b) HVDC bi-pole links & HVDC back to back stations : 95%

For incentive consideration:

(a) AC system : 98.5%

(b) HVDC bi-pole links & HVDC back to back stations : 96%

Provided that for new HVDC station NATAF shall be considered as 95% for first three years of operations for the purpose of incentive:

Provided further that no incentive shall be payable above the availability of 99.75%:

Provided also that the computation of incentive/disincentive shall be undertaken during annual performance review and at the end of Control Period.

Provided further that for AC and HVDC system, actual outage hours shall be considered for computation of availability up to two tripping per year. After two tripping in a year, for every tripping, an additional 12 hours of outage shall be considered in addition to the actual outage hours:

Provided also that in case of an outage of a transmission element affecting evacuation of power from a generating station, outage hours shall be multiplied by a factor of 2.

68 Calculation of Aggregate Revenue Requirement

- 68.1 Aggregate Revenue Requirement of Transmission Licensee shall comprise of following components, viz.,

a) Return on Equity Capital;

b) Interest on Loan Capital;

c) Depreciation;

d) Operation and maintenance expenses;

e) Interest on working capital and deposits from Transmission System Users.

Minus,

g) Non-tariff income; and

h) Income from Other Business, to the extent specified in these Regulations.

68.2 Return on Equity Capital

68.2.1 The Transmission Licensee shall be allowed a return on equity capital, as specified in Regulation 34 of these Regulations.

68.3 Interest on Loan Capital

68.3.1 The Transmission Licensee shall be allowed interest on the Loan Capital, as specified in Regulation 35 of these Regulations.

68.4 Depreciation

68.4.1 The Transmission Licensee shall be permitted to recover depreciation on the value of fixed assets used in the Transmission Business as specified in Regulation 33 of these Regulations.

68.5 Operation and Maintenance expenses

68.6 Existing Transmission Licensee

68.6.1 Operation and Maintenance (O&M) expenses shall comprise of the following

- a) Salaries, wages, pension contribution and other employee costs;
- b) Administrative and general expenses including insurance charges if any;
- c) Repairs and maintenance expenses;

68.6.2 The O&M expenses for the first year of the Control Period shall be approved by the Commission taking into account the actual O&M expenses for last five years till Base Year subject to prudence check and any other factors considered appropriate by the Commission.

68.6.3 The O&M expenses for the nth year and also for the year immediately preceding the Control Period shall be approved based on the formula given below:-

$$O\&M_n = R\&M_n + EMP_n + A\&G_n$$

Where –

- $O\&M_n$ – Operation and Maintenance expense for the nth year;
- EMP_n – Employee Costs for the nth year;
- $R\&M_n$ – Repair and Maintenance Costs for the nth year;
- $A\&G_n$ – Administrative and General Costs for the nth year;

68.6.4 The above components shall be computed in the manner specified below:

$$EMP_n = (EMP_{n-1}) \times (1+G_n) \times (CP \text{ inflation})$$

$$R\&M_n = K \times (GFA_{n-1}) \times (WP \text{ inflation}) \text{ and}$$

$$A\&G_n = (A\&G_{n-1}) \times (WPI_{inflation}) + Provision$$

Where -

- EMP_{n-1} – Employee Costs for the (n-1)th year;
- $A\&G_{n-1}$ – Administrative and General Costs for the (n-1)th year;
- Provision: Cost for initiatives or other one-time expenses as proposed by the Transmission Licensee and validated by the Commission.
- 'K' is a constant specified by the Commission in %. Value of K for each year of the control period shall be determined by the Commission in the MYT Tariff order based on licensee's filing, benchmarking of repair and maintenance expenses, approved repair and maintenance expenses vis-à-vis GFA approved by the Commission in past and any other factor considered appropriate by the Commission;
- CPI inflation – is the average increase in the Consumer Price Index (CPI) for immediately preceding three years;
- WPI inflation – is the average increase in the Wholesale Price Index (WPI) for immediately preceding three years;
- GFA_{n-1} --- Gross Fixed Asset of the transmission licensee for the n-1th year;
- G_n is a growth factor for the nth year. Value of G_n shall be determined by the Commission in the MYT tariff order for meeting the additional manpower requirement based on licensee's filings, benchmarking, and any other factor that the Commission feels appropriate:

68.7 O&M Norms for New Transmission Licensee

For the New transmission licensees, the year-wise O&M norms shall be determined on case to case basis:

Provided that the same shall not be applicable to those new projects which are awarded on a competitive bidding basis.

Explanation: The term "New Transmission Licensee" shall mean the transmission licensee(s) for which Transmission Licence is granted by the Commission prior to or after the date of effectiveness of these Regulations, and whose transmission project assets are commissioned after March 31, 2024.

68.8 O&M Sharing between two Transmission Licensees

- 68.8.1 For such Transmission Licensees whose bays are installed in the premises of and maintained by another Transmission Licensee, the O&M expense for such assets shall be allowed in accordance with the norms applicable for the Transmission Licensee who performs the O&M of such assets:

Provided that the Transmission Licensees shall mutually agree on sharing of such allowed O&M expenses:

Provided further that Transmission Licensees shall project addition of such assets over the Control Period separately in their Capital Investment Plan to be submitted in accordance with Regulation 6.

68.9 Contribution to Contingency Reserve

- 68.9.1 The Transmission Licensee may make an appropriation to the Contingency Reserve of a sum not exceeding 0.1 per cent of the gross fixed assets approved by the Commission at the beginning of the year, for each year, which shall be allowed in the calculation of aggregate revenue requirement:

Provided that where the amount of such Contingency Reserve exceeds one (1) per cent of the gross fixed assets, no such appropriation shall be allowed, which would have the effect of increasing the reserve beyond the said maximum:

Provided further that the amount so appropriated may be invested in securities and fixed deposit. Interest earned shall be added to the Contingency Reserve.

Provided further that the amount of such Contingency Reserve shall not be utilized for any other purpose except for reasons specified in these Regulations.

Provided also that the Transmission Licensee shall maintain separate account for such reserve.

- 68.9.2 The Contingency Reserve shall not be drawn upon during the term of the licence except to meet such charges as may be approved by the Commission as being the expenses arising out of accidents, natural calamities or circumstances beyond the control of the Licensee;

Provided that such drawal from Contingency Reserve shall be computed after making due adjustments for any other compensation that may have been received by the Licensee as part of an insurance cover and Government Grant, if any.

68.10 Interest on working capital

- 68.10.1 The Transmission Licensee shall be allowed interest on the estimated level of working capital, as specified in Regulation 37 of these Regulations.

69 Non-Tariff Income

- 69.1 The amount of non-tariff income relating to the Transmission Business as approved by the Commission shall be deducted from the aggregate revenue requirement in determining annual transmission charges of the Transmission Licensee:

The indicative list of various heads to be considered for Non-Tariff Income shall be as under:

- (a) Income from rent on land or buildings;
- (b) Income from sale of scrap;
- (c) Income from statutory investments;
- (e) Interest on advances to suppliers/contractors;
- (f) Rental from staff quarters;
- (g) Rental from contractors;
- (h) Income from hire charges from contactors and others;
- (i) Income from advertisements, sale of tender etc.;
- (j) Miscellaneous receipts like parallel operation charges;
- (k) Deferred Income from grant, subsidy, etc., as per Annual Accounts;
- (l) Excess found on physical verification;
- (m) Interest on investments, fixed and call deposits and bank balances;*
- (o) Supervisory charges for contractual works;
- (p) Any other Non-Tariff Income:

*(*Note – Any income from fixed deposit made out of profit of the Transmission Licensee shall not be deducted as Non-Tariff Income, provided the details of the same, certified by the auditor is made available)*

Provided that the interest/dividend earned from investments made out of Return on Equity corresponding to the regulated business of the Transmission Licensee shall not be included in Non-Tariff Income.

Provided further that the Transmission Licensee shall submit full details of its forecast of non-tariff income to the Commission along with its application for determination of aggregate revenue requirement.

70 Income from Other Business

- 70.1 Where the Transmission Licensee has engaged in any Other Business, an amount equal to one-third of the revenues from such Other Business after deduction of all direct and indirect costs attributed to such Other Business shall be deducted from the aggregate revenue requirement in calculating the annual transmission charges of the Transmission Licensee:

Provided that the Transmission Licensee shall follow a reasonable basis for allocation of all joint and common costs between the Transmission Business and the Other Business and shall

submit the Allocation Statement as approved by the Board of Directors to the Commission along with its application for determination of tariff:

Provided further that where the sum total of the direct and indirect costs of such Other Business exceed the revenues from such Other Business, no amount shall be allowed to be added to the aggregate revenue requirement of the Transmission Licensee on account of such Other Business.

71 Computation and Payment of Transmission Charge

71.1 The Annual Transmission Charges for the Transmission Licensee shall be determined, based on the norms as specified in these Regulations and recovered on monthly basis as transmission charge from the users who shall share the Transmission Charge in proportion of the allotted transmission capacity.

Provided that the charges payable by the Transmission System Users may also take into consideration factors such as voltage, distance, direction, quantum of flow and time of use, as may be specified by the Commission in its order.

71.2 The transmission charge (inclusive of incentive) payable for a calendar month for a transmission system or part thereof shall be computed in accordance with the following equation:

For AC system:

- a) For $TAFM_n \leq 98.00\%$

$$AFC \times (NDM_n/NDY) \times (TAFM_n/98.00\%)$$
- b) For $TAFM_n: 98.00\% < TAFM_n < 98.50\%$

$$AFC \times (NDM_n/NDY) \times (1)$$
- c) For $TAFM_n: 98.50\% < TAFM_n \leq 99.75\%$

$$AFC \times (NDM_n/NDY) \times (TAFM_n/98.50\%)$$
- d) For $TAFM_n > 99.75\%$

$$AFC \times (NDM_n/NDY) \times (99.75\%/98.50\%)$$

Where,

AFC = Annual Fixed Cost specified for the year in Rupees

NDM_n = Number of days in nth month

NDY = Number of days in the year

TAFM_n = Transmission System availability factor for the nth month, in percent computed in accordance with Appendix III.

For HVDC bi-pole links and HVDC back-to-back Stations:

$$TC1 = AFC \times (NDM1 / NDY) \times (TAFM1/NATAF)$$

$$TC2 = AFC \times (NDM2 / NDY) \times (TAFM2/NATAF) - TC1$$

$$TC3 = AFC \times (NDM3 / NDY) \times (TAFM3/NATAF) - (TC1+TC2)$$

$$TC4 = AFC \times (NDM4 / NDY) \times (TAFM4/NATAF) - (TC1+TC2+TC3)$$

.....

$$TC11 = AFC \times (NDM11/NDY) \times (TAFM11/NATAF) - (TC1+TC2+....+TC10)$$

$$TC12 = AFC \times (TAFY/NATAF) - (TC1+TC2+....+TC11);$$

If,

- (i) TAFM: 95.00% < TAFM < 97.50%, then TAFM=NATAF;
- (ii) TAFM: 97.50% ≤ TAFM ≤ 99.75%, then NATAF=97.50%; and
- (iii) For TAFM ≥ 99.75%, then TAFM=99.75% and NATAF= 97.50%.

Where,

TCn = Transmission charges inclusive of incentive up to the nth month

AFC = Annual fixed cost specified for the year in rupees

NATAF = Normative Annual Transmission Availability Factor in percentage

NDMn = No of days up to the end of the nth month of the financial year

NDY = No. of days in the year

TAFMn. = Transmission availability factor up to the end of the nth month of the year in percentage computed in accordance with Appendix -II

TAFY = Transmission availability factor in per cent for the year.

71.3 The monthly Transmission Tariff as determined by the Commission as per Regulation 71.2 above shall be shared by all long-term and medium-term open access customers on monthly basis (including existing Distribution Licensees) in the ratio of their allotted capacities.

71.4 The transmission licensee shall raise the bill for the transmission charge (inclusive of incentive) for a month based on its estimate of TAFMn. Adjustments, if any, shall be made on the basis of the TAFM to be certified by the SLDC within 30 days from the last day of the relevant month.

72 Open Access Transactions

- 72.1 All the matters related to Open Access Transactions shall be dealt in accordance with Assam Electricity Regulatory Commission (Terms and Condition for Open Access) Regulations, 2024 as applicable and as amended from time to time.

73 Transmission losses

- 73.1 The energy losses in the transmission system of the Transmission Licensee, as determined by the State Load Despatch Centre and approved by the Commission, shall be borne by the Transmission System Users pro-rata to their usage of the intra-State transmission system:

Provided that the Commission may stipulate a trajectory for reduction of transmission losses in accordance with Regulation 7, as a part of Multi Year Tariff framework applicable to the Transmission Licensee.

74 Payment Modalities

- 74.1 State Transmission Utility (STU) shall raise monthly bill for Intra-State Transmission Charges on every Transmission System User (TSU) on 1st working day of the Month for the Transmission Charges of preceding month.
- 74.2 The monthly bill for transmission tariff for each calendar month shall be payable on 14th day of subsequent calendar month by the TSUs.
- 74.3 All TSUs shall ensure timely payment of Transmission Tariff to STU so as to enable STU to make timely settlement of claims raised by Transmission Licensees.

In case the payment of any bill for charges payable under these regulations is delayed by a beneficiary or long term customer as the case may be, beyond a period of 45 days from the date of presentation of bills, a late payment surcharge as specified in the Ministry of Power – Electricity (Late Payment Surcharge and Related Matters) Rules, 2022 as amended from time to time shall be levied by the generating company or the transmission licensee, as the case may be.

Provided that in case a different LPS mechanism is provided in the PPA, the same shall be governed by the provisions of the PPA.

Provide further that unless otherwise agreed by the parties, the charges payable by a beneficiary or long term customer shall be first adjusted towards a late payment surcharge on the outstanding charges and, thereafter, towards monthly charges billed by the generating company or the transmission licensee, as the case may be, starting from the longest overdue bill.

CHAPTER 8: COMPONENTS OF ARR AND TARIFF FOR DISTRIBUTION WHEELING BUSINESS

75 Separation of accounts

- 75.1 The distribution licensee shall segregate the accounts of the licensed business into Wheeling Business and Retail Supply Business and submit separate ARR for respective businesses. The ARR for wheeling business shall be used to determine wheeling charges recoverable from open access consumers and the ARR for Retail Supply Business to determine retail supply tariff for sale of electricity to different categories of consumers of the licensee which will be inclusive of wheeling charges.

Provided that till such time the accounts are segregated as per provisions of these regulations, the distribution licensee shall prepare an allocation statement to apportion costs and revenues to respective business. The allocation statement shall be approved by the Board of Directors of the distribution licensee and accompanied with an explanation of the methodology which should be consistent over the control period.

76 Applicability

- 76.1 The Regulations contained in this Chapter shall apply in determining tariff payable for usage of distribution wires of a Distribution Licensee by a Distribution System User.

77 Components of Aggregate Revenue Requirement for Distribution Wheeling Business

- 77.1 The wheeling charges for Distribution Wheeling Business of the Distribution Licensee shall provide for the recovery of the Aggregate Revenue Requirement, as provided in Regulation 81 of these Regulations and shall comprise the following:

Aggregate Revenue Requirement:

- a) Return on Equity Capital;
- b) Interest on Loan Capital;
- c) Depreciation;
- d) Operation and maintenance expenses;
- e) Interest on working capital and deposits from Distribution System Users;
- f) Provision for Bad and doubtful debts; and
- g) Income tax.

Wheeling charges = Aggregate Revenue Requirement, as above, minus:

- h) Non-tariff income; and
- i) Income from Other Business, to the extent specified in these Regulations, and
- j) Receipts on account of additional surcharge on charges of wheeling.

- 77.2 The wheeling charges of the Distribution Licensee shall be determined by the Commission on the basis of an application for determination of tariff made by the Distribution Licensee in accordance with Chapter 3 of these Regulations.

Provided that the Wheeling Charges may be denominated in terms of Rupees/kWh or Rupees/kW/month, for the purpose of recovery from the Distribution System User, or any such denomination, as stipulated by the Commission from time to time.

78 Multi-Year Tariff

Except where exempted by the Commission, the Regulations contained in Chapter 3 of these Regulations shall apply to all Distribution Licensees in the State with effect from April 1st, 2025.

79 Capital Investment Plan

- 79.1 The Distribution Licensee shall submit a Capital investment plan, as part of the MYT Petition, to the Commission in accordance with Regulation 6 including complete details of its proposed capital expenditure projects:
- 79.2 The Commission shall review the Capital Investment Plan submitted by the Distribution Licensee taking into consideration the prudence of the proposed expenditure and estimated impact on transmission charges in accordance with Regulation 7.
- 79.3 The Distribution Licensee shall submit, along with the MYT Petition or along with the Petition for Annual Performance Review, as the case may be, details showing the progress of capital expenditure projects, together with such other information, particulars or documents as the Commission may require to assess such progress.

80 Capital cost

- 80.1 The approved Capital Investment Plan of the Distribution Licensee shall be the basis for determining the annual allowable capital cost for each financial year for any capital expenditure project initiated on or after April 1st, 2025.
- 80.2 For each capital expenditure project, the sum total of annual allowable capital cost from the date of commencement of such project till the date of commissioning shall be the original cost of such project.
- 80.3 The provisions of the Statements of Accounting Standards (AS10): Accounting for Fixed Assets of the Institute of Chartered Accountants of India shall apply, to the extent not inconsistent with these Regulations, in determining the original cost of capital expenditure projects and/or original cost of fixed assets capitalised.
- 80.4 The capital cost shall be allowed as provided in Regulation 29.
- 80.5 The amount of any contributions made by consumers and Distribution System Users towards works for access to the distribution system of the Distribution Licensee shall be deducted from

the original cost for such project for the purpose of calculating the Equity Capital, as provided in these Regulations.

81 Calculation of Aggregate Revenue Requirement

81.1 Return on Equity Capital

81.1.1 The Distribution Licensee shall be allowed a return on equity capital on Distribution Wheeling Business, as specified in Regulation 34 of these Regulations.

81.2 Interest on Loan capital

81.2.1 The Distribution Licensee shall be allowed interest on the Loan Capital, as specified in Regulation 35 of these Regulations.

81.3 Depreciation

81.3.1 The Distribution Licensee shall be permitted to recover depreciation on the value of fixed assets used in the Distribution Business as specified in Regulation 33 of these Regulations.

81.4 Operation and Maintenance expenses

81.4.1 The Distribution Licensee shall be allowed O&M expense as provided in Regulation 38 of these Regulations.

81.5 Contribution to Contingency Reserve

81.5.1 The Distribution Licensee may make an appropriation to the Contingency Reserve of a sum not exceeding 0.1 per cent of the gross fixed assets approved by the Commission at the beginning of the year, for each year, which shall be allowed in the calculation of aggregate revenue requirement:

Provided that where the amount of such Contingency Reserve exceeds one (1) per cent of the gross fixed assets, no such appropriation shall be allowed, which would have the effect of increasing the reserve beyond the said maximum:

Provided further that the amount so appropriated may be invested in securities and fixed deposit. Interest earned shall be added to the Contingency Reserve.

Provided further that the amount of such Contingency Reserve shall not be utilized for any other purpose except for reasons specified in these Regulations.

Provided also that the Distribution Licensee shall maintain separate account for such reserve.

81.5.2 The Contingency Reserve shall not be drawn upon during the term of the licence except to meet such charges as may be approved by the Commission as being the expenses arising out of accidents, natural calamities or circumstances beyond the control of the Licensee;

Provided that such drawal from Contingency Reserve shall be computed after making due adjustments for any other compensation that may have been received by the Licensee as part of an insurance cover and Government Grant, if any.

81.6 Interest on security deposits

81.6.1 Interest on security deposits shall be at the SBI base rate as on 1st April of the respective financial year.

81.7 Interest on working capital

81.7.1 The Distribution Licensee shall be allowed interest on the estimated level of working capital, as specified in Regulation 37 of these Regulations.

81.8 Provision for Bad and doubtful debts

81.8.1 The Commission may allow a provision for bad and doubtful debts upto 1% of the amount shown as receivables in the audited accounts of the Distribution Licensee, duly allocated for the Wheeling Business for each year of the Control period:

Provided that if subsequent to the write off of a particular bad debt, revenue is realized from such bad debt, the same shall be included as an uncontrollable item under the Non-Tariff Income of the year in which such sum is realized.

Provided that where the cumulative amount of such provisioning for bad and doubtful debts exceeds five (5) per cent of the amount shown as receivables in the audited accounts in any year of the Distribution Licensee duly allocated for the Wheeling Business, no such appropriation shall be allowed which would have the effect of increasing the provisioning beyond the said maximum.

82 Non-Tariff Income

82.1 The amount of non-tariff income relating to the Distribution Business as approved by the Commission shall be deducted from the Aggregate Revenue Requirement in determining the wheeling charges of Distribution Wheeling Business of the Distribution Licensee:

Provided that the Distribution Licensee shall submit full details of its forecast of non-tariff income to the Commission along with its application for determination of wheeling charges.

The indicative list of various heads to be considered for non-tariff income shall be as under-

- (a) Income from rent of land or buildings or other assets;
- (b) Income from trading;
- (c) Income from sale of scrap;
- (d) Income from hire charges from contactors;
- (e) Income from sale of tender documents;

- (f) Income from open access charges;
- (g) Rebate on PP bills;
- (h) Supervision charges for capital works;
- (i) Interest on investments, fixed and call deposits and bank balances;*
- (j) Income from Security Constrained Economic Despatch (SCED) & Market Based Economic Despatch (MBED);
- (k) Miscellaneous receipts and any other income not included above.

*(*Note – Any income from fixed deposit made out of profit of the Distribution Licensee shall not be deducted as Non-Tariff Income, provided the details of the same, certified by the auditor is made available)*

83 Income from Other Business

- 83.1 Where the Distribution Licensee has engaged in any Other Business, an amount equal to one-third of the revenues from such Other Business after deduction of all direct and indirect costs attributed to such Other Business shall be deducted from the Aggregate Revenue Requirement in determining the wheeling charges of Distribution Wheeling Business of the Distribution Licensee:

Provided that the Distribution Licensee shall follow a reasonable basis for allocation of all joint and common costs between the Distribution Business and the Other Business and shall submit the Allocation Statement as approved by the Board of Directors to the Commission along with its application for determination of wheeling charges:

Provided further that where the sum total of the direct and indirect costs of such Other Business exceed the revenues from such Other Business, no amount shall be allowed to be added to the Aggregate Revenue Requirement of the Distribution Licensee on account of such Other Business

84 Determination of Wheeling Charges

- 84.1 The Commission shall specify the wheeling charge of Distribution Wheeling Business of the Distribution Licensee in its Order passed under sub-section (3) of Section 64 of the Act:

Provided that the charges payable by a Distribution System User under this Chapter 8 may comprise any combination of fixed/demand charges, and variable charges, as may be stipulated by the Commission in such Order.

85 Receipts on account of Additional surcharge

- 85.1 The amount received by the Distribution Licensee by way of additional surcharge on charges of Distribution Wheeling Business, as approved by the Commission in accordance with the AERC (Terms and Conditions for Open Access) Regulations, as amended from time to time,

from Distribution System users, shall be deducted from the aggregate revenue requirement in calculating the wheeling charges of such Distribution Licensee.

86 Wheeling losses

86.1 The Distribution Licensee shall be allowed to recover, in kind, the approved level of technical losses arising from the operation of the distribution system:

Provided that the Commission may stipulate a trajectory for wheeling losses at different voltage levels in accordance with Regulation 9.

Provided that any variation between the actual level of wheeling losses and the approved level shall be dealt with, as part of the Annual Performance Review, in accordance with the mechanisms provided in Regulation 8.

CHAPTER 9: COMPONENTS OF ARR AND TARIFF FOR RETAIL SUPPLY BUSINESS

87 Applicability

87.1 These Regulations shall apply for determination of tariff for retail supply of electricity by a Distribution Licensee to its consumers:

88 Components of Tariff

88.1 The tariff for retail supply by a Distribution Licensee shall provide for recovery of the aggregate revenue requirement of the Distribution Licensee for each year of the Control Period, as approved by the Commission and comprising the following: -

88.2 Aggregate revenue requirement:

- (a) Return on Equity Capital;
- (b) Interest on Loan Capital;
- (c) Depreciation;
- (d) Cost of own power generation /power purchase expenses;
- (e) Transmission charges;
- (f) Operation and Maintenance expenses;
- (g) Interest on working capital and on consumer security deposits; and
- (h) Provision for Bad and doubtful debts.
- (i) Income tax

Revenue requirement from sale of electricity = Aggregate revenue requirement, as above,

Minus:

- (j) Non-tariff income;
- (k) Income from Other Business, to extent specified in these Regulations;
- (l) Receipts on account of cross-subsidy surcharge.
- (m) Receipts on account of additional surcharge

88.3 The tariff for retail supply by the Distribution Licensee shall be determined by the Commission on the basis of an application for determination of tariff made by the Distribution Licensee in accordance with Chapter 3 of these Regulations.

88.4 Provided that the Commission may determine tariff for Zones/Circles/Divisions or for the groups of Zones/Circles/Divisions of a Distribution Licensee based on the performance parameters as may be stipulated by the Commission.

88.5 The Distribution Licensee shall be allowed to offer a rebate to the consumers on tariff and charges determined by the Commission:

Provided that the Distribution Licensee shall submit details of such rebates to the Commission every quarter, in the manner and format, as stipulated by the Commission from time to time.

Provided that the impact of such rebates on the Distribution Licensee shall be borne entirely by the Distribution Licensee and impact of such rebate shall not be allowed by the Commission to be passed through to the consumers, in any form.

Provided that such rebates should not to be offered selectively to any consumer/s, and shall have to be offered to the entire consumer category/sub-category/consumption slab in a non-discriminatory manner.

89 Multi-Year Tariff

Except where exempted by the Commission, the Regulations contained in Chapter 3 of these Regulations shall apply to all Distribution Licensees in the State with effect from April 1st, 2025.

90 Capital Investment Plan

90.1 The Distribution Licensee shall submit a detailed Capital investment plan, and physical targets for each year of the Control Period for meeting the requirement of load growth, reduction in distribution losses, increase in collection efficiency, metering, consumer services, etc. to the Commission for approval, along with the MYT Petition:

90.2 The Distribution Licensee shall submit the Capital Investment Plan in accordance with Regulation 6 of these Regulations.

90.3 The Commission shall approve the Capital investment plan in accordance with the principles specified in these Regulations.

91 Capital Cost

91.1 The approved Capital Investment Plan of the Distribution Licensee shall be the basis for determining the annual allowable capital cost for each financial year for any capital expenditure project initiated on or after April 1st, 2025.

91.2 For each capital expenditure project, the sum total of allowable capital cost from the date of commencement of such project till the date of commissioning shall be the original cost of such project:

91.3 The provisions of Accounting Standards (AS10): Accounting for Fixed Assets of the Institute of Chartered Accountants of India, as amended from time to time, shall apply, to the extent not

inconsistent with these Regulations, in determining the original cost of capital expenditure projects and/or original cost of fixed assets capitalised.

91.4 The amount of any contributions made by consumers and Distribution System Users towards works for Retail Supply by the Distribution Licensee shall be deducted from the original cost for such project for the purpose of calculating the Equity Capital, as provided in these Regulations.

91.5 The capital cost shall be allowed as provided in Regulation 29.

92 Sales forecast

92.1 The Distribution Licensee shall submit a monthly forecast of the expected sales of electricity to each tariff category/sub-category and to each tariff slab within such tariff category/sub-category to the Commission for approval along with the MYT Petition, as specified in these Regulations.

92.2 The sales forecast shall be consistent with the load forecast prepared as part of the long-term power procurement plan under Chapter 4 of these Regulations and shall be based on past data and reasonable assumptions regarding the future:

Provided that where the Commission has stipulated a methodology for forecasting sales to any particular tariff category, the Distribution Licensee shall incorporate such methodology in developing the sales forecast for such tariff category.

93 Calculation of Aggregate Revenue Requirement

93.1 Return on Equity Capital

93.1.1 The Distribution Licensee shall be allowed a return on equity capital as specified in Regulation 34 of these Regulations.

93.2 Interest on Loan capital

93.2.1 The Distribution Licensee shall be allowed interest on the Loan Capital, as specified in Regulation 35 of these Regulations.

93.3 Depreciation

93.3.1 The Distribution Licensee shall be permitted to recover depreciation on the value of fixed assets used in the Distribution Business as specified in Regulation 33 of these Regulations.

93.4 Cost of power generation/ power purchases

93.4.1 The Distribution Licensee shall be allowed to recover the cost of power generated by the Generation Business or purchased from approved sources for supply to consumers based on the power procurement plan of the Distribution Licensee, as per Regulation 26 and in the manner as stipulated in Chapter 4 of these Regulations.

93.5 Transmission charges

93.5 Transmission charges

93.5.1 The Distribution Licensee shall be allowed to recover transmission charges payable for access to and use of the intra-State transmission system in accordance with the tariff approved by the Commission under Chapter 7 of these Regulations.

93.6 Operation and Maintenance expenses

93.6.1 The Distribution Licensee shall be allowed O&M expense as provided in Regulation 38 of these Regulations.

93.7 Interest on working capital

93.7.1 The Distribution Licensee shall be allowed interest on the estimated level of working capital, as specified in Regulation 37 of these Regulations.

93.8 Provision for Bad and doubtful debts

93.8.1 The Commission may allow a provision for bad and doubtful debts upto 1% of the amount shown as receivables in the audited accounts of the Distribution Licensee, duly allocated for the Supply Business for each year of the Control period:

Provided that if subsequent to the write off of a particular bad debt, revenue is realized from such bad debt, the same shall be included as an uncontrollable item under the Non-Tariff Income of the year in which such sum is realized.

Provided further that where the amount of such cumulative provisioning for bad and doubtful debts exceeds five (5) per cent of the amount shown as receivables in the audited accounts in any year of the Distribution Licensee duly allocated for the Wheeling Business, no such appropriation shall be allowed which would have the effect of increasing the provisioning beyond the said maximum.

94 Non-Tariff Income

94.1 The amount of non-tariff income relating to the Retail Supply Business as approved by the Commission shall be deducted from the Aggregate Revenue Requirement in calculating the tariff from retail supply of electricity of the Distribution Licensee:

Provided that the Distribution Licensee shall submit full details of its forecast of non-tariff income to the Commission along with its application for determination of tariff.

Provided further that, while considering the Delayed Payment Surcharge earned from consumer as part of Non-Tariff Income, the amount of Delayed Payment Surcharge paid to Long Term Power suppliers shall be deducted.

The indicative list of various heads to be considered for non-tariff income shall be as under-

- (a) Income from rent of land or buildings or other assets;
- (b) Income from trading;
- (c) Income from sale of scrap;

- (d) Income from hire charges from contactors;
- (e) Income from sale of tender documents;
- (f) Income from open access charges;
- (g) Rebate on PP bills;
- (h) Supervision charges for capital works;
- (i) Interest on investments, fixed and call deposits and bank balances;*
- (j) Miscellaneous receipts and any other income not included above.

*(*Note – Any income from fixed deposit made out of profit of the Distribution Licensee shall not be deducted as Non-Tariff Income, provided the details of the same, certified by the auditor is made available)*

95 Income from Other Business

95.1 Where the Distribution Licensee has engaged in any Other Business, an amount equal to one-third of the revenues from such Other Business after deduction of all direct and indirect costs attributed to such Other Business shall be deducted from the Aggregate Revenue Requirement in calculating the tariff from retail supply of electricity by the Distribution Licensee:

Provided that the Distribution Licensee shall follow a reasonable basis for allocation of all joint and common costs between the Distribution Business and the Other Business and shall submit the Allocation Statement as approved by the Board of Directors to the Commission along with its application for determination of tariff:

Provided further that where the sum total of the direct and indirect costs of such Other Business exceed the revenue from such Other Business, no amount shall be allowed to be added to the aggregate revenue requirement of the Distribution Licensee on account of such Other Business.

Provide also that nothing contained in this Regulation shall apply to a local authority engaged, before the commencement of the Act, in the business of distribution of electricity.

96 Receipts on account of cross-subsidy surcharge

96.1 The amount received by the Distribution Licensee by way of cross-subsidy surcharge, as approved by the Commission in accordance with the AERC (Terms and Conditions for Open Access) Regulations, as amended from time to time, shall be deducted from the Aggregate Revenue Requirement in calculating the tariff for retail supply of electricity by such Distribution Licensee.

97 Distribution Losses

97.1 The Commission will specify the distribution loss trajectory for the Control Period.

Provided that Distribution Licensee shall submit distribution loss reduction trajectory during the control period commensurate with Capital Investment plans for approval of the Commission.

Provided that any variation between the actual level of distribution losses and the approved level shall be dealt with, at the time of truing up.

- 97.2 The Distribution Licensee as a part of its MYT Petition shall submit the AT&C Loss trajectory agreed by the State Governments and approved by the Central Government under any National Scheme or Programme, or otherwise:

Provided that the Commission may stipulate trajectory for AT&C losses in its Order on the MYT Petition filed by Distribution Licensee.

98 Time of Day (ToD) Tariff

- 98.1 The Distribution Licensee shall propose ToD tariff for consumers of all categories having load of 10 kW and above in its MYT Petition so that same may be implemented after installation of Smart Meters.

- 98.2 The Distribution Licensee shall also propose the ToD tariff in accordance with the Electricity (Rights of Consumers) Rules, 2020 and its subsequent amendments, giving due consideration to the Solar Hours, along with its MYT Petition:

Provided that Distribution Licensee may proposed seasonal ToD tariff in its MYT Petition.

CHAPTER 10: Terms and Conditions of Determination of ARR and Tariff of SLDC

99 Applicability

- 99.1 These Regulations shall apply for determination of fees and charges to be collected by the SLDC from the users of intra-state transmission system (i.e. Generating companies, transmission and distribution licensee, trading companies and open access consumers)
- 99.2 The transmission licensee notified as State Transmission Utility by the State Govt. as per Section 39(1) of the Act and entrusted with the operation of SLDC shall submit separate ARR for its transmission business and SLDC business, as long as it remains under its control, as per provisions of these regulations. The ARR for each business shall be based on the audited accounts of the corresponding business. After a Government company or an authority or a corporation is established or constituted for operation of SLDC by or under any State Act, as may be notified by the State Govt. as per provisions of Section 31 of the Act, the ARR for SLDC business shall be submitted by such Government company, authority or corporation, as the case may be, as per provisions of these regulations.
- 99.3 The Commission may require the STU or the Government company/Authority/Corporation established for operation of SLDC or the SLDC itself to submit such details/information as may be required for determination of SLDC charges. Further, the Commission may give directions to SLDC in relation to the role and functioning of SLDC.

100 Application for Registration with SLDC

- 100.1 Any new users of intra-State transmission system, which come under the purview of SLDC, shall register themselves with the SLDC, by filing an application to the SLDC along with a fee of Rs 25,000 (Rupees Twenty Five Thousand only) or such amended fees as may be decided by the Commission from time to time.
- 100.2 The new users of intra-State transmission system, shall submit an application to the SLDC, at least one month before the proposed date of connection to the Intra-State transmission system, along with the above-mentioned Fee.
- 100.3 After being satisfied with the completeness and correctness of the information furnished in the application, the SLDC, shall register the application in its records and duly intimate the applicant regarding such registration.
- 100.4 The SLDC shall maintain consolidated information about all the users connected to the Intra-State transmission system and being monitored / serviced by it, on a separate web-page on their web-site.

101 Petition for determination of SLDC Charges

- 101.1 The SLDC shall provide to the Commission, full details of its calculations of its Aggregate

Revenue Requirement for the ensuing financial year, not later than four months before the commencement of the said ensuing Year.

- 101.2 The total annual expenses and return on equity of the SLDC for each financial year of the Control Period shall be worked out on the basis of expenses and return allowed in terms of these Regulations.
- 101.3 The SLDC shall also file the proposed allocation of charges to all the users of intra State Transmission System being monitored and serviced by it in line with these Regulations. SLDC shall further forward a copy of its petition for determination of Aggregate Revenue Requirement along with the proposal for allocation of charges to all the users of intra State Transmission System being monitored and serviced by it.
- 101.4 The SLDC shall provide the details of calculation of the expenses and other related information in the formats as specified by the Commission from time to time.
- 101.5 The SLDC shall also furnish the details of capital investment plan for the control period. For capital investment schemes costing above Rupees 25 lakh, approval of the Commission shall be obtained in respect of each of such schemes prior to commencement of works.
- 101.6 The Aggregate Revenue Requirement and other details filed by the SLDC shall be scrutinised and as a result of such scrutiny, the Commission may call for such further information and clarification as may be required.
- 101.7 Based on the information furnished by SLDC and after due examination, scrutiny and consultation process, the Commission will approve the Aggregate Revenue Requirement covering the expenses of the SLDC and determine the SLDC Charges.
- 101.8 In the event of non-revision of SLDC charges during any year, any variation (shortfall or excess) in recovery of SLDC charges shall be carried forward to the next financial year and adjusted as may be decided by the Commission.
- 101.9 The SLDC shall submit periodic returns containing operational and cost data, as may be prescribed by the Commission.
- 101.10 All filings and application for determination of SLDC Charges shall be made in conformity with the stipulations made in these Regulations

102 Levy of SLDC Charges

- 102.1 All expenses incurred by the SLDC, established by the State Government under Section 31 of the Act, shall be accounted for separately;

Provided that if on the date of publication of these Regulations, the State Transmission Utility (STU) is operating the State Load Despatch Centre and performing the functions under the Act, as provided under sub-clause (2) of Section 31 of the Act, the STU shall maintain separate accounts for expenses related to operation of the State Load Despatch Centre;

Provided further that till such time the accounts are not segregated, the STU shall apportion its costs on the basis of an Allocation Statement to be submitted to the Commission with all relevant details.

103 Annual SLDC Charges

103.1 The annual charges to be recovered by the SLDC shall include the component of Return on Equity and also the following expenses:

- a) O&M expenses;
- b) Return on Equity
- c) Depreciation;
- d) Lease Charges
- e) Interest and Finance charges;
- f) Income Tax, if any;
- g) Interest on working capital, if any;
- h) Statutory fees and charges payable by SLDC;
- i) Any other expenses incidental to discharging the functions of SLDC as deemed appropriate by the Commission;

Minus,

- j) Non-tariff income including but not limited to interest on investment, fees/charges other than SLDC charges, Income from sale of scrap, etc;
- k) Income from open access charges.

Provided that Depreciation, Interest and Finance Charges, Interest on working capital and Return on Equity for the SLDC shall be allowed in accordance with the provisions specified in Chapter 5 of these Regulations:

Provided further that prior period income/expenses shall be allowed by the Commission at the time of truing up based on audited accounts, on a case-to-case basis, subject to prudence check.

Provided also that all penalties and compensation payable by the SLDC to any party for failure to meet its obligations or for damages, as a consequence of the orders of the Commission shall not be allowed to be recovered whereby the details of penalties and compensation paid or payable, if any, is required to be submitted to the Commission along with the Petition under these Regulations.

104 Operation and Maintenance Expenses

104.1 Operation and Maintenance (O&M) expenses shall comprise of the following:-

- a) Salaries, wages, pension contribution and other employee costs;
- b) Administrative and general expenses including insurance charges if any;

c) Repairs and maintenance expenses;

104.2 The O&M expenses for the first year of the Control Period will be approved by the Commission taking into account actual O&M expenses of the previous years and any other factors considered appropriate by the Commission.

104.3 The O&M expenses for the nth year and also for the year immediately preceding the Control Period shall be approved based on the formula given below:-

$$O\&M_n = R\&M_n + EMP_n + A\&G_n$$

Where –

- O&M_n – Operation and Maintenance expense for the nth year;
- EMP_n – Employee Costs for the nth year;
- R&M_n – Repair and Maintenance Costs for the nth year;
- A&G_n – Administrative and General Costs for the nth year;

104.4 The above components shall be computed in the manner specified below:

$$EMP_n = (EMP_{n-1}) \times (1+G_n) \times (\text{CPI inflation})$$

$$R\&M_n = K \times (GFA_{n-1}) \times (\text{WPI inflation}) \text{ and}$$

$$A\&G_n = (A\&G_{n-1}) \times (\text{WPI inflation}) + \text{Provision}$$

Where -

- EMP_{n-1} – Employee Costs for the (n-1)th year;
- A&G_{n-1} – Administrative and General Costs for the (n-1)th year;
- Provision: Cost for initiatives or other one-time expenses as proposed by the SLDC and validated by the Commission.
- 'K' is a constant specified by the Commission in %. Value of K for each year of the control period shall be determined by the Commission in the MYT Tariff order based on SLDC's filing, benchmarking of repair and maintenance expenses, approved repair and maintenance expenses vis-à-vis GFA approved by the Commission in past and any other factor considered appropriate by the Commission;
- CPI inflation – is the average increase in the Consumer Price Index (CPI) for immediately preceding three years;
- WPI inflation – is the average increase in the Wholesale Price Index (WPI) for immediately preceding three years;
- GFA_{n-1} — Gross Fixed Asset of the transmission licensee for the n-1th year;

- G_n is a growth factor for the n th year. Value of G_n shall be determined by the Commission in the MYT tariff order for meeting the additional manpower requirement based on SLDC's filings, benchmarking, and any other factor that the Commission feels appropriate:

105 Non-Tariff Income

105.1 The amount of Non-Tariff Income relating to the SLDC as approved by the Commission shall be deducted from the Aggregate Revenue Requirement in determining the Charges of the SLDC:

Provided that the SLDC shall submit full details of its forecast of Non-Tariff Income to the Commission in such form as may be stipulated by the Commission from time to time.

105.2 The indicative list of various heads that shall be considered under Non-Tariff Income is as under:

- (a) Income from rent on land or buildings;
- (b) Income from sale of scrap;
- (c) Interest on advances to suppliers/contractors;
- (d) Rental from staff quarters;
- (e) Rental from contractors;
- (f) Income from hire charges from contactors and others;
- (g) Scheduling and System Operation Charges;
- (h) Miscellaneous receipts such as application fees, etc.;
- (i) Excess found on physical verification;
- (j) Interest on investments, fixed and call deposits and bank balances;*
- (k) Deferred Income from grant, subsidy, etc., as per Annual Accounts;
- (l) Any Other Non-Tariff Income:

*(*Note – Any income from fixed deposit made out of profit of the SLDC shall not be deducted as Non-Tariff Income, provided the details of the same, certified by the auditor is made available)*

106 Basis for collection of SLDC charges

106.1 The annual SLDC charges as determined by the Commission shall be allocated between the Beneficiaries using the intra-State transmission system on the basis of contracted transmission capacity.

Provided further that SLDC shall be entitled to levy and collect fee and charges for any other services rendered to the users and power exchanges as specified in any other regulations.

- 106.2 The Short-term open access customers using the intra-State transmission system shall however pay only such scheduling charges to the SLDC as may be specified by the Commission.

107 Billing of SLDC Charges:

- 107.1 The SLDC shall furnish necessary monthly bills at the rate of one twelfth of the annual charges as approved by the Commission, to the users of intra State Transmission System being monitored and serviced by it for each billing month within seven days after the last day of the preceding month;

Provided that for the purpose of billing and collection of the prescribed charges, a fraction of a MW shall be treated as one full MW.

- 107.2 The Beneficiaries shall make payment to the SLDC of the amounts due within one month of the date of receipt of the bill.
- 107.3 Disputes arising out of billing of SLDC charges shall be, as far as possible, settled by mutual negotiations. If the disputes are not resolved through mutual negotiations within sixty (60) days of the receipt of the bills, the matter shall be referred to the Commission through a petition by either of the parties. The decision of the Commission shall be final and binding on all the parties.
- 107.4 Pending resolution of the dispute, 90% of the bill amount shall be paid under protest within the due date.

CHAPTER 11: GRANT OF SUBSIDIES BY STATE GOVERNMENT

108 Manner of provision of subsidy by State Government

108.1 Pursuant to Section 65 of the Electricity Act, 2003 in case the State Government requires grant of any subsidy to any consumer or class of consumers in the tariff determined under Section 62 of the Act, the State Government shall, notwithstanding any direction which may be given under Section 108 of the Act, pay, in advance in the manner as may be specified, by the Commission the amount to compensate the person affected by the grant of subsidy in the manner the Commission may direct, as a condition for the licensee or any other person concerned to implement the subsidy provided for by the State Government:

Provided that no such direction of the State Government shall be operative if the payment is not made in accordance with the provisions contained in this section and the tariff fixed by State Commission shall be applicable from the date of issue of orders by the Commission in this regard.

108.2 Accounting of the subsidy payable under section 65 of the Act, shall be done by the Distribution Licensee, in accordance with the Standard Operating Procedures issued by the Central Government, in this regard.

108.3 Distribution Licensee shall submit to the Commission a quarterly report consisting of details w.r.t demands of subsidy raised by Distribution Licensee to the State Government during the relevant quarter based on the accounts of the energy consumed by the subsidized category and consumer category wise per unit subsidy declared by the State Government, the actual payment of subsidy in accordance with section 65 of the Act and the gap in subsidy due and paid as well as other relevant details, as may be specified by the Commission and / or Ministry of Power vide its Rules framed under the provisions of the Act.

Explanation: The term "Unit" means Kilo Watt Hour (kWh) or Kilo Watt (kW) or Horse Power (HP) or Kilo Volt Ampere (kVA), in accordance with the relevant Regulations or the Tariff Orders issued by the Commission.

108.4 The quarterly report shall be submitted by the distribution licensee within 30 days from end date of the respective quarter and the State Commission shall examine the report, and issue it with corrections, if any, in accordance with sub-rule (2), within thirty days of the submission.

108.5 In case subsidy has not been paid in advance, the Commission shall issue order for implementation of the tariff without subsidy, in accordance with provisions of the section 65 of the Act.

108.6 If subsidy accounting and the bills raised for subsidy is not found in accordance with the Act or Rules or Regulations issued there under, the Commission shall take appropriate action against the concerned officers of the Distribution Licensee for non-compliance as per provisions of the Act.

CHAPTER 12: MISCELLANEOUS

109 Hearing

- 109.1 The Commission may hold hearing(s) on the ARR/tariff filing and hear such persons as the Commission may consider appropriate to decide on such ARR/tariff filing.
- 109.2 The procedure of hearing on the ARR/Tariff filing shall be as per the provisions of the AERC (Conduct of Business) Regulations, 2004 as amended from time to time or in the manner as the Commission may decide from time to time.

110 Issue of Orders and Directions

- 110.1 Subject to the provision of the Act and these regulations, the Commission may, from time to time, issue orders and directions in regard to the implementation of these regulations and procedure to be followed on various matters.

111 Interpretation

- 111.1 If a question arises relating to the interpretation of any provision of these regulations, the decision of the Commission shall be final.

112 Sharing of CDM Benefits

- 112.1 The proceeds of carbon credit from approved CDM project shall be shared in the following manner, namely-
- (i) 100% of the gross proceeds on account of CDM to be retained by the project developer in the first year after the date of commercial operation of the generating station or the transmission system or the distribution system, as the case may be;
 - (ii) in the second year, the share of the beneficiaries shall be 10% which shall be progressively increased by 10% every year till it reaches 50%, where after the proceeds shall be shared in equal proportion, by the generating company or the transmission or distribution licensee, as the case may be, and the beneficiaries.

113 Norms of operation to be ceiling norms

- 113.1 Norms of operation specified in these regulations are the ceiling norms and shall not preclude the generating company or the transmission licensee or the distribution licensee, as the case may be, and the beneficiaries and the long-term transmission and distribution customers from agreeing to the improved norms of operation and in case the improved norms are agreed to, such improved norms shall be applicable for determination of tariff.

114 Power to Amend

- 114.1 The Commission may, at any time, vary, alter, modify or amend any provisions of these Regulations.

115 Power to remove difficulties

- 115.1 If any difficulty arises in giving effect to any of the provisions of these regulations, the Commission may, by a general or special order, not being inconsistent with the provisions of these regulations or the Act, do or undertake to do things or direct the generating company or the licensee to do or undertake such things which appear to be necessary or expedient for the purpose of removing the difficulties.

116 Power to Relax

- 116.1 The Commission may by general or special order, for reasons to be recorded in writing, and after giving an opportunity of hearing to the parties likely to be affected may relax any of the provisions of these regulations on its own motion or on an application made before it by an interested person.

117 Saving of Inherent Powers of the Commission

- 117.1 Nothing in these regulations shall be deemed to limit or otherwise affect the inherent power of the Commission to make such orders as may be necessary for ends of justice or to protect consumers' interest or to prevent the abuse of the process of the Commission.
- 117.2 Nothing contained in these regulations shall limit or otherwise affect the inherent powers of the Commission from adopting a procedure, which is at variance with any of the provisions of these regulations, if the Commission, in view of the special circumstances of the matter or class of matters and for reasons to be recorded in writing, deems it necessary or expedient to depart from the procedure specified in these regulations.
- 117.3 Nothing in these regulations shall, expressly or by implication, bar the Commission to deal with any matter or exercise any power under the Act for which no regulations have been framed, and the Commission may deal with such matters, powers and functions in a manner it thinks fit.

118 Repeal

- 118.1 Save as otherwise provided in these Regulations, the "Assam Electricity Regulatory Commission (Terms and Conditions for determination of Multi Year Tariff) Regulations, 2021 and amendments thereof" are hereby repealed.
- 118.2 Notwithstanding such repeal, any proceedings before the Commission pertaining to the period till FY 2024-25, including review Petitions, shall be governed by the "Assam Electricity Regulatory Commission (Terms and Conditions for determination of Multi Year Tariff) Regulations, 2021 and amendments" thereof.

Appendix I

Depreciation Schedule

Sr. No.	Asset Particulars	Depreciation Rate (Salvage Value = 10%)
		SLM
A	Land under full ownership	0.00%
B	Land under lease	
(a)	for investment in the land	3.34%
(b)	For cost of clearing the site	3.34%
(c)	Land for reservoir in case of hydro generating station	3.34%
C	Assets purchased new	
a.	Plant & Machinery in generating stations	
(i)	Hydro electric	5.28%
(ii)	Steam electric NHRB & waste heat recovery boilers	5.28%
(iii)	Diesel electric and gas plant	5.28%
b.	Cooling towers & circulating water systems	5.28%
c.	Hydraulic works forming part of the Hydro-generating stations	
(i)	Dams, Spillways, Weirs, Canals, Reinforced concrete flumes and siphons	5.28%
(ii)	Reinforced concrete pipelines and surge tanks, steel pipelines, sluice gates, steel surge tanks, hydraulic control valves and hydraulic works	5.28%
d.	Building & Civil Engineering works	
(i)	Offices and showrooms	3.34%
(ii)	Containing thermo-electric generating plant	3.34%
(iii)	Containing hydro-electric generating plant	3.34%
(iv)	Temporary erections such as wooden structures	100.00%
(v)	Roads other than Kutcha roads	3.34%
(vi)	Others	3.34%

e.	Transformers, Kiosk, sub-station equipment & other fixed apparatus (including plant foundations)	
(i)	Transformers including foundations having rating of 100 KVA and over	5.28%
(ii)	Others	5.28%
f.	Switchgear including cable connections	5.28%
g.	Lightning arrestor	
(i)	Station type	5.28%
(ii)	Pole type	5.28%
(iii)	Synchronous condenser	5.28%
h.	Batteries	18%
(i)	Underground cable including joint boxes and disconnected boxes	5.28%
(ii)	Cable duct system	5.28%
i.	Overhead lines including cable support	
(i)	Lines on fabricated steel operating at terminal voltages higher than 66 KV	5.28%
(ii)	Lines on steel supports operating at terminal voltages higher than 13.2 KV but not exceeding 66 KV	5.28%
(iii)	Lines on steel on reinforced concrete support	5.28%
(iv)	Lines on treated wood support	5.28%
j.	Meters	5.28%
k.	Self propelled vehicles	9.50%
l.	Air Conditioning Plants	
(i)	Static	5.28%
(ii)	Portable	9.50%
m.(i)	Office furniture and furnishing	6.33%
(ii)	Office equipment	6.33%
(iii)	Internal wiring including fittings and apparatus	6.33%
(iv)	Street Light fittings	5.28%
n.	Apparatus let on hire	
(i)	Other than motors	9.50%
(ii)	Motors	6.33%
o.	Communication equipment	
(i)	Radio and high frequency carrier system	6.33%

(ii)	Telephone lines and telephones	6.33%
p.	I. T Equipment including software	15.00%
q.	Any other assets not covered above	5.28%

Note: Where the life of the particular asset is less than the useful life of the project, the useful life of such particular asset shall be considered as per the provisions of the Companies Act, 2013 and subsequent amendment thereto.

Appendix II

Depreciation Schedule for New Projects

Sr. No.	Asset Particulars	Depreciation Rate (Salvage Value=10%) SLM
A	Land under full ownership	0.00%
B	Land under lease	
(a)	for investment in the land	3.34%
(b)	For the cost of clearing the site	3.34%
I	Land for reservoir in case of hydro generating station	3.34%
C	Assets purchased new	
a.	Plant & Machinery in generating stations	
(i)	Hydro electric	4.22%
(ii)	Steam electric NHRB & waste heat recovery boilers	4.22%
(iii)	Diesel electric and gas plant	4.22%
b.	Cooling towers & circulating water systems	4.22%
c.	Hydraulic works forming part of the Hydro-generating stations	
(i)	Dams, Spillways, Weirs, Canals, Reinforced concrete flumes and siphons	4.22%
(ii)	Reinforced concrete pipelines and surge tanks, steel pipelines, sluice gates, steel surge tanks, hydraulic control valves and hydraulic works	4.22%
d.	Building & Civil Engineering works	
(i)	Offices and showrooms	3.34%
(ii)	Containing thermo-electric generating plant	3.34%
(iii)	Containing hydro-electric generating plant	3.34%
(iv)	Temporary erections, such as wooden structures	100.00%
(v)	Roads other than Kutcha roads	3.34%
(vi)	Others	3.34%
e.	Transformers, Kiosks, sub-station equipment & other fixed apparatus (including plant)	
(i)	Transformers, including foundations having a rating of 100 KVA and over	4.22%
(ii)	Others	4.22%

Sr. No.	Asset Particulars	Depreciation Rate (Salvage Value=10%) SLM
f.	Switchgear, including cable connections	4.22%
g.	Lightning arrestor	
(i)	Station type	4.22%
(ii)	Pole type	4.22%
(iii)	Synchronous condenser	4.22%
h.	Batteries	9.50%
(i)	Underground cable, including joint boxes and disconnected boxes	4.22%
(ii)	Cable duct system	4.22%
i.	Overhead lines, including cable support	
(i)	Lines on fabricated steel operating at terminal voltages higher than 66 KV	4.22%
(ii)	Lines on steel supports operating at terminal voltages higher than 13.2 KV but not exceeding 66 KV	4.22%
(iii)	Lines on steel on reinforced concrete support	4.22%
(iv)	Lines on treated wood support	4.22%
j.	Meters	4.22%
k.	Self propelled vehicles	9.50%
l.	Air Conditioning Plants	
(i)	Static	4.22%
(ii)	Portable	9.50%
m.(i)	Office furniture and furnishing	6.33%
(ii)	Office equipment	6.33%
(iii)	Internal wiring, including fittings and apparatus	6.33%
(iv)	Street Light fittings	4.22%
n.	Apparatus let on hire	
(i)	Other than motors	9.50%
(ii)	Motors	6.33%

Sr. No.	Asset Particulars	Depreciation Rate (Salvage Value=10%) SLM
o.	Communication equipment	
(i)	Radio and high frequency carrier system	15.00%
(ii)	Telephone lines and telephones	15.00%
(iii)	Fibre Optic/OPGW	6.33%
p.	I. T Equipment including software UNMS, URTDSM, EMS, Cyber Security System, REMC, WAMS, SCADA system	15.00%
q.	Any other assets not covered above	4.22%

Note: Where the life of the particular asset is less than the useful life of the project, the useful life of such particular asset shall be considered as per the provisions of the Companies Act, 2013 and subsequent amendment thereto

Appendix III

Procedure for Calculation of Transmission SystemAvailability Factor for a Month

1. Transmission system availability factor for nth calendar month ("TAFMn") shall be calculated by the respective transmission licensee, separately for each AC and HVDC transmission system and grouped according to sharing of transmission charges.
2. Transmission system availability factor for nth calendar month ("TAFMn") shall be calculated by considering the following:
 - i) **AC transmission lines:** Each circuit of AC transmission line shall be considered as one element;
 - ii) **Inter-Connecting Transformers (ICTs):** Each ICT bank (three single-phase transformers together) shall form one element;
 - iii) **Static VAR Compensator (SVC):** SVC, along with SVC transformer, shall form one element;
 - iv) **Bus Reactors or Switchable line reactors:** Each Bus Reactors or Switchable line reactors shall be considered as one element;
 - v) **HVDC Bi-pole links:** Each pole of the HVDC link, along with associated equipment at both ends, shall be considered as one element;
 - vi) **HVDC back-to-back station:** Each block of the HVDC back-to-back station shall be considered as one element. If the associated AC line (necessary for the transfer of inter-regional power through the HVDC back-to-back station) is not available, the HVDC back-to-back station block shall also be considered unavailable;
 - vii) **Static Synchronous Compensation ("STATCOM"):** Each STATCOM shall be considered as a separate element.
3. The Availability of the AC and HVDC portion of the Transmission system shall be calculated by considering each category of transmission elements as under:

TAFMn (in %) for AC system:

$$= \frac{(o \times AV_o) + (p \times AV_p) + (q \times AV_q) + (r \times AV_r) + (u \times AV_u)}{(o + p + q + r + u)} \times 100$$

Where,

o = Total number of AC lines.

AVo	=	Availability of o number of AC lines
p	=	Total number of bus reactors/switchable line reactors
AVp	=	Availability of p number of bus reactors/switchable line reactors
q1	=	Total number of ICTs
AVq	=	Availability of q number of ICTs
r	=	Total number of SVCs
AVr	=	Availability of r number of SVCs
u	=	Total number of STATCOM
AVu	=	Availability of u number of STATCOM

TAFMn (in %) for HVDC System:

$$= \frac{\sum_{x=1}^s Cx_{bp}(\text{act}) \times AVx_{bp} + \sum_{y=1}^t Cy(\text{act})_{btb} \times AVy_{btb}}{\sum_{x=1}^s Cx_{bp} + \sum_{y=1}^t Cy_{btb}} \times 100$$

Where,

Cx _{bp} (act)	=	Total actual operated capacity of xth HVDC pole
Cx _{bp}	=	Total rated capacity of xth HVDC pole
AVx _{bp}	=	Availability of xth HVDC pole
Cy _{btb} (act)	=	Total actual operated capacity of yth HVDC back-to-back station block
Cy _{btb}	=	Total rated capacity of yth HVDC back-to-back station block
AVy _{btb}	=	Availability of yth HVDC back-to-back station block
s	=	Total no of HVDC poles
t	=	Total no of HVDC Back to Back blocks

4. The availability for each category of transmission elements shall be calculated based on the weightage factor, total hours under consideration and non-available hours for each element of that category. The formulae for calculation of the Availability of each category of the transmission elements are as per **Appendix-IV**. The weightage factor for each category of transmission elements shall be considered as under:

- For each circuit of the AC line – The number of sub-conductors in the line multiplied by ckt-km;
- For each HVDC pole- The rated MW capacity;

- (c) For each ICT bank – The rated MVA capacity;
 - (d) For SVC- The rated MVAR capacity (inductive and capacitive);
 - (e) For Bus Reactor/switchable line reactors – The rated MVAR capacity;
 - (f) For HVDC back-to-back stations - Rated MW capacity of each block; and
 - (g) For STATCOM – Total rated MVAR Capacity.
5. The transmission elements under outage due to the following reasons shall be deemed to be available:
- i. Shut down availed for maintenance of another transmission scheme or construction of new element or renovation/upgradation/additional capitalization in an existing system approved by the Commission. If the other transmission scheme belongs to the transmission licensee, SLDC may restrict the deemed availability period to that considered reasonable for the work involved. In case of a dispute regarding deemed availability, the matter may be referred to the Grid Code Management Committee (GCMC), within 30 days.
 - ii. Switching off of a transmission line to restrict over-voltage and manual tripping of switched reactors as per the directions of the SLDC.
6. For the following contingencies, the outage period of transmission elements, as certified by the SLDC, shall be excluded from the total time of the element under the period of consideration for the following contingencies:
- i. Outage of elements due to force majeure events beyond the control of the transmission licensee. However, whether the same outage is due to force majeure (not design failure) will be verified by the SLDC. A reasonable restoration time for the element shall be considered by SLDC (or State Power Committee, if applicable), and any additional time taken by the transmission licensee for restoration of the element beyond the reasonable time shall be treated as outage time attributable to the transmission licensee. SLDC (or State Power Committee, if applicable) may consult the transmission licensee or any expert for estimation of reasonable restoration time. Circuits restored through ERS (Emergency Restoration System) shall be considered as available;
 - ii. Outage caused by grid incident/disturbance not attributable to the transmission licensee, e.g. faults in a substation or bays owned by another agency causing an outage of the transmission licensee's elements, and tripping of lines, ICTs, HVDC, etc., due to grid disturbance. However, if the element is not restored on receipt of direction from SLDC while normalizing the system following grid incident/disturbance within reasonable time, the element will be considered not available for the period of outage after issuance of SLDC's direction for restoration;
 - iii. The outage period which can be excluded for the purpose of sub-clause (i) and (ii) of this clause shall be declared as under:
 - a) Maximum up to one month by the SLDC;

- b) Beyond one month and up to three months by Grid Code Management Committee;
- c) Beyond three months by the Commission for which the transmission license shall approach the Commission along with reasons and steps taken to mitigate the outage and restoration timeline.

7. Time frame for certification of transmission system availability:

- i. The following schedule shall be followed for certification of availability by the SLDC:
 - Submission of outage data along with documentary proof (if any) and TAFPn calculation by Transmission Licensees to SLDC/ constituents – By the 5th of the following month;
 - Review of the outage data by SLDC / constituents and Issue of availability certificate by SLDC by the 3rd of the next month;

Appendix IV

Formulae for Calculation of Availability of Each Category of Transmission Elements

For AC transmission system

AVo(Availability of o no. of AC lines)	$= \frac{\sum_{i=1}^o W_i(T_i - TNA_i) / T_i}{\sum_{i=1}^o W_i}$
AVq(Availability of q no. of ICTs)	$= \frac{\sum_{k=1}^q W_k(T_k - TNA_k) / T_k}{\sum_{k=1}^q W_k}$
AVr(Availability of r no. of SVCs)	$= \frac{\sum_{l=1}^r W_l(T_l - TNA_l) / T_l}{\sum_{l=1}^r W_l}$
AVp(Availability of p no. of Switched Bus reactors)	$= \frac{\sum_{m=1}^p W_m(T_m - TNA_m) / T_m}{\sum_{m=1}^p W_m}$
AVu (Availability of u no. of STATCOMs)	$= \frac{\sum_{n=1}^u W_n(T_n - TNA_n) / T_n}{\sum_{n=1}^u W_n}$
AVx _{bp} (Availability of an individual HVDC pole)	$= \frac{(T_x - T_N)}{T_x}$
AVy _{btb} (Availability of an individual HVDC Back-to-back Blocks)	$= \frac{(T_x - T_N)}{T_x}$

For the HVDC transmission system

For the new HVDC commissioned but not completed twelve months;

For first 12 months: [(AV_{xbp} or AV_{ybtb})x95%/85%], subject to a ceiling of 95%.

Where,

o = Total number of AC lines;

AV_o	=	Availability of o number of AC lines;
p	=	Total number of bus reactors/switchable line reactors;
AV_p	=	Availability of p number of bus reactors/switchable line reactors;
q	=	Total number of ICTs;
AV_q	=	Availability of q number of ICTs;
r	=	Total number of SVCs;
AV_r	=	Availability of r number of SVCs;
U	=	Total number of STATCOM;
AV_u	=	Availability of u number of STATCOMs;
W_i	=	Weightage factor for i th transmission line;
W_k	=	Weightage factor for k th ICT;
W_l	=	Weightage factors for inductive & capacitive operation of l th SVC;
W_m	=	Weightage factor for m th bus reactor;
W_n	=	Weightage factor for n th STATCOM.
$T_i, T_k, T_l, T_m, T_n, T_x, T_y$	-	The total hours of i th AC line, k th ICT, l th SVC, m th Switched Bus Reactor & n th STATCOM, x th HVDC pole and y th HVDC back-to-back block during the period under consideration (excluding time period for outages not attributed to transmission licensee for the reasons given in Para 5 of the procedure)
T_{iA}, T_{iAK}		The non-availability hours (excluding the time period for outages not T_{iA} , T_{iAK} , attributable to transmission licensee taken as deemed availability as T_{iAN} , T_{iAN} , T_{iAX} , T_{iAY} per Para 5 of the procedure) for i th AC line, k th ICT, l th SVC, m th Switched Bus Reactor, n th STATCOM, x th HVDC pole and y th HVDC back-to-back block.

ASHOK KUMAR BARMAN (RETD.),
Secretary,
Assam Electricity Regulatory Commission.